



PRETREATMENT PERMIT

issued to

Reliable Plating and Polishing Co., Inc.
80 Bishop Avenue
Bridgeport, CT 06607

Location Address:

80 Bishop Avenue
Bridgeport, CT

Permit ID: SP0000106

Permit Expires: June 10, 2019

SECTION 1: GENERAL PROVISIONS

- (A) This permit is reissued in accordance with section 22a-430 of Chapter 446k, Connecticut General Statutes ("CGS"), and Regulations of Connecticut State Agencies ("RCSA") adopted thereunder, as amended, and a modified Memorandum of Agreement dated June 3, 1981, by the Administrator of the United States Environmental Protection Agency ("EPA") which authorizes the State of Connecticut to administer a Pretreatment Program pursuant to 40 CFR Part 403.
- (B) Reliable Plating and Polishing Co., Inc., ("Permittee"), shall comply with all conditions of this permit including the following sections of the RCSA which have been adopted pursuant to section 22a-430 of the CGS and are hereby incorporated into this permit. Your attention is especially drawn to the notification requirements of subsections (i)(2), (i)(3), (j)(1), (j)(6), (j)(8), (j)(9)(C), (j)(11)(C), (D), (E), and (F), (k)(3) and (4) and (l)(2) of section 22a-430-3.

Section 22a-430-3 General Conditions

- (a) Definitions
- (b) General
- (c) Inspection and Entry
- (d) Effect of a Permit
- (e) Duty
- (f) Proper Operation and Maintenance
- (g) Sludge Disposal
- (h) Duty to Mitigate
- (i) Facility Modifications; Notification
- (j) Monitoring, Records and Reporting Requirements
- (k) Bypass
- (l) Conditions Applicable to POTWs
- (m) Effluent Limitation Violations (Upsets)
- (n) Enforcement
- (o) Resource Conservation
- (p) Spill Prevention and Control
- (q) Instrumentation, Alarms, Flow Recorders
- (r) Equalization

Section 22a-430-4 Procedures and Criteria

- (a) Duty to Apply
- (b) Duty to Reapply
- (c) Application Requirements
- (d) Preliminary Review
- (e) Tentative Determination
- (f) Draft Permits, Fact Sheets
- (g) Public Notice, Notice of Hearing
- (h) Public Comments
- (i) Final Determination

- (j) Public Hearings
 - (k) Submission of Plans and Specifications. Approval.
 - (l) Establishing Effluent Limitations and Conditions
 - (m) Case by Case Determinations
 - (n) Permit issuance or renewal
 - (o) Permit Transfer
 - (p) Permit revocation, denial or modification
 - (q) Variances
 - (r) Secondary Treatment Requirements
 - (s) Treatment Requirements for Metals and Cyanide
 - (t) Discharges to POTWs - Prohibitions
- (C) Violations of any of the terms, conditions or limitations contained in this permit may subject the Permittee to enforcement action, including but not limited to, penalties, injunctions and/or forfeitures pursuant to applicable sections of the CGS and RCSA. Specifically, civil penalties of up to twenty-five thousand dollars may be assessed per violation per day.
- (D) Any false statement in any information submitted pursuant to this permit may be punishable as a criminal offense under section 22a-438 or 22a-131a of the CGS or in accordance with section 22a-6, under section 53a-157b of the CGS.
- (E) The authorization to discharge under this permit may not be transferred without prior written approval of the Commissioner of Energy and Environmental Protection ("the Commissioner"). To request such approval, the Permittee and proposed transferee shall register such proposed transfer with the Commissioner at least thirty (30) days prior to the transferee becoming legally responsible for creating or maintaining any discharge which is the subject of the permit transfer. Failure by the transferee to obtain the Commissioner's approval prior to commencing such discharge(s) may subject the transferee to enforcement action for discharging without a permit pursuant to applicable sections of the CGS and RCSA.
- (F) Nothing in this permit shall relieve the Permittee of other obligations under applicable federal, state and local law.
- (G) An annual fee shall be paid for each year this permit is in effect as set forth in section 22a-430-7 of the RCSA.

SECTION 2: DEFINITIONS

- (A) The definitions of the terms used in this permit shall be the same as the definitions contained in section 22a-423 of the CGS and sections 22a-430-3(a) and 22a-430-6 of the RCSA.
- (B) In addition to the above, the following definitions shall apply to this permit:

"----" in the limits column on the monitoring table means a limit is not specified but a value must be reported on the Discharge Monitoring Report ("DMR").

"Average Monthly Limit" means the maximum allowable "Average Monthly Concentration" as defined in section 22a-430-3(a) of the RCSA when expressed as a concentration (e.g. mg/l). Otherwise, it means "Average Monthly Discharge Limitation" as defined in section 22a-430-3(a) of the RCSA.

"Daily Concentration" means the concentration of a substance as measured in a daily composite sample, or the arithmetic average of all grab sample results defining a grab sample average.

"Daily Quantity" means the quantity of waste generated during an operating day.

"Grab Sample Average ("GSA")" means the arithmetic average of all grab sample analyses. Grab samples shall be collected just prior to discharge from each tank over a full operating day for as long as a discharge exists on that day (minimum of two grab samples per day).

"Instantaneous Limit" means the highest allowable concentration of a substance as measured by a grab sample, or the highest allowable measurement of a parameter as obtained through instantaneous monitoring.

"Maximum Daily Limit" means the maximum allowable "Daily Concentration" (defined above) when expressed as a concentration (e.g. mg/l). Otherwise, it means the maximum allowable "Daily Quantity" as defined above unless it is expressed as a flow quantity. If expressed as a flow quantity it means "Maximum Daily Flow" as defined in section 22a-430-3(a) of the RCSA.

"mg/l" means milligrams per liter.

"NA" as a monitoring table abbreviation means "not applicable".

"NR" as a monitoring table abbreviation means "not required".

"Range During Sampling" or "RDS", as a sample type, means the maximum and minimum of all values recorded as a result of analyzing each grab sample of 1) a Composite Sample, or 2) a Grab Sample Average. For those permittees with continuous monitoring and recording pH meters, Range During Sampling shall mean the maximum and minimum readings recorded with the continuous monitoring device during the Composite or Grab Sample Average sample collection.

"Quarterly", in the context of a sampling frequency, means sampling is required in the months of March, June, September, and December.

SECTION 3: COMMISSIONER'S DETERMINATION

- (A) The Commissioner has made a final determination and found that continued use of the existing system to treat the discharge will protect the waters of the state from pollution. The Commissioner's decision is based on Application No. 201206671 for permit reissuance received on October 26, 2012 and the administrative record established in the processing of that application.
- (B)
 - (1) From the issuance of this permit through and including June 30, 2014, the Commissioner hereby authorizes the Permittee to discharge in accordance with the terms and conditions of Permit No. SP0000106, issued by the Commissioner to the Permittee on May 1, 2008, the previous application submitted by the Permittee on April 28, 2004, and all modifications and approvals issued by the Commissioner or the Commissioner's authorized agent for the discharge and/or activities authorized by, or associated with, Permit No. SP0000106, issued by the Commissioner to the Permittee on May 1, 2008.
 - (2) From July 1, 2014 until this permit expires or is modified or revoked, the Commissioner hereby authorizes the Permittee to discharge in accordance with the terms and conditions of Permit No. SP0000106, issued by the Commissioner to the Permittee on June 11, 2014, Application No. 201206671 received by the Department on October 26, 2012, and all modifications and approvals issued by the Commissioner or the Commissioner's authorized agent for the discharge and/or activities authorized by, or associated with, Permit No. SP0000106, issued by the Commissioner to the Permittee on June 11, 2014.
- (C) The Commissioner reserves the right to make appropriate revisions to the permit in order to establish any appropriate effluent limitations, schedules of compliance, or other provisions that may be authorized under the Federal Clean Water Act or the CGS or regulations adopted thereunder, as amended. The permit as modified or renewed under this paragraph may also contain any other requirements of the Federal Clean Water Act or CGS or regulations adopted thereunder which are then applicable.

SECTION 4: EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

- (A) The discharges shall not exceed and shall otherwise conform to the specific terms and conditions listed below. The discharges are restricted by, and shall be monitored in accordance with, the tables below.

Table A

Discharge Serial Number: DSN 001-1		Monitoring Location: 1						
Wastewater Description: Metal finishing wastewaters generated by electroplating, electroless nickel plating, passivating, anodizing, buffing, and polishing; boiler blowdown; chiller maintenance wastewater; building maintenance wastewater.								
Monitoring Location Description: Chamber stationed alongside clarification unit								
Discharge is to: The City of Bridgeport East Side Publicly Owned Treatment Works ("POTW")								
PARAMETER	UNITS	FLOW/TIME BASED MONITORING				INSTANTANEOUS MONITORING		
		Average Monthly Limit	Maximum Daily Limit	Sample/Reporting Frequency ²	Sample Type or Measurement to be reported	Instantaneous limit or required range	Sample/Reporting Frequency ²	Sample Type or measurement to be reported
Cadmium, Total	mg/l	0.07	0.11	Weekly	Daily Composite	0.16	NR	Grab
Chromium, Total	mg/l	1.0	2.0	Weekly	Daily Composite	3.0	NR	Grab
Chromium, Hexavalent	mg/l	0.02	0.04	Weekly	GSA	0.06	NR	Grab
Copper, Total	mg/l	1.0	2.0	Weekly	Daily Composite	3.0	NR	Grab
Cyanide, Total	mg/l	0.65	1.2	Weekly	GSA	1.8	NR	Grab
Cyanide, Amenable	mg/l	----	----	Weekly	GSA	NA	NR	NA
Flow, Average Daily ¹	gpd	18,000	NA	Continuously/ Monthly	Daily Flow	NA	NR	NA
Flow, Maximum during 24 hr period ¹	gpd	NA	24,000	Continuously/ Monthly	Daily Flow	NA	NR	NA
Flow, Day of Sampling	gpd	NA	24,000	Weekly	Daily Flow	NA	NR	NA
Lead, Total	mg/l	0.1	0.5	Weekly	Daily Composite	0.75	NR	Grab
Nickel, Total	mg/l	1.0	2.0	Weekly	Daily Composite	3.0	NR	Grab
pH, Day of Sampling	S.U.	NA	NA	NR	NA	6.0-10.0	Weekly	RDS
pH, Minimum	S.U.	NA	NA	NR	NA	6.0	Continuously	Continuously
pH, Maximum	S.U.	NA	NA	NR	NA	10.0	Continuously	Continuously
Silver, Total	mg/l	0.1	0.43	Quarterly	Daily Composite	0.64	NR	Grab
Total Suspended Solids	mg/l	----	----	Weekly	Daily Composite	NA	NR	NA
Total Toxic Organics ("TTOs") ³	mg/l	NA	NA	NR	NA	2.13	Monthly	Grab
Zinc, Total	mg/l	1.0	2.0	Weekly	Daily Composite	3.0	NR	Grab

Table Footnotes:

¹ For this parameter, the Permittee shall maintain at the facility a record of the Total Daily Flow for each day of discharge and shall report the Average Daily Flow and the Maximum Daily Flow for each sampling month.

² The first entry in this column is the 'Sample Frequency'. If this entry is not followed by a 'Reporting Frequency' and the 'Sample Frequency' is more frequent than monthly, then the 'Reporting Frequency' is monthly. If the 'Sample Frequency' is specified as monthly, or less frequently, then the 'Reporting Frequency' is the same as the 'Sample Frequency'.

³ See section 5, paragraph F.

Table Footnotes:

¹ For this parameter, the Permittee shall maintain at the facility a record of the Total Daily Flow for each day of discharge and shall report the Average Daily Flow and the Maximum Daily Flow for each sampling month.

² The first entry in this column is the 'Sample Frequency'. If this entry is not followed by a 'Reporting Frequency' and the 'Sample Frequency' is more frequent than monthly, then the 'Reporting Frequency' is monthly. If the 'Sample Frequency' is specified as monthly, or less frequently, then the 'Reporting Frequency' is the same as the 'Sample Frequency'.

³ See section 5, paragraph F.

Table B									
Discharge Serial Number: DSN 001-A					Monitoring Location: 1				
Wastewater Description: Cyanide batch treatment effluent									
Monitoring Location Description: After 1,300 gallon cyanide destruction tank									
Discharge is to: DSN 001-1									
PARAMETER	UNITS	FLOW/TIME BASED MONITORING				INSTANTANEOUS MONITORING			
		Average Monthly Limit	Maximum Daily Limit	Sample/Reporting Frequency ²	Sample Type or Measurement to be reported	Limit or required range	Sample/Reporting Frequency ²	Sample Type or measurement to be reported	
Flow, Day of sampling	gpd	NR	----	Weekly	Daily Flow	NA	NR	NA	
Cyanide, Amenable	mg/l	NR	NR	NR	NR	0.86	Weekly	Grab	
Table Footnotes:									
¹ For this parameter the Permittee shall maintain at the facility a record of the Total Daily Flow for each day of discharge.									
² The first entry in this column is the 'Sample Frequency'. If this entry is not followed by a 'Reporting Frequency' and the 'Sample Frequency' is more frequent than monthly then the 'Reporting Frequency' is monthly. If the 'Sample Frequency' is specified as monthly, or less frequently, then the 'Reporting Frequency' is the same as the 'Sample Frequency'.									

Table C									
Discharge Serial Number: DSN 001-B					Monitoring Location: 1				
Wastewater Description: Chromium reduction effluent									
Monitoring Location Description: After 700 gallon chromium reduction tank									
Discharge is to: DSN 001-1									
PARAMETER	UNITS	FLOW/TIME BASED MONITORING				INSTANTANEOUS MONITORING			
		Average Monthly Limit	Maximum Daily Limit	Sample/Reporting Frequency ²	Sample Type or Measurement to be reported	Instantaneous limit or required range	Sample/Reporting Frequency ²	Sample Type or measurement to be reported	
Flow, Day of sampling	gpd	NR	----	Weekly	Daily Flow	NA	NR	NA	
Table Footnotes:									
¹ For this parameter the Permittee shall maintain at the facility a record of the Total Daily Flow for each day of discharge.									
² The first entry in this column is the 'Sample Frequency'. If this entry is not followed by a 'Reporting Frequency' and the 'Sample Frequency' is more frequent than monthly then the 'Reporting Frequency' is monthly. If the 'Sample Frequency' is specified as monthly, or less frequently, then the 'Reporting Frequency' is the same as the 'Sample Frequency'.									

- (B) All samples shall be comprised of only those wastewaters described in this schedule. Therefore, samples shall be taken prior to combination with wastewaters of any other type and after all approved treatment units, if applicable. All samples taken shall be representative of the discharge during standard operating conditions.
- (C) In cases where limits and sample type are specified but sampling is not required, the limits specified shall apply to all samples which may be collected and analyzed by the Department of Energy and Environmental Protection personnel, the Permittee or other parties.

SECTION 5: SAMPLE COLLECTION, HANDLING AND ANALYTICAL TECHNIQUES AND REPORTING REQUIREMENTS

- (A) Chemical analyses to determine compliance with effluent limits and conditions established in this permit shall be performed using the methods approved by the Environmental Protection Agency pursuant to 40 CFR 136 unless an alternative method has been approved in writing in accordance with 40 CFR 136.4 or as provided in section 22a-430-3(j)(7) of the RCSA. Chemicals which do not have methods of analysis defined in 40 CFR 136 shall be analyzed in accordance with methods specified in this permit.
- (B) All metals analyses identified in this permit shall refer to analyses for total recoverable metal as defined in 40 CFR 136 unless otherwise specified.
- (C) The results of chemical analysis required above shall be entered on the DMR, provided by this office, and reported to the Bureau of Materials Management and Compliance Assurance at the address below. Except for continuous monitoring, any monitoring required more frequently than monthly shall be reported on an attachment to the DMR, and any additional monitoring conducted in accordance with 40 CFR 136 or other methods approved by the Commissioner shall also be included on the DMR, or as an attachment, if necessary. The report shall also include a detailed explanation of any violations of the limitations specified. The DMR shall be received at the address below by the last day of the month following the month in which samples are taken.

Water Permitting and Enforcement Division (Attn: DMR Processing)
Bureau of Materials Management and Compliance Assurance
Connecticut Department of Energy and Environmental Protection
79 Elm Street
Hartford, CT 06106-5127

- (D) If this permit requires monitoring of a discharge on a calendar basis (e.g. monthly, quarterly) but a discharge has not occurred within the frequency of sampling specified in the permit, the Permittee must submit the DMR as scheduled, indicating "NO DISCHARGE". For those permittees whose required monitoring is discharge dependent (e.g. per batch), the minimum reporting frequency is monthly. Therefore, if there is no discharge during a calendar month for a batch discharge, a DMR must be submitted indicating such by the end of the following month.
- (E) NetDMR Reporting Requirements

1. Prior to one-hundred and eighty (180) days after the issuance of this permit, the Permittee may either submit monitoring data and other reports to the Department in hard copy form or electronically using NetDMR, a web-based tool that allows Permittees to electronically submit DMRs and other required reports through a secure internet connection. Unless otherwise approved in writing by the Commissioner, no later than one-hundred and eighty (180) days after the issuance of this permit the Permittee shall begin reporting electronically using NetDMR. Specific requirements regarding subscription to NetDMR, and submittal of data and reports in hard copy form and using NetDMR are described below:

- a. Submittal of *NetDMR Subscriber Agreement*

On or before fifteen (15) days after the issuance of this permit, the Permittee and/or the person authorized to sign the Permittee's DMRs ("Signatory Authority") as described in section 22a-430-3(b)(2) of the RCSA shall contact the Department at deep.netdmr@ct.gov and initiate the NetDMR subscription process for electronic submission of DMR information. Information on NetDMR is available on the Department's website at www.ct.gov/deep/netdmr. On or before ninety (90) days after issuance of this permit, the Permittee shall submit a signed and notarized copy of the *Connecticut DEEP NetDMR Subscriber Agreement* to the Department.

b. Submittal of Reports Using NetDMR

Unless otherwise approved by the Commissioner, on or before one-hundred and eighty (180) days after issuance of this permit, the Permittee and/or the Signatory Authority shall begin electronically submitting DMRs and reports required under this permit to the Department using NetDMR, in satisfaction of the DMR submission requirement of section 5(C) of this permit.

DMRs shall be submitted electronically to the Department no later than the thirtieth (30th) day of the month following the completed reporting period. All reports required under the permit, including any monitoring conducted more frequently than monthly or any additional monitoring conducted in accordance with 40 CFR 136, shall be submitted to the Department as an electronic attachment to the DMR in NetDMR. Once a Permittee begins submitting reports using NetDMR, it will no longer be required to submit hard copies of DMRs or other reports to the Department. The Permittee shall also electronically file any written report of non-compliance described in section 6 of this permit as an attachment in NetDMR. NetDMR is accessed from: <http://www.epa.gov/netdmr>.

c. Submittal of NetDMR Opt-Out Requests

If the Permittee is able to demonstrate a reasonable basis, such as technical or administrative infeasibility, that precludes the use of NetDMR for electronically submitting DMRs and reports, the Commissioner may approve the submission of DMRs and other required reports in hard copy form ("opt-out request"). Opt-out requests must be submitted in writing to the Department for written approval on or before fifteen (15) days prior to the date the Permittee would be required under this permit to begin filing DMRs and other reports using NetDMR. This demonstration shall be valid for twelve (12) months from the date of the Department's approval and shall thereupon expire. At such time, DMRs and reports shall be submitted electronically to the Department using NetDMR unless the Permittee submits a renewed opt-out request and such request is approved by the Department.

All opt-out requests and requests for the NetDMR subscriber form should be sent to the following address or by email at deep.netdmr@ct.gov:

Attn: NetDMR Coordinator
Connecticut Department of Energy and Environmental Protection
79 Elm Street
Hartford, CT 06106-5127

- (F) Copies of all DMRs shall be submitted concurrently to the Bridgeport East Side Publicly Owned Treatment Works ("POTW"), which is involved in the collection and treatment of the permitted discharge.
- (G) For Total Toxic Organics ("TTOs") monitoring, in accordance with section 22a-430-4(1) of the RCSA and 40 CFR 433 (Metal Finishing Point Source Category), the Permittee may, in lieu of analyzing for TTOs, include a statement on each DMR certifying compliance with its approved Solvent Management Plan. This certification statement shall be as follows:

"Based on my inquiry of the person or persons responsible for managing compliance with the permit limitation for Total Toxic Organics (TTO), I certify that, to the best of my knowledge and belief, no dumping of concentrated toxic organics into the wastewaters has occurred since filing the last discharge monitoring report which required such certification. I further certify that this facility is implementing the solvent management plan approved by the Commissioner."

SECTION 6: RECORDING AND REPORTING OF VIOLATIONS, ADDITIONAL TESTING REQUIREMENTS

- (A) If any sample analysis indicates that an effluent limitation specified in section 4 of this permit has been exceeded, a second sample of the effluent shall be collected and analyzed for the parameter(s) in question and the results reported to the Water Permitting and Enforcement Division (Attn: DMR Processing) within thirty (30) days of the exceedance.
- (B) The Permittee shall immediately notify the Water Permitting and Enforcement Division and the Bridgeport East Side Publicly Owned Treatment Works ("POTW") of all discharges that could cause problems to the POTW, including but not limited to slug loadings of pollutants which may cause a violation of the POTW's NPDES permit, or which may inhibit or disrupt the POTW, its treatment processes or operations, or its sludge processes, use or disposal.

- (C) In addition to the notification requirements specified in section 1B of this permit, if any sampling and analysis of the discharge performed by the Permittee indicates a violation of limits specified in section 4 of this permit, the Permittee shall notify the Water Permitting and Enforcement Division within twenty-four (24) hours of becoming aware of the violation.


SECTION 7: COMPLIANCE CONDITIONS

In accordance with 40 CFR 403.8(f)(2)(viii), the Commissioner may provide public notification, in a newspaper of general circulation in the area of the respective POTW, of permittees that at any time in the previous twelve (12) months were in significant noncompliance with the provisions of this permit. For the purposes of this provision, a permittee that is a Significant Industrial User ("SIU") is in significant noncompliance if its violation(s) meet(s) one or more of the following criteria:

- **Chronic violations:** Those in which sixty-six percent (66%) or more of all measurements taken for the same pollutant parameter during a six-month period exceed (by any magnitude) the Average Monthly, Maximum Daily or Maximum Instantaneous Limit(s).
- **Technical Review Criteria violations:** Those in which thirty-three percent (33%) or more of all of the measurements taken for the same pollutant parameter during a six (6) month period equal or exceed the Average Monthly, Maximum Daily or Maximum Instantaneous Limit(s) multiplied by 1.4 for biochemical oxygen demand, total suspended solids, or fats, oil, and grease, or 1.2 for all other pollutants except pH.
- **Monitoring Reports:** Failure to provide, within forty-five (45) days after the due date, required reports such as DMRs.
- **Compliance Schedule:** Failure to meet within ninety (90) days after the schedule date, a compliance schedule milestone contained in or linked to a respective permit for starting construction, completing construction, or attaining final compliance.
- **Noncompliance Reporting:** Failure to accurately report noncompliance in accordance with the provisions identified in Section 6 of this permit.
- **Discretionary:** Any other violation of an effluent limit that the Department determines has caused, alone or in combination with other discharges, a violation of the POTW's NPDES permit, inhibition or disruption of the POTW, its treatment processes or operations, or its sludge processes, use or disposal.
- **Imminent Endangerment:** Any discharge of a pollutant that has caused imminent endangerment to human health, welfare or to the environment, or has resulted in the Department's exercise of its emergency authority under 40 CFR 403.8(f)(1)(vi)(B) to halt or prevent such a discharge.
- **Best Management Practices ("BMPs"):** Any other violation or group of violations, which may include a violation of BMPs, which the Department determines will adversely affect the operation or implementation of the pretreatment program.

This permit is hereby issued on

6/11/2014


Macky McCleary
Deputy Commissioner
Department of Energy and Environmental Protection

MM/MVM

cc: The City of Bridgeport East Side Publicly Owned Treatment Works

DATA TRACKING AND TECHNICAL FACT SHEET

Permittee: Reliable Plating and Polishing Co., Inc.

Permit, Address, and Facility Data

Permit No.: SP0000106

Application No.: 201206671

Mailing Address: Street: 80 Bishop Avenue City: Bridgeport ST: CT Zip: 06607 Contact Name: Scott Cleary Phone No.: (203) 366-5261 Email: reliablepltgct@aol.com	Location Address: Street: 80 Bishop Avenue City: Bridgeport ST: CT Zip: 06607 DMR Contact Jack Olexovitch Phone No.: (203) 366-5261 Email: reliablepltgct@aol.com
---	--

Permit Information

Duration	5 Year <u>X</u>	10 Year <u> </u>	30 Year <u> </u>
Type	New <u> </u>	Reissuance <u>X</u>	Modification <u> </u>
Categorization	Point Source (X)	Non-Point Source ()	GIS # <u> </u>
NPDES ()	Pretreatment (X)	Groundwater (UIC) ()	Groundwater (Other) ()

NPDES Major (MA)
Pretreatment SIU (SI) X
NPDES or Pretreatment Minor (MI)
Pretreatment Significant Industrial User (SIU) X
Pretreatment Categorical (CIU) X

Pollution Prevention Mandate Environmental Equity Issue

Standard Industrial Classification ("SIC") Code: 3471 - Electroplating, Plating, Polishing, Anodizing, and Coloring

Solvent Management Plan

Is the facility operating under an approved solvent management plan? Yes X No
Approved on: January 16, 2014

Compliance Issues

Compliance Schedule Yes No X

Is the permittee subject to a pending enforcement action? Yes No X

Ownership Code

Private X Federal State Municipal Other

DEEP Staff Engineer Mariana Miller

Permit Fees

Discharge Code	DSN Number	Annual Fee
501035Z	001-1	\$12,762.50
501035N	001-A	Waived*
501035N	001-B	Waived*

* Outfalls 001-A and 001-B are internal wastestreams discharging to DSN 001-1.

For Sewer Discharges

Discharge to the City of Bridgeport East Side Sewage Treatment Facility. The facility ID number of the POTW is 015-067.

Nature of Business Generating Discharge

Reliable Plating and Polishing Co., Inc. conducts metal finishing operations on customer supplied metal parts. The following processes take place at the facility: electroplating, electroless nickel plating, passivating, anodizing, buffing, and polishing.

Process and Treatment Description (by Discharge Serial Number ("DSN"))

DSN 001-1: The wastewaters discharged from this outfall are generated by electroplating, electroless nickel plating, passivating, anodizing, buffing, and polishing. Boiler blowdown, chiller maintenance wastewaters, and building maintenance wastewaters also contribute to this outfall. The onsite wastewater treatment system consists of metals removal by neutralization, flocculation, solids settling and sludge dewatering.

DSN 001-A: This discharge consists of cyanide-bearing wastewaters, which are treated through two stage cyanide destruction. The wastewaters are discharged to the onsite wastewater treatment system at DSN 001-1.

DSN 001-B: This discharge consists of chromium-bearing wastewaters, which are treated through hexavalent chromium reduction. The wastewaters are discharged to the onsite wastewater treatment system at DSN 001-1.

Resources Used to Draft Permit

- | | | |
|----------|--|---------------------------------------|
| <u>X</u> | Federal Effluent Limitation Guideline | <u>40 CFR 433</u> |
| | | Metal Finishing Point Source Category |
| — | Performance Standards | |
| — | Federal Development Document | |
| — | Treatability Manual | |
| <u>X</u> | Department File Information | |
| — | Connecticut Water Quality Standards | |
| — | Anti-degradation Policy | |
| — | Coastal Management Consistency Review Form | |
| — | Other (See <i>Other Comments</i>) | |

Basis for Limitations, Standards or Conditions

- X Pretreatment Standards for New Sources ("PSNS")
- X Case-by-Case using Best Professional Judgment ("BPJ") (See *Other Comments*)
- X Section 22a-430-4(s) of the Regulations of Connecticut State Agencies ("RCSA")

DSN	Parameter	BPJ	RCSA	PSNS
001-1	Cadmium, Total; AML, MDL		X	
	Cadmium, Total; MIL	X		
	Chromium, Total; AML, MDL, MIL		X	
	Chromium, Hexavalent; AML, MDL, MIL	X		
	Copper, Total; AML, MDL, MIL		X	
	Cyanide, Total; AML, MDL		X	
	Cyanide, Total; MIL	X		
	Lead, Total; AML, MDL, MIL		X	
	Nickel, Total; AML, MDL, MIL		X	
	pH	X		
	Silver, Total; AML		X	
	Silver, Total; MDL			X
	Silver, Total; MIL	X		
	Total Toxic Organics ("TTOs"); MIL			X
001-A	Zinc, Total; AML, MDL, MIL Cyanide, Amenable	X	X	

AML: Average Monthly Limit, MDL: Maximum Daily Limit, MIL: Maximum Instantaneous Limit

General Comments

In developing the permit's concentration limits, EPA Metal Finishing Categorical Limits (40 CFR Part 433) and section 22a-430-4(s)(2) of the RCSA limits were compared. The Connecticut limits were found to be more stringent and thus incorporated in the permit, except as noted above.

Other Comments

Reliable Plating & Polishing Co., Inc. ("Reliable") conducts electroplating, anodizing, buffing and polishing of customer supplied parts for the electronics and lock and hardware industries. Boiler blowdown wastewaters, barrel washing wastewaters, laboratory wastewaters and building maintenance wastewaters are generated by ancillary operations taking place at the facility.

Reliable is subject to regulation under PSNS under 40 CFR 433.17 (Metal Finishing Point Source Category) because the discharge from this site was initiated on January 1, 1990. The fact sheet in the previous permit indicated

that the limits were based on 40 CFR 413 (Electroplating Point Source Category), which was in error. 40 CFR 413 does not apply because the discharge began after PSNS went into effect (August 31, 1982). Therefore, it is classified as a new discharge.

Reliable is a "job shop", as defined in 40 CFR 433, because the company owns less than fifty percent (50%) of the parts undergoing metal finishing.

There are two, 1300 gallon tanks used for the treatment of cyanide-bearing wastewaters. One tank is for equalization and the other is for cyanide destruction. After cyanide destruction of wastewater in the destruction tank, a sample is collected and sent to the lab. Once the results are received from the lab and show that the treated wastewater meets the limits specified in the permit, the wastewater in the destruction tank is dumped into the wastewater treatment system. The wastewater then flows from the equalization tank to the destruction tank, and the process is repeated.

During an inspection on November 13, 2013, Mr. Chris Gerke of the Water Permitting and Enforcement Division discovered that there were multiple issues with Reliable's clarifier tank. The interior wall sections visible at the static water level of the tank were rusted and sections of the tank wall were peeling inward. Small holes in the tank wall were visible at the discharge side of the tank, and the steel crossbeam at the neutralization side was also corroded. Reliable is required to take corrective action addressing the repair and/or replacement of the clarifier tank. In addition, Reliable must address holding time exceedances and inconsistent laboratory reporting, two other issues discovered during the above-referenced inspection. In a December 18, 2013 letter, the company proposed that the replacement of the clarifier tank will take place the week of June 27th-July 6th, 2014.

During the summer of 2013, parts of the closed-loop chiller were stolen from the site. As of January 9, 2014, the parts had been replaced and the chiller had been returned to operation.

Reliable also generates wastewaters registered under the *General Permit for the Discharge of Stormwater Associated with Industrial Activity*.

Previously, the AML, MDL and MIL for cadmium were 0.1 mg/l, 0.5 mg/l and 0.75 mg/l, respectively. The cadmium AML and MDL of 0.07 mg/l and 0.11 mg/l apply to discharges subject to PSNS, in accordance with section 22a-430-4(s)(2)(1) of the RCSA. The new MIL was calculated by multiplying the MDL by a factor of 1.5, consistent with what has recently been done in other permits. In order to remain conservative, the calculated value was rounded to 0.16 mg/l.

The limits for hexavalent chromium for DSN 001-1 and amenable cyanide for DSN 001-A were carried over from the previous permit.

There is no MIL listed for total cyanide in section 22a-430-4(s)(2) of the RCSA. By multiplying the MDL for DSN 001-1 by 1.5, the MIL of 1.8 mg/l was calculated.

The pH limits of 6.0-10.0 S.U. are considered to be protective of sanitary sewer systems.

The previous permit did not contain effluent limits for silver. However, an e-mail was received from Reliable on October 31, 2013 indicating that silver is present in one chrome tank on the plating line. The tank is drummed for disposal, so there is a low chance of silver entering the wastewater treatment system. Effluent limits have been incorporated into this permit, with a quarterly monitoring requirement. In order to remain conservative, the calculated MIL $((0.43 \text{ mg/l}) \times (1.5))$ was rounded to 0.64 mg/l.

The City of Bridgeport East Side Sewage Treatment Facility confirmed its approval with the permit conditions on March 17, 2014.

The public notice was published in the CT Post on May 2, 2014. The Department has received no written comments on the proposed action.