

Pollutant	Conc. Units	DF	C _s ¹	C _e ²		C _d ³		Criteria * 0.9		Reasonable Potential		Limits	
				Acute	Chronic	Acute	Chronic	Acute	Chronic	Acute	Chronic	Acute	Chronic
Cadmium	µg/L	1.7	0	0.0	0.0	0.0	0.0	29.9	7.2	N	N	N/A	N/A
Copper	µg/L	1.7	0	17.8	17.8	10.4	10.4	5.2	3.4	Y	Y	8.8	5.7
Lead	µg/L	1.7	0	0.4	0.4	0.2	0.2	198.7	7.7	N	N	N/A	N/A
Nickel	µg/L	1.7	0	3.1	3.1	1.8	1.8	67.3	7.5	N	N	N/A	N/A
Zinc	µg/L	1.7	0	94.6	94.6	55.7	55.7	85.6	77.1	N	N	N/A	N/A
Ammonia (Cold)	mg/L	1.7	0	24.3	24.3	14.3	14.3	114.3	17.3	N	N	N/A	N/A
Ammonia (Warm)	mg/L	1.7	0	11.8	11.8	6.9	6.9	26.5	4.0	N	Y	N/A	6.8

¹Median concentration for the receiving water upstream of the zone of influence of the facility's discharge taken from the WET testing data during the review period (see Appendix A).

²Values represent the 95th percentile (for n ≥ 10) or maximum (for n < 10) concentrations from the DMR data and/or WET testing data during the review period (see Appendix A). If the pollutant already has a limit (for either acute or chronic conditions), the value represents the existing limit.