

Final Remediation General Permit Under the National Pollutant Discharge Elimination System (NPDES) for Discharges in Massachusetts

Massachusetts General Permit, Permit No. MAG910000

In compliance with the provisions of the Federal Clean Water Act, as amended,¹ and the Massachusetts Clean Waters Act, as amended,² the following permit authorizes discharge of water from four general categories, including: 1) site remediation³ primarily related to petroleum contamination; 2) site remediation³ activities where petroleum is not the primary contaminant; 3) contaminated construction site dewatering; and 4) miscellaneous contaminated discharges. Such discharges are authorized at sites located in Massachusetts (including both Commonwealth and Indian Country lands) to all classes of waters designated in the Massachusetts Water Quality Standards, 314 CMR 4.00 et seq., unless otherwise restricted, in accordance with effluent limitations, monitoring requirements, and other conditions set forth herein.

This permit shall become effective when issued. If this permit is not reissued prior to the expiration date, it will be administratively continued in accordance with the Administrative Procedures Act and remain in force and in effect. However, once this permit expires EPA-NE cannot provide written notification of coverage under this general permit to any permittee who submits Notice of Intent to EPA Region I after the permit's expiration date. Any permittee who was granted coverage prior to the expiration date will automatically remain covered by the continued permit until the earlier of: reissuance of this permit, at which time the permittee must comply with the Notice of Intent conditions of the new permit to maintain authorization to discharge; the permittee's submittal of a Notice of Termination; issuance of an individual permit; or a formal permit decision by the Director not to reissue this general permit, at which time the permittee must seek coverage under an alternative general or individual permit.

Signed this day of 2005

Linda M. Murphy, Director
Office of Ecosystem Protection
U.S. Environmental Protection Agency
Boston, MA

Glenn Haas, Director
Division of Watershed Management
Department of Environmental Protection
Commonwealth of Massachusetts
Boston, MA

¹33 U.S.C. §§ 1251 et seq.; the "CWA"

² M.G.L. Chap. 21, §§ 26-53

³For discharges that are subject to the Massachusetts Contingency Plan and 310 CMR 40.000, the permit applies as a matter of federal, but not state, law. For all other discharges, the permit applies under both.

**Final Remediation General Permit Under the National Pollutant Discharge
Elimination System (NPDES) for Discharges in New Hampshire**

New Hampshire General Permit, Permit No. NHG910000

In compliance with the provisions of the Federal Clean Water Act, as amended,⁴ the following permit authorizes discharge of water from four general categories, including: 1) site remediation activities primarily related to petroleum contamination; 2) site remediation activities where petroleum is not the primary contaminant ("non-petroleum" sites); 3) contaminated construction site dewatering; and 4) miscellaneous contaminated discharges. Such discharges are authorized to all waters located in New Hampshire, unless otherwise restricted by the New Hampshire water quality standards,⁵ in accordance with effluent limitations, monitoring requirements, and other conditions set forth herein.

This permit shall become effective when issued. If this permit is not reissued prior to the expiration date, it will be administratively continued in accordance with the Administrative Procedures Act and remain in force and in effect as to any particular permittee. However, once this permit expires EPA-NE cannot provide written notification of coverage under this general permit to any permittee who submits Notice of Intent to EPA Region I after the permit's expiration date. Any permittee who was granted permit coverage prior to the expiration date will automatically remain covered by the continued permit until the earlier of: reissuance of this permit, at which time the permittee must comply with the Notice of Intent conditions of the new permit to maintain authorization to discharge; the permittee's submittal of a Notice of Termination; issuance of an individual permit; or a formal permit decision by the Director not to reissue this general permit, at which time the permittee must seek coverage under an alternative general permit or an individual permit.

Signed this day of 2005.

Linda M. Murphy
Director, Office of Ecosystem Protection
U.S. Environmental Protection Agency
Boston, MA

⁴ 33 U.S.C. §§ 1251 et seq.; the "CWA"

⁵ 50 RSA § 485-A:8 and the N.H. Code of Administrative Rules, CHAPTER Env-Ws 1700 SURFACE WATER QUALITY REGULATIONS (December 1999)

Table of Contents of RGP:

PART I - Permit Applicability and Conditions

	<u>Page #</u>
A. Applicability and Coverage of the Remediation General Permit (RGP)	5
1. Subject Discharges	5
2. Geographic Coverage Area	6
3. Specific Discharges Excluded From Coverage	6
4. Endangered and Threatened Species and/or Critical Habitat	8
5. National Historic Preservation Act	9
B. Application and Notice of Intent (NOI)	9
1. Definition of “Owner” & “Operator”	9
2. Eligibility for Coverage Under the RGP	9
3. Notice of Intent Options	10
4. General Application Requirements	10
5. Consultation with Federal Services	11
6. Signature	11
7. Submission of NOIs	11
8. When the Director May Require Application for an Individual NPDES Permit	11
9. EPA Determination of Coverage	12
C. Effluent Limitations and Monitoring Requirements	12
1. General Effluent Limitations and Monitoring Requirements	12
2. pH Limitations	12
3. Water Quality Requirements	13
4. Prohibition of Toxic Discharge	14
5. Heat	14
6. Chemical Effluent Limits and Effluent Monitoring	15
7. Consideration of Dilution Factors for Discharges of Metals	15
8. Specific Pollutants to Be Monitored for Individual Subcategories	15
9. Flow Monitoring	26
D. Sampling, Testing, Recordkeeping, and Reporting Requirements	26
1. Sampling and Testing	26
2. Initial Treatment System Discharge Startup	27
3. Acute Toxicity Testing and Monitoring	28
4. Recordkeeping and Reporting	29
5. Intermittent Operations and System Re-Start	29
6. Extended System Shutdown	30
7. Short Term Discharges	30
8. Hydrostatic Testing Discharge Monitoring Requirements	30
E. Best Management Practices Plan (BMPP)	31
1. Development of a BMPP	31
2. Additional Best Management Practices	32

3. BMPs for Hydrostatic Testing	33
4. BMPP Deadlines	33
F. Special NPDES Permit Conditions	34
1. Compliance with Municipal Separate Storm Sewer Systems (MS4) Requirements and Storm Water Management Programs (SWMP)	34
2. Special Conditions for Hydrostatic Testing	35
G. Administrative Requirements	35
1. Notice of Change (NOC)	35
2. Notice of Termination (NOT)	35
3. Joint Issuance and Enforcement	36
4. Continuation of This General Permit After Expiration	36
H. Additional Permit Conditions Applicable to Specific States or Indian Country Lands	37
(If required, to be completed following State certification process and the public notice period.)	

Part II. Standard Conditions

APPENDICES:

Appendix I - Areas of Critical Concern in Massachusetts

Appendix II - Endangered Species Act: County Species List

Appendix III - Effluent Limitations

Appendix IV - Metals Limitations at Selected Dilution Ranges

Appendix V - NOI, NOC, and NOT Forms and Instructions

Appendix VI - EPA New England's Optimum Minimum Levels Organic and Inorganic Chemicals Covered by the RGP

Appendix VII - Endangered Species & Historic Preservation Requirements

Appendix VIII - Monthly Data Summary Form and Instructions

PART I - Permit Applicability and Conditions

A. Applicability and Coverage of the Remediation General Permit (RGP)

1. Subject discharges - During the period beginning on the effective date and lasting through expiration, the permittee is authorized to discharge wastewater to surface waters from a variety of discharges listed below, including discharges from:
 - a. site remediation activities related primarily to petroleum, including site remediation of groundwater contaminated from petroleum spills or leaks, such as gasoline, fuel oil, or other oil contaminated sites;
 - b. site remediation where the spill or leak is not petroleum-specific, such as sites contaminated with volatile organic compounds and/or metals;
 - c. construction de-watering of contaminated sites, such as at EPA or state-listed contamination sites, including locations where sub-surface site investigations and/or soil characterization for disposal have revealed various common pollutants typically associated with past industrialization, power generation, incineration, or other activity and where no specific source of contamination is apparent; and
 - d. de-watering of miscellaneous contaminated discharge sites, such long-term remediation of contaminated sumps, and short-term contaminated dredge drain back waters (if not covered by Section 401/404 permit), aquifer pump testing to evaluate remediation of formerly contaminated sites, well development or rehabilitation at contaminated or formerly contaminated sites, and hydrostatic testing of pipelines and tanks.

Table I: Activities Covered by the Remediation General Permit

Category	Sub-Category
I - Petroleum Related Site Remediation	A. Gasoline Only Sites B. Fuel Oils and Other Oil Sites C. Petroleum Sites Containing Other Contaminants
II - Non Petroleum Site Remediation	A. VOC Only Sites B. VOC Sites Containing Other Contaminants C. Sites Containing Primarily Metals
III - Contaminated Construction Dewatering	A. General “Urban Fill” Sites B. Known Contamination Sites

IV - Miscellaneous Related Discharges	A. Aquifer Pump Testing to Evaluate Formerly Contaminated Sites B. Well Development/Rehabilitation at Contaminated/Formally Contaminated Sites C. Hydrostatic Testing of Pipelines and Tanks D. Long-Term Remediation of Contaminated Non-residential Sumps and Dikes E. Short-term Contaminated Dredging Drain Back Waters (if not covered by 401/404 permit)
--	---

2. Geographic Coverage Area

- a. *Massachusetts:* All of the discharges to be authorized by this general NPDES permit for dischargers in the Commonwealth of Massachusetts are into all waters of the Commonwealth and Indian Country lands unless otherwise restricted by the Massachusetts Surface Water Quality Standards, 314 CMR 4.00 (or as revised), including 314 CMR 4.04(3) Protection of Outstanding Resource Waters.
- b. *New Hampshire:* All of the discharges to be authorized by this general NPDES permit for dischargers in the State of New Hampshire are into all waters of the State of New Hampshire unless otherwise restricted by the State Water Quality Standards: see 50 RSA § 485-A:8 and the N.H. Code of Administrative Rules, Chapter Env-Ws 1700 or as revised.

3. Specific Discharges Excluded From Coverage - the following discharges are excluded from coverage under this General Permit:

- a. *Discharges to Outstanding Resource Waters in Massachusetts and New Hampshire:*
 - 1) as defined in Massachusetts by 314 CMR 4.06(3), including Public Water Supplies (314 CMR 4.06(1)(d)1) which have been designated by the state as Class A waters, unless a variance is granted by the Massachusetts Department of Environmental Protection (MADEP) under 314 CMR 4.04(3)(b), or
 - 2) as defined in New Hampshire under Env-Ws 1708.05(a), unless allowed by the New Hampshire Department of Environmental Services (NH DES) under Env-Ws 1708.05(b).
- b. *Discharges to Areas of Critical Environmental Concern (ACEC) in Massachusetts* as defined by the Massachusetts Wetlands Protection Act c.131, Section 40, unless a variance as allowed in the water quality standards is granted by the State. See Appendix I for a listing of ACEC's by city and town in Massachusetts (MA).

- c. *Discharges to Class A waters in New Hampshire*, in accordance with RSA 485-A:8, I. To determine if the proposed receiving water is a Class A waterbody, contact the NH DES at the address listed in Part I.D.4 of this permit.
- d. *Discharges to designated areas under the Endangered Species Act (ESA)* unless the requirements specified in this permit are fulfilled. See Parts I.B.4 & 5 and Appendices II and VII for additional requirements.
- e. *Discharges to designated areas under the Essential Fish Habitat Act (EFH)* unless the requirements specified in this permit are fulfilled.
- f. *Discharges of pollutants which are specifically excluded by the States' published 303(d) lists of "non-attainment" segments of receiving waters in the Commonwealth of Massachusetts and the State of New Hampshire*, as defined by the CWA and approved by EPA unless the discharge is at or below a concentration that meets water quality standards.
- g. *Discharges to a Publicly-Owned Treatment Works (POTW)* which are permitted under Section 402 of the CWA (NPDES).
- h. *Discharge to municipal separate storm sewer systems (MS4s)*, unless local permitting or approval under the municipality's Storm Water Management Program (SWMP), required under EPA's MS4 general permits, is completed. See Part I.F.1.
- i. *Discharges directly or indirectly to the ground.*
- j. *Discharge of dredge drain back waters covered by CWA Section 401 and 404 and 40 CFR 330.5(a)(16)* administered by the US Army Corps of Engineers (USACOE) where USACOE intends to permit the discharge.
- k. *Discharges of water supply or other well development or rehabilitation waste waters*, except discharges of treated water from the development or rehabilitation of monitoring wells at contaminated or formerly contaminated sites. This permit does not cover wastewater from wells that contain naturally occurring substances or materials from only routine maintenance activities.
- l. *Discharge of water from one water body to another water body*, otherwise referred to as "water transfers," except for the specific purpose of hydrostatic testing of pipelines, tanks and other structures.
- m. *Uncontaminated construction dewatering discharges* eligible for coverage under EPA Region I's General Permit for Construction Dewatering dated September 23, 2002, or non-stormwater discharges covered by the EPA's national Construction General Permit dated July 1, 2003.

- n. *Short-term discharges from sumps or other similar water collection structures, e.g., discharges lasting less than one week (7 days) at residential properties. These discharges may, however, be subject to local requirements under EPA’s Phase I and II Municipal Separate Storm Sewer System (MS4) general permits.*
 - o. *“New Source” dischargers, as defined in 40 CFR § 122.2.*
 - p. *Discharges listed in an individual NPDES permit unless:*
 - 1) the permit has expired;
 - 2) EPA has terminated the existing permit;
 - 3) the discharges are separate from the currently permitted discharges; or
 - 4) the discharge is new and eligible for this permit (e.g., an industry where the primary process waste discharge is covered by an individual permit but the facility is conducting groundwater remediation with separate treatment and discharge).
 - q. *Discharges for which the Director makes a determination that an individual permit is required under 40 CFR 122.28(b)(3). See Part I.B.8. below.*
 - r. *Discharges which adversely affect properties listed or eligible for listing in the National Registry of Historic Places under the National Historic Preservation Act of 1966, 16 USC Sections 470 et seq.*
 - s. *Discharges of any commercial or industrial wastes to Ocean Sanctuaries in Massachusetts, as defined at 302 CMR 5.00.*
 - t. *Discharges to territorial seas, as defined by Section 502 of the Clean Water Act.*
 - u. *Discharges made from a CERCLA remediation site under a signed Record of Decision under 40 CFR 300.400(e)(1).*
4. Endangered and Threatened Species and/or Critical Habitat⁶: Proposed discharges that are located in areas in which listed endangered or threatened species may be present, are not automatically covered under this permit. Prior to submitting a Notice of Intent (NOI), operators must demonstrate permit eligibility following the eligibility requirements of Appendix VII and the most recent Endangered and Threatened Species County-Species List in Appendix II.

There are four listed species of concern to applicants applying for permit coverage, namely the **shortnose sturgeon**, the **dwarf wedge mussel**, the **bog turtle**, and the **northern redbelly cooter**. The shortnose sturgeon is listed under the jurisdiction of the National Marine Fisheries Service and the **dwarf wedgemussel**, the **bog turtle**, and the **northern redbelly cooter** are listed under the jurisdiction of the U.S. Fish and Wildlife Service.

⁶ There is currently only one area federally-designated as critical habitat in MA, i.e., for the Northern Redbelly Cooter in Plymouth County, MA, and none in NH.

5. National Historic Preservation Act - Facilities which adversely affect properties listed or eligible for listing in the National Registry of Historic Places under the National Historic Preservation Act of 1966, 16 USC Sections 470 et seq. are not authorized to discharge under this permit. Prior to submitting a Notice of Intent (NOI), applicants must determine whether their discharges have the potential to affect a property that is either listed or eligible for listing on the National Register of Historic Places. Electronic listings of National and State Registers of Historic Places are maintained by the National Park Service (www.nr.nps.gov/nrishome.htm), the Massachusetts Historical Commission (www.state.ma.us/sec/mhc.) and the New Hampshire Historical Commission (www.state.nh.us/nhdhr.)

Applicants must comply with applicable State, Tribal and local laws concerning the protection of historic properties and places. Applicants must coordinate with the State Historic Preservation Officer and/or Tribal Historic Preservation Officer and others regarding effects of their discharges on historic properties. Prior to submitting the NOI, the applicant must meet the requirements of Appendix VII, Section II, pertaining to historic places.

B. Application and Notice of Intent (NOI)

1. Definition of “owner” and “operator” -

- a. For purposes of this permit, the “owner” of a property is the person, as defined by 40 CFR 122.2, holding the title, deed, or legal document to the regulated property, facility, or activity, including a party working under an easement on the property.
- b. The “operator” is defined as the person who has operational control over plans and specifications, or the person who has day-to-day supervision and control of activities occurring at the site. Further, for purposes of this permit, the operator is:
 - i. The owner if that person is performing all work related to complying with this permit; **or**
 - ii. Both the owner and contractor(s), as co-permittees, if a contractor(s) has been hired to perform work related to complying with this permit.

2. Eligibility for Coverage Under the Remediation General Permit (RGP) - The following types of facilities or sites are eligible to apply for coverage under the RGP:

- a. New dischargers.
- b. Facilities with on-going discharges pursuant to EPA- or State-approved site remediation projects.
- c. Facilities with expired individual permits that have been administratively continued in accordance with 40 CFR§ 122.6 may apply for coverage under this general permit. If, and when, EPA New England (EPA-NE) grants coverage under this permit, EPA-NE will initiate the process to revoke the individual

permit.

- d. Any facility operating under an effective (unexpired) individual NPDES permit may request that the individual permit be revoked and that coverage under this general permit be granted, as outlined in 40 CFR § 122.28(b)(3)(v). If, and when, EPA-NE grants coverage under this permit, EPA-NE will initiate the process to terminate the individual permit.
3. Notice of Intent Options: The “operator” of the site or facility is responsible for applying for the permit as required by 40 CFR 122.21(b). To be covered by this general permit, operators of applicable sites or facilities, whose discharge or discharges are identified in Part I.A.1 above, must submit to EPA-NE and the appropriate State, a complete, signed **Notice of Intent (NOI)**. For purposes of this RGP, the NOI consists of either:
 - a. The suggested NOI form in Appendix V of this permit, or
 - b. Another form of official correspondence containing all of the information required in the NOI instructions in Appendix V of this permit.
 4. General Application Requirements
 - a. Facilities For Which an Individual NPDES Application Has Not Been Previously Submitted
 - 1) Operators of proposed new discharges seeking coverage under this general permit, must submit a NOI to EPA-NE post-marked at least **14 days** prior to the commencement of discharge.
 - 2) Operators of existing discharges pursuant to EPA- or State-approved site remediation projects, who have never submitted an application for an individual NPDES permit, must file an NOI for coverage under this permit or application Forms 1 & 2C for coverage under an individual permit. The applicant must submit the NOI or individual permit application within **30 days** of the effective date of the RGP to: EPA-NE, the respective State, and the municipality into which the discharge is proposed,. See Appendix V for NOI instructions and addresses.
 - b. Facilities For Which Individual NPDES Permit Applications Have Been Previously Submitted - For facility operators with discharges pursuant to approved site remediation projects, who have previously filed a NPDES application for coverage under an individual permit, the following conditions apply:
 - 1) If a facility owner or operator has made only minor changes to the discharge operations since submission of the application, the applicant may notify EPA in writing that the existing application continues to be accurate and is serving in lieu of a notice of intent (NOI). Minor changes include changes to administrative information, changes to the treatment system that improve performance or decrease flow, changes to the discharge location on the same receiving water, etc.
 - 2) If a facility owner or operator has made significant changes to the discharge

operations since submission of the application, the operator must file a NOI following the instructions in Appendix V. Significant changes include: discharges containing chemicals not reported in the original application, additional discharge locations, discharges to different receiving waters, changes of flow of greater than 25%, etc.

5. Consultation with Federal Services - **All** applicants must comply with the requirements of Appendix VII, Section I, regarding consultation pertaining to endangered species.
6. Signature - The Notice of Intent must be signed by the operator(s) of the facility, as defined in Part I.B.1. above, in accordance with the signatory requirements of 40 CFR Section 122.22.
7. Submission of NOIs - Each applicant must submit a copy of the Notice of Intent to EPA and the appropriate State authority⁷ listed in Appendix V. Additionally, the applicant must submit a copy of the NOI to the municipality in which the proposed discharge would be located.
8. When the Director May Require Application for an Individual NPDES Permit - The Director may require any person authorized by this permit to apply for and obtain an individual NPDES permit.
 - a. Instances where an individual permit may be required include the following:
 - 1) The discharge(s) is a significant contributor of pollution;
 - 2) The discharger is not in compliance with the conditions of this permit;
 - 3) A change has occurred in the availability of the demonstrated technology of practices for the control or abatement of pollutants applicable to the point source;
 - 4) Effluent limitation guidelines are promulgated for point sources covered by this permit;
 - 5) A Water Quality Management Plan or Total Maximum Daily Load containing requirements applicable to such point source is approved;
 - 6) The discharge is to an outstanding natural resource water;
 - 7) The discharge causes or may cause violations to the water quality standards of the receiving water or if actual or imminent harm to aquatic organisms is identified;
 - 8) The discharge adversely impacts any federally-managed species for which Essential Fish Habitat has been designated;
 - 9) The discharge is into waters which are specifically excluded by the States' published 303(d) lists of "non-attainment" segments of receiving waters in the Commonwealth of Massachusetts and the State of New Hampshire, as defined by the CWA and approved by EPA, and the discharge is above a concentration that meets water quality standards.
 - 10) The point source(s) covered by this permit no longer:
 - i) Involves the same or substantially similar types of operations;

⁷For discharges that are subject to the Massachusetts Contingency Plan and 310 CMR 40.000, the permit applies as a matter of federal, but not state, law. For all other discharges, the permit applies under both.

- ii) Discharges the same types of wastes;
 - iii) Requires the same effluent limitations or operating conditions;
 - iv) Requires the same or similar monitoring; or
- 11) In the opinion of the Director, the discharge is more appropriately controlled under an individual or different general permit.

- b. If the Director requires an individual permit, the permittee will be notified in writing that an individual permit is required, and will be given a brief explanation of the reasons for this decision.
 - c. When an individual NPDES permit is issued to an operator otherwise subject to this general permit, the applicability of this permit to that operator is automatically terminated on the effective date of the individual permit.
9. EPA Determination of Coverage - Any applicant may request to be included under this general permit but the final authority rests with the EPA-NE. Coverage under the general permit will not be effective until EPA-NE has reviewed the certification and existing file information, made a determination that coverage under the RGP is appropriate, and notified the operator in writing of its determination. The effective date of coverage will be the date of signature of the notification letter by the EPA-NE Director.

C. Effluent Limitations and Monitoring Requirements

- 1. General Effluent Limitations and Monitoring Requirements - Each discharge outfall subject to this permit shall be limited and monitored by the permittee as specified below in accordance with the receiving water classification when indicated. Permittees shall monitor for the influent and effluent for all applicable parameters unless otherwise specified.
 - a. Permittees must monitor monthly for each outfall in accordance with Parts I.C, D, E, and F, and Parts II.C and D of this permit.
 - b. All of the parameter limits of the permit apply except where the permittee has certified that pollutants are “believed absent” in the discharge (see Part I.C.8 below) or where specifically excluded in the provisions below.
- 2. pH Limitations - For discharges in Massachusetts, Table II below applies to the effluent only. For discharges in New Hampshire, Table III below applies to the effluent only.

Table II: pH Limits in Massachusetts

<u>Effluent Characteristic</u>	<u>Units</u>	<u>Discharge Limitation</u>	<u>Monitoring Requirement</u>	
			<u>Measure-ment Frequency</u>	<u>Sample Type</u>
pH Range for Class A & Class B Waters ⁸	Standard Units	6.5 to 8.3 ⁹	1/Month	Grab ¹⁰
pH Range for Class SA & Class SB Waters ⁸	Standard Units	6.5 to 8.5 ⁹	1/Month	Grab ¹⁰

Table III: pH Limits in New Hampshire

<u>Effluent Characteristic</u>	<u>Units</u>	<u>Discharge Limitation</u>	<u>Monitoring Requirement</u>	
			<u>Measure-ment Frequency</u>	<u>Sample Type</u>
pH Range for Class B Waters ⁸	Standard Units	6.5 to 8.0	1/Month	Grab ¹⁰

3. Water Quality Requirements - The discharge shall not cause a violation of the water quality standards of the receiving water.
 - a. The discharge shall be adequately treated to insure that the surface water remains free from pollutants in concentrations or combinations that settle to form harmful deposits, float as foam, debris, scum, form a visible sheen or other visible pollutants.
 - b. The discharge shall be adequately treated to insure that the receiving waters remain free from color, odor, taste, or turbidity in concentrations that would render them unsuitable for their designated use unless such concentrations are naturally occurring.

⁸State certification requirement.

⁹ The permittee may request that the pH range be widened to within 6 to 9 s.u. or another range due to naturally occurring conditions in the receiving water. Similarly, permittees may request such a change if the naturally occurring source water is unaltered by the permittee's operation. The scope of any demonstration must receive prior approval from the MA DEP. An NOC must be submitted to the EPA-NE Director upon approval from the state (see Appendix V).

¹⁰ pH sampling for compliance with permit limits may be performed using field methods as provided for in EPA test method 150.1.

4. Prohibition of Toxic Discharge - The discharge shall not contain materials in concentrations or in combinations which are hazardous or toxic to aquatic life or which would impair the uses designated by the classification of the receiving waters.
5. Heat - Where the permittee's operation contains a process that alters the temperature of the water prior to discharge, effluent temperature shall be monitored prior to discharge and the following temperature limits apply:

Table IV: Temperature Limits

Effluent Characteristic	Units	Discharge Limitation	Monitoring Requirement	
			Measurement Frequency	Sample Type
a. Warm water fisheries daily maximum temperature	Fahrenheit (°F)	83	1/Month	Grab ¹¹
b. Cold water fisheries daily maximum temperature	°F	68	1/Month	Grab ¹¹
For sites in Massachusetts , the following additional temperature limits apply:				
c. Coastal and marine waters daily maximum and maximum of maximum daily mean	°F	85 (daily max.) 80 (maximum daily mean)	1/Month	Grab ¹¹

¹¹Temperature sampling per Method 170.1

For sites in **Massachusetts**, the following additional limits on temperature change apply:

Class of Water Body	Type of Fishery or Subcategory	Units	Maximum Change in Temperature	Measurement Frequency	Sample Type
A		°F	1.5	1/Month	Grab ¹¹
B	Warm Water	°F	5	1/Month	Grab ¹¹
	Cold Water and Lakes/Ponds	°F	3	1/Month	Grab ¹¹
SA	Coastal	°F	1.5	1/Month	Grab ¹¹
SB	July to September	°F	1.5	1/Month	Grab ¹¹
	October to June	°F	4	1/Month	Grab ¹¹

6. Chemical Effluent Limits and Influent and Effluent Monitoring - In addition to the general monitoring requirements of Part II.C and Part II.D, after the initial startup sampling and testing requirements of Part I.D.2 have been met, permittees must monitor their untreated influents and outfall discharge effluents on a **monthly basis** unless otherwise provided for by this permit. See Appendix V, Section II, Notice of Change. Permittees must demonstrate compliance with all of the applicable effluent parameter limits specified in this permit, except as provided for in Part I.C.8 (see Table V below).
7. Consideration of Dilution Factors for Discharges of Metals - Where discharges of metals require effluent limits, dilution factors may be applied to the discharges of **metals to freshwater**.¹² In the NOI, the applicant must select the applicable parameters and, if necessary, an appropriate dilution factor. See Appendix V, Section I.A.3. of the NOI Instructions for detailed instructions for determining the applicable effluent limitations for metals into freshwater¹³.
8. Specific Pollutants to Be Monitored for Individual Sub-Categories
 - a. Upon becoming subject to this permit, permittees must monitor the untreated influents and outfall discharge effluents of all of the chemicals related to the applicable sub-categories listed in Table V below on a monthly basis, except for any chemical for which the permittee certified in the NOI that the chemical was “**believed absent.**” See Appendix V, Section I.A.3.
 - 1) If the discharge falls within only one sub-category (e.g., gasoline remediation sites), the permittee must monitor monthly for the pollutants specified for that sub-category, except for any chemical for which the permittee certified in the NOI that the chemical was “**believed absent.**”

¹² Dilution factors may be available for discharges to saline waters but only with approval of the flow modeling information from the State prior to the submission of the NOI.

- 2) If the site falls within more than one sub-category, the permittee is required to monitor for all sub-category specified pollutants, except for any chemical for which the permittee certified in the NOI that the chemical was **“believed absent.”**
- b. If the permittee certified in the NOI that any chemicals were **“believed absent,”** the following additional requirements apply regarding those chemicals:
 - 1) If the discharge continues for fewer than six (6) months from the start of the discharge under this permit, monthly monitoring of that chemical is not required.
 - 2) If the discharge continues for six (6) months or longer from the start of the discharge under this permit, the permittee must re-certify by letter to EPA that chemicals continue to be **“believed absent.”** Such re-certification shall be made at least once during each sequential six (6) month period that the discharge continues.
 - i. Re-certification of a chemical as **“believed absent”** shall be based on laboratory data from a minimum of one (1) new untreated influent sample taken within 30 days following the end of the six-month period, or
 - ii. In lieu of new sampling every six (6) months, the permittee may re-certify that a chemical is **“believed absent,”** by submitting historical sampling data demonstrating that the untreated influent concentration was below the otherwise applicable limit for that chemical in Appendices III or IV, or below the minimum level (see Part I.D.1.d). To use historical data, the permittee must submit (e.g., with the NOI or by letter) a minimum of six (6) consecutive months of laboratory data at a point prior to any treatment of the water, and obtained pursuant to:
 - 1) Massachusetts’ regulations 310 CMR 40.0000, the Massachusetts Contingency Plan (“Chapter 21E”);
 - 2) New Hampshire’s Title 50 RSA 485-A: Water Pollution and Waste Disposal or Title 50 RSA 485-C: Groundwater Protection Act Chapter 485-A, Section 485-A:13, “Water Discharge Permits” or
 - 3) EPA permit exclusion letter issued pursuant to 40 CFR 122.3.
 Such historical data may be submitted with the NOI or within 30 days following the end the first six-month period of operation under the permit. Historical data used for re-certification can not be more than two years old (i.e., must have been collected less than 2 years before the re-certification is due).
 - c. Re-certifications that permitted chemicals are **“believed absent”** must be signed in accordance with 40 CFR Section 122.22.
 - d. Regardless of certification of chemicals as **“believed absent,”** the Director may provide written notice to any operator, requiring monitoring of specific parameters. Any such notice will briefly state the reasons for the monitoring, parameters to be monitored, frequency and period of monitoring, sample types, and reporting requirements.
 - e. If the discharge is known to contain additional chemicals than are listed in

Appendix III of the permit, the permittee must also monitor for the known chemicals on a monthly basis (i.e., as “monitor only”). See Appendix V, Section A.3.b.

- f. As required in 40 CFR Section 122.42, in addition to reporting requirements specified in the permit, permittees must notify the Director as soon as they have reason to believe that any activity has occurred which would result in the discharge of any toxic pollutant which is not otherwise limited in the permit and is referenced in 40 CFR 401.15.
- g. Certain monitoring requirements may be reduced upon demonstration by ongoing sampling and analytical data.
 - i. To be eligible for a reduction in **influent** monitoring, the permittee must provide a minimum of **6 consecutive months** of data. This data must be submitted with a notice of change (NOC) per Appendix V, Section II.
 - ii. To be eligible for a reduction in **effluent** monitoring, the permittee must provide **12 consecutive months** of data demonstrating compliance with the applicable parameter limits, applicable ML (see Part I.D.1.d), or demonstrating no toxicity, in the case of whole effluent toxicity testing is required. This type of change requires written approval by the Director. Prior to receiving written approval, the permittee must continue to monitor at the frequency specified in the RGP. This data must be submitted with a NOC.

Table V: Chemical Effluent Limits and Monitoring Requirements by Sub-Category

1. Petroleum Related Site Remediation

A. Gasoline Remediation Sites					
Pollutants To Be Monitored	Effluent Limit		Limit Type	Sample Type	Sampling Frequency
Benzene	5.0 micrograms per liter (ug/l)		daily maximum	grab	1/month
Total Benzene, Toluene, Ethylbenzene, and Xylene (BTEX)	100 ug/l		daily maximum	grab	1/month
Naphthalene	20 ug/l¹³		daily maximum	grab	1/month
Ethylene dibromide	0.05 ug/l		daily maximum	grab	1/month
Methyl-t-Butyl Ether (MtBE)	70.0 ug/l		daily maximum	grab	1/month
tert-Butyl Alcohol	Monitor Only (ug/L)		daily maximum	grab	1/month
tert-Amyl Methyl Ether	Monitor Only (ug/L)		daily maximum	grab	1/month
Total Suspended Solids (TSS)	30.0 milligrams per liter (mg/l)		monthly average	grab	1/month
Total Petroleum Hydrocarbon	5.0 mg/l		daily maximum	grab	1/month
Lead (total recoverable)	In MA: FW¹⁴ = 1.3 ug/L SW¹⁵ = 8.5 ug/L	In NH: FW = 0.5 ug/L SW = 8.5 ug/L	monthly average	grab	1/month
Iron (total recoverable)	In MA: 1,000 ug/L	In NH: 1,000 ug/L	daily maximum	grab	1/month

¹³ Naphthalene can be reported as both a purgeable (VOC) and extractable (SVOC) organic compound. If both VOC and SVOC analyzed, the highest value must be used unless the QC criteria for one of the analyses is not met. In such cases, the value from the analysis meeting the QC criteria must be used.

¹⁴FW = freshwater

¹⁵SW = saltwater

B. Fuel Oils (and Other Oils) Sites					
Pollutants To Be Monitored	Effluent Limit		Limit Type	Sample Type	Sampling Frequency
Acetone	Monitor Only (ug/L)		daily maximum	grab	1/month
TPH	5.0 mg/l		daily maximum	grab	1/month
Naphthalene	20 ug/l ¹³		daily maximum	grab	1/month
Polycyclic Aromatic Hydrocarbons (PAHs)	See Appendix III (#'s 35 & 36)		daily maximum	grab	1/month
Benzene	5.0 ug/l		daily maximum	grab	1/month
BTEX	100 ug/l		daily maximum	grab	1/month
Nickel (total recoverable)	In MA: FW = 29.0 ug/L SW = 8.2 ug/L	In NH: FW = 16.1 ug/L SW = 8.2 ug/L	monthly average	grab	1/month
Chromium III (trivalent) (total recoverable)	In MA: FW = 48.8 ug/L SW = 100 ug/L	IN NH: FW = 27.7 ug/L SW = 100 ug/L	monthly average	grab	1/month
Chromium VI (hexavalent) (total recoverable)	In MA: FW = 11.4 ug/L SW = 50.3 ug/L	In NH: FW = 11.4 ug/L SW = 50.3 ug/L	monthly average	grab	1/month
Zinc (total recoverable)	In MA: FW = 66.6 ug/L SW = 85.6 ug/L	In NH: FW = 37 ug/L SW = 85.6 ug/L	monthly average	grab	1/month
Iron (total recoverable)	In MA: 1,000 ug/L	In NH: 1,000 ug/L	daily maximum	grab	1/month
C. Petroleum Sites Containing Other Pollutants					
Pollutants To Be Monitored	Effluent Limit		Limit Type	Sample Type	Sampling Frequency
All pollutants listed in Appendix III	See Appendix III		See Appendix III	grab	1/month

2. Non-Petroleum (i.e., Not Gasoline and Oil) Site Remediation

A. VOC-Only Sites				
Pollutants To Be Monitored	Effluent Limit	Limit Type	Sample Type	Sampling Frequency
Carbon Tetrachloride	4.4 ug/l	daily maximum	grab	1/month
1,2 (or o)-Dichlorobenzene (DCB)	600 ug/l	daily maximum	grab	1/month
1,3 (or m)-Dichlorobenzene	320 ug/l	daily maximum	grab	1/month
1,4 (or p)-Dichlorobenzene	5.0 ug/l	daily maximum	grab	1/month
Total Dichlorobenzene	763 ug/l - NH only	daily maximum	grab	1/month
1,1-Dichloroethane (DCA)	70 ug/l	daily maximum	grab	1/month
1,2-Dichloroethane	5.0 ug/l	daily maximum	grab	1/month
1,1-Dichloroethylene (DCE)	3.2 ug/	daily maximum	grab	1/month
cis-1,2-Dichloroethylene	70 ug/l	daily maximum	grab	1/month
Methylene Chloride	4.6 ug/l	daily maximum	grab	1/month
Tetrachloroethylene (PCE)	5.0 ug/l	daily maximum	grab	1/month
1,1,1-Trichloroethane (TCA)	200 ug/l	daily maximum	grab	1/month
1,1,2 Trichloroethane	5.0 ug/l	daily maximum	grab	1/month
Trichloroethylene (TCE)	5.0 ug/l	daily maximum	grab	1/month
Vinyl Chloride	2.0 ug/l	daily maximum	grab	1/month
TPH	5.0 mg/l	daily maximum	grab	1/month
Phenols	300 ug/l	daily maximum	grab	1/month
Pentachlorophenol	1.0 ug/l	daily maximum	grab	1/month
Total Phthalates (sum of individual compounds)	3.0 ug/L	monthly average	grab	1/month
A. VOC-Only Sites (continued)				

Pollutants To Be Monitored	Effluent Limit	Limit Type	Sample Type	Sampling Frequency
Bis (2-Ethylhexyl) Phthalate [Di- (ethylhexyl) Phthalate]	6.0 ug/l	daily maximum	grab	1/month
Total PCBs	0.000064 ug/L ¹⁶	daily maximum	grab	1/month
Acetone	Monitor Only (ug/L)	daily maximum	grab	1/month
1,4 Dioxane	Monitor Only (ug/L)	daily maximum	grab	1/month
BTEX	100 ug/l	daily maximum	grab	1/month
Iron (total recoverable)	1,000 ug/L	daily maximum	grab	1/month

B. VOC Sites Containing Other Contaminants				
Pollutants To Be Monitored	Effluent Limit	Limit Type	Sample Type	Sampling Frequency
All pollutants listed in Appendix III	See Appendix III	See Appendix III	grab	1/month

¹⁶Although the maximum value for PCBs is 0.000064 ug/L, the compliance limit is equal to the minimum level (ML) of the test method used as listed in Appendix VI (i.e., 0.5 ug/l for Method 608 or 0.00005 ug/l when Method 1668a is approved).

C. Sites Containing Primarily Metals				
Pollutants To Be Monitored	Effluent Limit	Limit Type	Sample Type	Sampling Frequency
All Metals listed in Appendix III	See Appendix III	See Appendix III	grab	1/month
Cyanide	SW = 1.0 ug/l , FW = 5.2 ug/l¹⁷	monthly average	grab	1/month
Carbon Tetrachloride	4.4 ug/l	daily maximum	grab	1/month
1,2 (or o)-Dichlorobenzene (DCB)	600 ug/l	daily maximum	grab	1/month
1,3 (or m)-Dichlorobenzene	320 ug/l	daily maximum	grab	1/month
1,4 (or p)-Dichlorobenzene	5.0 ug/l	daily maximum	grab	1/month
Total Dichlorobenzene	763 ug/l - NH only	daily maximum	grab	1/month
1,1-Dichloroethane (DCA)	70 ug/l	daily maximum	grab	1/month
1,2-Dichloroethane	5.0 ug/l	daily maximum	grab	1/month
1,1-Dichloroethylene (DCE)	3.2 ug/l	daily maximum	grab	1/month
cis-1,2-Dichloroethylene	70 ug/l	daily maximum	grab	1/month
Methylene Chloride	4.6 ug/l	daily maximum	grab	1/month
Tetrachloroethylene (PCE)	5.0 ug/l	daily maximum	grab	1/month
1,1,1-Trichloroethane (TCA)	200 ug/l	daily maximum	grab	1/month
1,1,2 Trichloroethane	5.0 ug/l	daily maximum	grab	1/month
Trichloroethylene (TCE)	5.0 ug/l	daily maximum	grab	1/month
Vinyl Chloride	2.0 ug/l	daily maximum	grab	1/month
Total Suspended Solids (TSS)	30.0 mg/l	monthly average	grab	1/month

¹⁷Limits for cyanide are based on EPA's water quality criteria expressed as micrograms (ug) of free cyanide per liter. There is currently no EPA approved test method for free cyanide. Therefore, total cyanide must be reported. Although the maximum values for cyanide are 5.2 ug/l and 1.0 ug/l for freshwater and saltwater, respectively, the compliance limits are equal to the minimum level (ML) of the test method used as listed in Appendix VI (i.e., 10 ug/l).

3. Contaminated Construction Dewatering

A. General Urban Fill Sites				
Pollutants To Be Monitored	Effluent Limit	Limit Type	Sample Type	Sampling Frequency
All pollutants listed in Appendix III	See Appendix III	See Appendix III	grab	1/month

B. Listed Contamination Sites				
Pollutants To Be Monitored	Effluent Limit	Limit Type	Sample Type	Sampling Frequency
All pollutants listed in Appendix III	See Appendix III	See Appendix III	grab	1/month

4. Miscellaneous Discharges

A. Aquifer Pump Testing				
Pollutants To Be Monitored	Effluent Limit	Limit Type	Sample Type	Sampling Frequency
All pollutants listed in Appendix III	See Appendix III	See Appendix III	grab	1/month

B. Well Development or Rehabilitation				
Pollutants To Be Monitored	Effluent Limit	Limit Type	Sample Type	Sampling Frequency
All pollutants listed in Appendix III	See Appendix III	See Appendix III	grab	1/month

C. Hydrostatic Testing of Pipelines and Tanks					
Pollutants To Be Monitored	Effluent Limit		Limit Type	Sample Type	Sampling Frequency
TSS	50 mg/l		monthly average	grab	Per Part I.D.8.
Total residual chlorine (TRC)	FW = 11 ug/l SW = 7.5 ug/l		monthly average	grab	Per Part I.D.8.
TPH	5.0 mg/l		daily maximum	grab	Per Part I.D.8.
Benzene	50.0 ug/l		daily maximum	grab	Per Part I.D.8.
Total BTEX	100 ug/l		daily maximum	grab	Per Part I.D.8.
Naphthalene	20 ug/l ¹³		daily maximum	grab	Per Part I.D.8.
Ethylene dibromide	0.05 ug/l		daily maximum	grab	Per Part I.D.8.
MtBE	70.0 ug/l - MA		daily maximum	grab	Per Part I.D.8.
tert-Butyl Alcohol	Monitor Only (ug/L)		daily maximum	grab	Per Part I.D.8.
tert-Amyl Methyl Ether	Monitor Only (ug/L)		daily maximum	grab	Per Part I.D.8.
PAHs	See Appendix III (#'s 35 & 36)		daily maximum	grab	Per Part I.D.8.
Lead (total recoverable)	In MA: FW = 1.3 ug/L, SW = 8.5 ug/L	In NH: FW = 0.5 ug/L, SW = 8.5 ug/L	monthly average	grab	Per Part I.D.8.
Nickel (total recoverable)	In MA: FW = 29.0 ug/L, SW = 8.2 ug/L	In NH: FW = 16.1 ug/L, SW = 8.2 ug/L	monthly average	grab	Per Part I.D.8.
Chromium (trivalent) (total recoverable)	In MA: FW = 48.8 ug/L	IN NH: FW = 27.7 ug/L	monthly average	grab	Per Part I.D.8.
Chromium (hexavalent) (total recoverable)	In MA: FW = 11.4 ug/L SW = 106 ug/L	In NH: FW = 11.4 ug/L, SW = 190 ug/L	monthly average	grab	Per Part I.D.8.
Zinc (total recoverable)	In MA: FW = 66.6 ug/L SW = 85.6 ug/L	In NH: FW = 37 ug/L SW = 85.6 ug/L	monthly average	grab	Per Part I.D.8.
Iron (total recoverable)	In MA: 1,000 ug/L	In NH: 1,000 ug/L	daily maximum	grab	Per Part I.D.8.

D. Contaminated Sumps				
Pollutants To Be Monitored	Effluent Limit	Limit Type	Sample Type	Sampling Frequency
All pollutants listed in Appendix III	See Appendix III	See Appendix III	grab	1/month

E. Contaminated Dredge Drain Back Waters (if not covered by Section 401/404 permit)				
Pollutants To Be Monitored	Effluent Limit	Limit Type	Sample Type	Sampling Frequency
All pollutants listed in Appendix III	See Appendix III	See Appendix III	grab	1/month

9. Flow Monitoring - There is no single flow limit that applies to all dischargers covered by this general permit. For proper operation and maintenance of treatment systems, the permittee must monitor and comply with site-specific flow limits as determined by the treatment system.
 - a. **Design flow:** The permittee shall monitor flow with a continuous flow meter, e.g., a meter that records the instantaneous gallons per minute (gpm) and total gallons discharged, to ensure that it does not exceed the design flow of the treatment system, determined by the component of the treatment train with the most restricted flow and as reported on the NOI. See BMPP requirements in Part I.E.2.
 - b. **Total flow:** The permittee shall monitor total monthly flow with a continuous total flow meter, e.g., a totalizer that records the instantaneous gallons per minute (gpm) and total gallons discharged, in order to ensure proper operation and maintenance of the effluent treatment system. See BMPP requirements in Part I.E.2.

D. Sampling, Testing, Recordkeeping, and Reporting Requirements

1. Sampling and Testing

- a. Samples shall be taken at a location that provides for a representative analysis of the influent and effluent. Influent sampling should be taken at a point prior to any treatment of the water, i.e., raw influent. For effluent, samples should be taken just prior to discharge to the receiving water or, if the effluent is commingled with another permitted discharge, prior to such commingling.
- b. All samples shall be tested using the analytical methods found in 40 CFR §136, or alternative methods approved by EPA in accordance with the procedures in 40 CFR §136.
 - i. For measuring volatile compounds, Method 8260C¹⁸ (or most recent version) may be used as a substitute for CWA Methods 524.2, 602, 624, or 1624.
 - ii. For measuring semivolatile compounds, Method 8270D¹⁹ (or the most recent version) may be used as a substitute for Methods 610, 625, and 1625.
 - iii. Any use of Method 8260C or Method 8270D must be accompanied by documented quality assurance quality control (QA/QC) test results to prove that the analytical process can achieve the lower detection limits of the alternative methods.

¹⁸ Method 8260C must be preceded by the sample preparation Method 5030.

¹⁹ Method 8270D must be preceded by either Method 3520C or Method 3535 as the sample preparation method. In either case, the quality control requirements of Method 3500B must be taken into account. The sample preparation method must be specified with data analysis records. Method 8270D may be modified to provide lower detection and quantitation limits using Selected Ion Monitoring (SIM).

- c. Compliance with the permit limits will be based on the Minimum Levels (MLs)²⁰ listed in Appendix VI of this permit. Any value below the applicable ML shall be reported as zero.
 - d. Analysis of influent and effluent samples shall use test methods with the MLs at or below limits where practicable. See Appendix VI for a list of test methods and MLs.
 - 1) Where sample concentrations are above the MLs, any of the methods listed for that pollutant in Appendix VI may be used.
 - 2) Where approved methods have MLs above the permit limits, the permittee must use the approved method with the lowest possible ML before the concentration can be considered non-detectable.
 - e. pH shall be monitored according to Method 150.1 or other method approved for use under 40 CFR 136.
 - f. Temperature shall be monitored according to Method 170.1 or other method approved for use under 40 CFR 136.
2. Initial Treatment System Discharge Startup - The permittee must perform the following additional sampling and analysis of all applicable parameters during the first month of discharge:
- a. During the first week of discharge, permittees must take laboratory samples from the intake to treatment and from the effluent once each day on the first, third, and sixth day of the discharge.

Note: in cases where days fall on a holiday, Sunday, or other normal non-workday, the schedule may be adjusted to the next day before or after the off-day and noted on the monitoring report.
 - b. During the first week, samples may be analyzed in accordance with 40 CFR 136 or by other methods approved by this permit with a 72-hour turnaround time. After first week, samples must be analyzed with a 7 day turnaround time.
 - c. If the treatment system is working properly and achieving effluent limits, sampling for the remainder of the first month shall be weekly (i.e., for weeks 2, 3, and 4) and then monthly thereafter for the term of the permit. After the first week, results for

²⁰ Minimum Level (ML) is the lowest level at which the analytical system gives a recognizable signal and acceptable calibration point for the analyte. The ML represents the lowest concentration at which an analyte can be measured with a known level of confidence. The ML is calculated by multiplying the laboratory-determined method detection limit by 3.18 (see 40 CFR Part 136, Appendix B).

these additional samples shall be received and reviewed by the operator no more than seven (7) days from the sampling event.

- d. During system startup, the operator may also utilize field monitoring and visual observations as appropriate (e.g. portable organic vapor analysis, pH, turbidity, or other tests) to aid in proper system startup.
 - e. If the operator has any indication of water treatment system malfunction or violation of effluent limitations, the operator must immediately shutdown the system discharge until appropriate repairs or other actions can be implemented.
 - 1) If the treatment system is shut down during startup, at re-start of treatment and discharge, the operator shall utilize field monitoring again and an additional laboratory sample must be taken with a 24-hour turnaround time when results must be reviewed by the operator.
 - 2) If the problem has been corrected, the operator may resume with the regular sampling schedule per Part I.D.2.a-d above.
 - 3) If the problem persists, the operator must shut down the treatment system again and make necessary repairs.
 - 4) The permittee must notify the Office of Environmental Stewardship at EPA-NE (617-918-2000) and the appropriate State by telephone, fax, e-mail or other means within 48-hours of the need to shut down the treatment system and cease discharge a second time.
 - 5) Discharge may resume upon completion of correction of the problems or unless otherwise directed by EPA-NE or the state contact.
 - f. Existing data may be substituted for the data required by Part I.D.2.a - e above:
 - i. If equivalent initial sampling and analysis has been conducted prior to the effective date of the permit pursuant to: Massachusetts' regulations 310 CMR 40.0000, the Massachusetts Contingency Plan ("Chapter 21E"); New Hampshire's Title 50 RSA 485-A: Water Pollution and Waste Disposal or Title 50 RSA 485-C: Groundwater Protection Act; or an EPA permit exclusion letter issued pursuant to 40 CFR 122.3, and the data has been submitted with the NOI.
 - ii. Unless the existing treatment system has been interrupted for 45 consecutive days or more prior to the effective date of this permit. Such systems must meet the applicable requirements of Part I.D.5 or 6 below.
3. Acute Toxicity Testing and Monitoring - Permittees are prohibited from adding materials or chemicals which would produce a toxic effect to any aquatic life.
- a. If the States and/or EPA-NE suspect that a discharge has a reasonable potential to cause or contribute to an excursion above the State's narrative criterion for toxicity, the State or EPA-NE may require that the results of a Whole Effluent Toxicity (WET) test and/or a priority pollutant scan of the waste water to be discharged as part of the Notice of Intent, as authorized at 40 CFR Section

122.44(d)(1)(v). If toxicity testing is required, EPA-NE will provide the permittee with a copy of the test procedure and detailed protocol.

- b. The permittee shall submit to EPA-NE and the appropriate State Agency the results of all testing conducted, as required at 40 CFR Section 122.41(l)(4)(ii).

4. Recordkeeping and Reporting

- a. In addition to the recordkeeping requirements found in Part II.C of this permit, the results of the sampling, monitoring, testing, and analysis shall be summarized monthly on the form provided in Appendix VIII and kept on-site or with the permittee and available for inspection by EPA or the State.
- b. The permittee shall submit a summary of the results from sampling, monitoring, testing, and analysis to the EPA-NE and state addresses listed in Appendix VIII, as appropriate, if:
 - 1) the results indicate that a violation of the effluent limitations of this permit has occurred, or
 - 2) EPA-NE or the State request such a report.

5. Intermittent Operations and System Re-Start - If the discharge has been interrupted for more than 45 consecutive days but fewer than 120 consecutive days, the permittee must perform additional monitoring and reporting during re-start.

- a. A minimum of two (2) sets of influent and effluent laboratory samples of all applicable parameters must be taken during the first week after re-start of discharge.
- b. During the first week, samples must be analyzed in accordance with 40 CFR 136 or by other methods allowed by this permit with a 72-hour turnaround time. After first week, samples must be analyzed with a 7 day turnaround time.
- c. If the system is working properly and achieving effluent limits, sampling for the remainder of the first month (i.e., weeks 2, 3, 4) shall be weekly and then monthly thereafter.
- d. If any sample or other observation indicates that effluent quality exceeds permit limitations, the same shutdown, repair, and notification requirements as required during initial startup apply.
- e. The reporting requirements of Part I.D.4 apply.

6. Extended System Shutdown - Treatment systems and discharges that are interrupted for 120 or greater consecutive days are considered extended shutdowns. Any system re-start after this period shall revert to the monitoring and reporting requirements for initial system startup of Part I.D.2.
7. Short-Term Discharges - Discharges lasting less than one week (7 days), such as: pump tests and discharge of temporarily containerized waters, excluding hydrostatic testing discharges, which are then terminated and are not planned to be re-started, are considered “short-term discharges.”
 - a. For all short term discharges, the permittee must take a minimum of three (3) representative influent and effluent laboratory samples.
 - b. At least one sample must be taken on the first day of discharge and one on the last day of discharge. Discharges of one day or less must take a minimum of one sample.
 - c. Samples must be analyzed with a 72-hour turnaround time in accordance with 40 CFR 136 or by other methods allowed by this permit.
 - d. The reporting requirements of Part I.D.4. apply.
8. Hydrostatic Testing Discharge Monitoring and Reporting Requirements - Hydrostatic test waters must meet additional monitoring requirements due to the unique nature of those activities.
 - a. **For New and Existing Tanks:** The operator must take a minimum of six (6) representative grab samples, including:
 - 1) For influent sampling, the operator must take one (1) sample of the fill (source) water during the first 10% of the fill segment time and one (1) sample during the last 10% of the fill-segment time;
 - 2) For in-process sampling, the operator shall take samples of the tank water, following testing but before draining, one (1) at top and one (1) at bottom. The operator shall analyze and evaluate in-process samples prior to discharge. If the analysis demonstrates that the water quality does not meet the effluent limits established in this permit, the operator shall not discharge the effluent until treatment reduces the pollutant level below the limits established in this permit;
 - 3) For effluent sampling, the operator must take one (1) sample of the discharge water during the first 10% of discharge and one (1) sample during the last 10% of discharge. If at anytime the analysis demonstrates that the discharge water quality is not consistent with the effluent limits established in this permit, the operator shall cease discharging the effluent until further treatment achieves the effluent limits; and

- 4) All effluent sampling shall be taken prior to the combination with wastewaters of any type.
- b. **For New and Existing Pipelines:** The operator must take a minimum of six (6) representative grab samples, including:
 - 1) For influent sampling, the operator must take one (1) sample of the fill (source) water during the first 10% and one (1) sample during the last 10% of the fill-segment time;
 - 2) For in-process sampling, the operator shall take two (2) samples of the pipeline water following depressurization. The operator shall analyze and evaluate in-process samples prior to discharge and if the analysis demonstrates that the water quality is not consistent with the effluent limits established in this permit, the operator shall not discharge the effluent until treatment reduces the pollutant level below the limits established in this permit;
 - 3) For effluent sampling, the operator must take one (1) sample of the discharge water during the first 10% of discharge and one (1) sample during the last 10% of discharge. If at anytime the analysis demonstrates that the discharge water quality is not consistent with the effluent limits established in this permit, the operator shall cease discharging the effluent until further treatment achieves the effluent limits;
 - 4) All effluent sampling shall be taken prior to the combination with wastewaters of any type.
- c. Permittees shall follow the reporting requirements of Part I.D.4.

E. Best Management Practices Plan (BMPP)

1. Development of a BMPP - The permittee shall develop and implement a best management practices plan (BMPP) for the discharge operations covered under this permit.
 - a. In accordance with good engineering practices, the permittee shall provide a plan for compliance with the terms of this permit. The BMPP should include methods:
 - 1) to minimize the potential for violations of the terms of the permit;
 - 2) to protect the designated water uses of surrounding surface water bodies;
 - 3) to mitigate pollution from materials storage areas, in-plant transfers of hazardous and/or toxic materials, process and material handling areas, loading and unloading operations, and accidental spillage; and
 - 4) to properly operate and maintain the treatment systems where they are used to meet the limitations in this permit.
 - b. The plan shall identify potential sources of pollution and describe what will be done to reduce the pollutants associated with day-to-day work activity from the

facility.

- c. The BMPP may be a stand-alone document or may be incorporated into any other BMPP, Pollution Prevention (P2), or Spill Prevention Control and Counter Measures (SPCC), or other plan required under other permits or programs.
 - d. The permittee must maintain the BMPP on-site or at the location of the principal operator identified in the RGP and made available for inspection to federal and state personnel.
 - e. The permittee must develop and include with the BMP plan a preventative maintenance plan (PMP) to insure that:
 - 1) a maintenance schedule is in place for any treatment equipment used to meet the limits of this permit, and
 - 2) implementation of regular maintenance activities are undertaken on the treatment system at the site
2. Additional Best Management Practices - The following are specific BMPs which are consistent with standard operating practices and should be considered in the development of a BMP plan:
- a. **Site Security** - Security for the treatment and other systems related to the NPDES discharge should be either incorporated into the overall site security plan or as separate site security provisions as part of a BMP plan.
 - b. **Management of Generated Wastes** - Operators covered by this permit must adhere to proper waste management practices for the facility and should describe how they will comply with the requirements of federal and state regulations, as applicable, including:
 - 1) For sites located in Massachusetts, waste regulations include: Massachusetts regulations for solid wastes generated at sites listed under the MA Contingency Plan (MCP) at 310 CMR 40.0030; and for facilities or sites not covered by the MCP, 310 CMR 30.000, "the Massachusetts Hazardous Waste Regulations."
 - 2) For sites located in New Hampshire, waste regulations include: Part Env-Wm 412, Reporting and Remediation of Oil Discharges, and Env-Wm 100-1100, Hazardous Waste Rules, and any other applicable regulations.
- Submission of a Notice of Termination (NOT) of the discharge (see Appendix V) does not relieve the operator of any requirement for proper management of solid and hazardous waste generated as a result of complying with the permit.
- c. **Prohibition of Discharge Exceeding Design Flow** - The BMPP should describe how flow through the treatment system will be maintained below the "system design flow" (i.e., the maximum flow through the component with the lowest

limiting capacity).

- d. **Total flow through treatment system** - The BMPP should describe how the permittee will monitor the total monthly flow through the treatment system as part of the PMP for the components of the system.
 - e. **Employee Training** - The BMP plan must include a program for training new employees and for refresher training for other employees who have direct or indirect responsibility for insuring compliance with the RGP.
 - f. **Management of Run-on and Runoff** - Any BMP plan developed for the facility covered by the RGP must include actions to control extraneous run-on and runoff of uncontaminated waters which may co-mingle with contaminated waters requiring treatment and discharge. In cases where the site or facility is large and may be covered by other permit requirements, the run-on/runoff controls may be integrated with the overall site requirements.
 - g. **Erosion, Scouring and Sediment Control** - The BMP plan must insure that the discharge(s) covered by this permit do not adversely affect existing water quality by preventing any erosion, stream scouring, or sedimentation caused directly or indirectly by the discharge.
3. BMPs for Hydrostatic Testing - In addition to meeting the numerical limits and other general BMPs in this section, hydrostatic testing dischargers must discuss in the BMPP and implement the following:
- a. Prior to hydrostatic testing, pipes or tanks that will come into contact with the test water must be thoroughly cleaned to remove scale, soil, residues, etc.
 - b. Discharge flow should not exceed the flow of receiving streams and rivers or alter the habitat in other water bodies.
 - c. All chemical additives must be identified. Testing water containing additives must be disposed of as waste.
 - d. De-watering structures (such as splash blocks, sediment filters, etc.) should be used to dissipate energy and control erosion.
4. BMPP Deadlines - The following deadlines apply for developing BMPPs:
- a. **New dischargers** - Permittees initiating new discharges after the effective date of the permit shall develop a BMPP before discharging. The BMPP shall be kept on site.

- b. **Existing dischargers planning to operate for fewer than 180 days** - Permittees overseeing discharges pursuant to approved site remediation projects which will continue for fewer than 180 days from approval of coverage under the RGP, must be able to document that BMPs are currently in place and being implemented at the time the discharge is authorized.
- c. **Existing dischargers planning to operate for more than 180 days** - Permittees with existing discharges pursuant to approved site remediation projects which plan to continue for more than 180 days from approval of coverage under the RGP, shall develop and implement a written BMP Plan (BMPP) within 30 days after receiving notification from EPA-NE that the site/facility is covered by the general permit. The BMPP shall be kept on site.
- d. **Annual certification** - Annually, no later than February 15th, the permittee shall submit a certification to the State and EPA-NE which certifies that the BMPP was followed during the previous calendar year. The certification should state whether or not the inspections and maintenance activities were conducted, results recorded, and records maintained and the facility is in compliance with the BMP Plan. Annual certifications should be submitted as a letter to the addresses listed in Appendix VIII.
 - 1) The annual certification shall be in the form of a letter and/or a checklist that indicates which elements of the BMP plan have been implemented and which elements have not, including reasons why not.
 - 2) The certification must be completed and signed according to the requirements of 40 CFR 122.22 by either the operator(s) of the treatment system.

F. Special NPDES Permit Conditions

The following are a number of special NPDES conditions which apply to certain types of discharges:

1. Compliance with Municipal Separate Storm Sewer Systems (MS4) Requirements and Storm Water Management Programs (SWMP)
 - a. Dischargers covered by the RGP who discharge indirectly into a surface water through a MS4 collection system must comply with local requirements for discharge to that system including any Storm Water Management Program (SWMP) developed under EPA's MS4 general permit. The permittee shall keep records of any local permit, monitoring, or other information regarding the compliance with the local requirements along with the compliance records for this permit.
 - b. If an operator of the facility is covered by the multi-sector storm water general permit and by this Remediation General Permit (RGP), the following particular

requirements apply:

- 1) Operators who are utilizing a non-municipal storm sewer system at a facility covered by the EPA multi-sector storm water general permit for industrial activities must comply with any SWPPP developed under that permit.
- 2) Where there is separate ownership and/or different operators of the facility/site and the sewer system, the operator of the facility/site covered by this permit must notify the operator of the facility covered by the multi-sector permit.
- 3) An authorization to discharge under this general permit, where the activity discharges to a municipal or private storm drain owned by another party, does not convey any rights or authorization to connect to that drain.

2. Special Conditions for Hydrostatic Testing

- a. Permittees are prohibited to discharge any sludge generated in the pre-cleaning or any rinsing solutions used in the pre-cleaning of the pipelines or tanks.
- b. Permittees are prohibited from discharging hydrostatic test water to which treatment chemicals, corrosion inhibitors or biocides have been added.

G. Administrative Requirements

1. Notice of Change (NOC) - Permittees covered under this permit may request a change to certain conditions of this permit through submission of a notice of change (NOC) to the EPA-NE Director with a copy to the State agency.
 - a. A list of acceptable changes can be found in the NOC instructions in Appendix V. Such changes are not a permit modifications as provided for under 40 CFR 122.62.
 - b. For purposes of the RGP, the NOC may consist of either:
 - 1) the suggested NOC form in Appendix V of the RGP, or
 - 2) some other form of official correspondence containing all of the information described in the NOC instructions in Appendix V of this permit.
 - c. Signed and completed NOC forms and attachments must be submitted to EPA-NE and the appropriate state at the addresses listed in Appendix V, Section I.B.
2. Notice of Termination (NOT) - Permittees shall notify EPA-NE and the state in writing of the termination of discharge(s) authorized under the general permit. The Notice of Termination (NOT) may be either the suggested NOT form in Appendix V or any other form of official correspondence to EPA-NE and the state. Instruction for completing the NOT are contained in Appendix V.

- a. Termination of Coverage Under the RGP for Discharge - The NOT must be completed and submitted within 30 days of the permanent cessation of the discharge(s) authorized by the RGP.
- b. Signed and completed NOT forms and attachments must be submitted to EPA-NE and the appropriate state at the addresses listed in Appendix V, Section I.B.

3. Joint Issuance and Enforcement

- a. For sites in New Hampshire, this NPDES Discharge Permit is issued by the EPA under Federal and State law. Upon final issuance by the EPA-NE, the NHDES-WD may adopt this permit, including all terms and conditions, as a State permit pursuant to RSA 485-A:13. Each Agency shall have the independent right to enforce the terms and conditions of this Permit. Any modification, suspension or revocation of this Permit shall be effective only with respect to the Agency taking such action, and shall not affect the validity or status of the Permit as issued by the other Agency, unless and until each Agency has concurred in writing with such modification, suspension or revocation.
- b. For sites in Massachusetts, this Discharge Permit is issued jointly by the U. S. Environmental Protection Agency and the Massachusetts Department of Environmental Protection under Federal and State law, respectively. As such, all the terms and conditions of this permit are hereby incorporated into and constitute a discharge permit issued by the Commissioner of the Massachusetts Department of Environmental Protection pursuant to M.G.L. Chap.21, §43, except where exempted under 310 CMR 40.0041(4) of the Massachusetts Contingency Plan. Each agency shall have the independent right to enforce the terms and conditions of this permit. Any modification, suspension or revocation of this permit shall be effective only with respect to the agency taking such action, and shall not affect the validity or status of this permit as issued by the other agency, unless and until each agency has concurred in writing with such modification, suspension or revocation. In the event any portion of this permit is declared invalid, illegal or otherwise issued in violation of state law, such permit shall remain in full force and effect under federal law as an NPDES permit issued by the U.S. Environmental Protection Agency. In the event this permit is declared invalid, illegal or otherwise issued in violation of federal law, this permit shall remain in full force and effect under state law as a permit issued by the Commonwealth of Massachusetts, except where exempted under 310 CMR 40.0041(4) of the Massachusetts Contingency Plan.

- 4. Continuation of This General Permit After Expiration: If this permit is not reissued prior to the expiration date, it will be administratively continued in accordance with the Administrative Procedures Act and remain in force and in effect as to any particular permittee. However, once this permit expires EPA-NE cannot provide written

notification of coverage under this general permit to any permittee who submits Notice of Intent to EPA Region I after the permit's expiration date. Any permittee who was granted permit coverage prior to the expiration date will automatically remain covered by the continued permit until the earlier of:

- a. Reissuance of this permit, at which time the permittee must comply with the Notice of Intent conditions of the new permit to maintain authorization to discharge;
- b. The permittee's submittal of a Notice of Termination;
- c. Issuance of an individual permit for the permittee's discharges; or
- d. A formal permit decision by the EPA-NE Director not to reissue this general permit, at which time the permittee must seek coverage under an alternative general permit or an individual permit.

H. Additional Permit Conditions Applicable to Specific States or Indian Country Lands
(If required, to be completed following State certification process and the public notice period.)