

WO Number

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

## INFORMATION ASSIGNED BY OFFICE

NAME:

SERVICE ID:

ACCOUNT NO.:

SERVICE ID:

ADDRESS:

METER NUMBER: 82nd &amp;

Reading Seq.

Ex. 7f (Water Infra)

PHONE NO.:

ISSUE DATE: 1/14/16

PROCESS DATE: 11

PROCESS TIME:

REQUESTED BY: PEGGY

ASSIGNED TO: DENNY

## WORK ORDER CODE &amp; DESCRIPTION:

CHECK SEWER LIFT STATION

## INFORMATION FROM THE FIELD

METER TYPE:

OLD METER #: \_\_\_\_\_

OLD METER READING: 0.00000

WORK DONE BY: FP-BS-DT

NEW METER TYPE: \_\_\_\_\_

NEW METER #: \_\_\_\_\_

NEW METER READING: \_\_\_\_\_

DATE: 1-15-16

Comments: Install New Electric 7 1/2 hp. Motor 213TTDB 6026  
Install Two New Float Ball Switches

DATE COMPLETED: \_\_\_\_\_

## FINAL BILL INFORMATION:

NAME:

ADDRESS:

CITY/STATE/ZIP: ' \_\_\_\_\_

WO Number \_\_\_\_\_

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

## INFORMATION ASSIGNED BY OFFICE

NAME: \_\_\_\_\_

SERVICE ID: \_\_\_\_\_

ACCOUNT NO.: \_\_\_\_\_

SERVICE ID: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

METER NUMBER: \_\_\_\_\_

Reading Seq. \_\_\_\_\_

Ex. 7f (Water Infra)

PHONE NO.: \_\_\_\_\_

ISSUE DATE: 1/25/16

PROCESS DATE: 11

PROCESS TIME: \_\_\_\_\_

REQUESTED BY: PEGGY

ASSIGNED TO: Denny

## WORK ORDER CODE &amp; DESCRIPTION:

Check Sewer LIFT STATION

## INFORMATION FROM THE FIELD

METER TYPE: \_\_\_\_\_

OLD METER #: \_\_\_\_\_

OLD METER READING: 0.00000

WORK DONE BY: FP-BS-DT

NEW METER TYPE: \_\_\_\_\_

NEW METER #: \_\_\_\_\_

NEW METER READING: \_\_\_\_\_

DATE: \_\_\_\_\_

Comments: Install New 7 1/2 hp. Electric Motor { Marathon Electric  
Install Two New B62 Gates Belts { 213TTDB6026

DATE COMPLETED: \_\_\_\_\_

## FINAL BILL INFORMATION:

NAME: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

CITY/STATE/ZIP: \_\_\_\_\_

WO Number

Sewer lift station

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

## INFORMATION ASSIGNED BY OFFICE

NAME:

SERVICE ID:

ACCOUNT NO.:

SERVICE ID:

ADDRESS:

METER NUMBER:

PHONE NO.:

ISSUE DATE: 11

PROCESS DATE: 11

PROCESS TIME:

REQUESTED BY: Wierha

ASSIGNED TO: Gary

Reading Seq. ✓

## WORK ORDER CODE &amp; DESCRIPTION:

53RD

Ex. 6 (Personal Privacy)

Sewer Backing Up.

## INFORMATION FROM THE FIELD

METER TYPE:

OLD METER #:

OLD METER READING: 0.00000

WORK DONE BY: F.P. - B.S. - D.T.

NEW METER TYPE:

NEW METER #:

NEW METER READING:

DATE: 1-20-16

Comments: Replaced top floatball at Centreville Pump station

Ex. 7f (Water Infra)

Ex. 7f (Water Infra)

DATE COMPLETED:

## FINAL BILL INFORMATION:

NAME:

ADDRESS:

CITY/STATE/ZIP:



WO Number

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

INFORMATION ASSIGNED BY OFFICE

NAME:  
SERVICE ID:

PHONE NO.: \_\_\_\_\_  
ISSUE DATE: 11

ACCOUNT NO.:

PROCESS DATE: 7/12/16

SERVICE ID: Reading Seq.

PROCESS TIME: \_\_\_\_\_

ADDRESS:

REQUESTED BY: PEGGY

METER NUMBER: CHECK pump STATION

ASSIGNED TO: FRANK

WORK ORDER CODE & DESCRIPTION:

**Ex. 6 (Personal Privacy)**

all about checking pumps

Bohine

**Ex. 6 (Personal Privacy)**

in CENTREVILLE

INFORMATION FROM THE FIELD

METER TYPE:

NEW METER TYPE: \_\_\_\_\_

OLD METER #: \_\_\_\_\_

NEW METER #: \_\_\_\_\_

OLD METER READING: 0.00000

NEW METER READING: \_\_\_\_\_

WORK DONE BY: F.P. - B.S.

DATE: 7-12-16

Comments: Cleaned float balls & cycled pump  
Pumping now

DATE COMPLETED: \_\_\_\_\_

FINAL BILL INFORMATION:

NAME:

ADDRESS:

CITY/STATE/ZIP: \_\_\_\_\_

cahworko.frx

WO Number

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

4115C

INFORMATION ASSIGNED BY OFFICE

NAME: \_\_\_\_\_  
SERVICE ID: \_\_\_\_\_  
ACCOUNT NO.: \_\_\_\_\_  
SERVICE ID: (Personal) \_\_\_\_\_  
ADDRESS: \_\_\_\_\_  
METER NUMBER: \_\_\_\_\_

PHONE NO.: \_\_\_\_\_  
ISSUE DATE: 11  
PROCESS DATE: 11  
PROCESS TIME: \_\_\_\_\_  
REQUESTED BY: \_\_\_\_\_  
ASSIGNED TO: FRANK

WORK ORDER CODE & DESCRIPTION:

3 Water coming out Manhole COVER

INFORMATION FROM THE FIELD

METER TYPE: \_\_\_\_\_  
OLD METER #: \_\_\_\_\_  
OLD METER READING: 0.00000  
WORK DONE BY: B.S. - F.P.

NEW METER TYPE: \_\_\_\_\_  
NEW METER #: \_\_\_\_\_  
NEW METER READING: \_\_\_\_\_  
DATE: 7-18-16

Comments: Turned off Bluff station due to  
Breaker Kicked out

Ex. 7f (Water Infra)

DATE COMPLETED: \_\_\_\_\_

FINAL BILL INFORMATION:

NAME: \_\_\_\_\_  
ADDRESS: \_\_\_\_\_  
CITY/STATE/ZIP: \_\_\_\_\_

cahworkco.frx

212197

WO Number

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

*Miss*

INFORMATION ASSIGNED BY OFFICE

NAME:  
SERVICE ID:  
ACCOUNT NO.:  
SERVICE ID: Reading Seq.  
ADDRESS:  
METER NUMBER:

PHONE NO.: \_\_\_\_\_  
ISSUE DATE: 11  
PROCESS DATE: 11  
PROCESS TIME: \_\_\_\_\_  
REQUESTED BY: \_\_\_\_\_  
ASSIGNED TO: \_\_\_\_\_

WORK ORDER CODE & DESCRIPTION:

*Pump station @ 83<sup>rd</sup> and  
not running*

**Ex. 7f (Water Infra)**

INFORMATION FROM THE FIELD

METER TYPE:  
OLD METER #: \_\_\_\_\_  
OLD METER READING: 0.00000  
WORK DONE BY: F.P. - B.S.

NEW METER TYPE: \_\_\_\_\_  
NEW METER #: \_\_\_\_\_  
NEW METER READING: \_\_\_\_\_  
DATE: 7-18-16

Comments: *Re-Set Breaker - Pumping now*

DATE COMPLETED: \_\_\_\_\_

FINAL BILL INFORMATION:

NAME:  
ADDRESS:  
CITY/STATE/ZIP:

cahworko.frx

WO Number

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

INFORMATION ASSIGNED BY OFFICE

NAME:  
SERVICE ID:  
ACCOUNT NO.:  
SERVICE ID: Reading Seq.  
ADDRESS:  
METER NUMBER:

PHONE NO.: \_\_\_\_\_  
ISSUE DATE: 11-8/23/16  
PROCESS DATE: 11  
PROCESS TIME: \_\_\_\_\_  
REQUESTED BY: Helba  
ASSIGNED TO: Frank

WORK ORDER CODE & DESCRIPTION:

Pump Station odor on Superior

INFORMATION FROM THE FIELD

METER TYPE:  
OLD METER #: \_\_\_\_\_  
OLD METER READING: 0.00000  
WORK DONE BY: F.P. - B.S.

NEW METER TYPE: \_\_\_\_\_  
NEW METER #: \_\_\_\_\_  
NEW METER READING: \_\_\_\_\_  
DATE: 8-24-16

Comments: Checked Stations - all good - smell odor by  
Bellerville's Treatment Station.

DATE COMPLETED: \_\_\_\_\_

FINAL BILL INFORMATION:

NAME:  
ADDRESS:  
CITY/STATE/ZIP:

cahworko.frx



CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

## INFORMATION ASSIGNED BY OFFICE

NAME:  
SERVICE ID:  
ACCOUNT NO.:  
SERVICE ID: Reading Seq.  
ADDRESS:  
METER NUMBER:

PHONE NO.:  
ISSUE DATE: 11 8/29/74  
PROCESS DATE: 11  
PROCESS TIME:  
REQUESTED BY: Wena  
ASSIGNED TO: Frank

## WORK ORDER CODE &amp; DESCRIPTION:

53<sup>RD</sup> + **Ex. 6 (Personal Privacy)** Sewer Backing Up  
Bad Odor

## INFORMATION FROM THE FIELD

METER TYPE: NEW METER TYPE: \_\_\_\_\_  
OLD METER #: \_\_\_\_\_ NEW METER #: \_\_\_\_\_  
OLD METER READING: 0.00000 NEW METER READING: \_\_\_\_\_  
WORK DONE BY: F.P. - B.S. DATE: 8-29-16

Comment: **Ex. 7f (Water Infra)** Pump clogged with mop head.  
Pulled back off Pump & cleaned out mop head.  
Pumping now.

DATE COMPLETED: \_\_\_\_\_

## FINAL BILL INFORMATION:

NAME:  
ADDRESS:  
CITY/STATE/ZIP:



WO Number

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

Ex. 6 (Personal Privacy) ASSIGNED BY OFFICE

NAME  
SERVICE ID

ACCOUNT NO.:

SERVICE ID:

ADDRESS:

METER NUMBER:

Reading Seq.

PHONE NO.:

ISSUE DATE:

PROCESS DATE:

PROCESS TIME:

REQUESTED BY:

ASSIGNED TO:

WORK ORDER CODE & DESCRIPTION:

Ex. 6 (Personal Privacy)

Called to see if the  
Pump @ 50th St is down

INFORMATION FROM THE FIELD

METER TYPE:

OLD METER #:

OLD METER READING: 0.00000

WORK DONE BY: F.P.-B.S.-D.F.

Comments:

Tapped line to Relieve Backup

NEW METER TYPE:

NEW METER #:

NEW METER READING:

DATE:

9-30-16

DATE COMPLETED:

FINAL BILL INFORMATION:

NAME:

ADDRESS:

CITY/STATE/ZIP:

cahworko.frx

WO Number

MISC

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

INFORMATION ASSIGNED BY OFFICE

NAME: \_\_\_\_\_

SERVICE ID: \_\_\_\_\_

ACCOUNT NO.: \_\_\_\_\_

SERVICE ID: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

METER NUMBER: \_\_\_\_\_

PHONE NO.: \_\_\_\_\_

ISSUE DATE: 11

PROCESS DATE: 11

PROCESS TIME: \_\_\_\_\_

REQUESTED BY: F.P.

ASSIGNED TO: B.S.

Reading Seq

Ex. 6  
(Personal  
Privacy)

LAUREL

WORK ORDER CODE & DESC

REPAIR BROKEN DISCHARGE LINE

INFORMATION FROM THE FIELD

METER TYPE: \_\_\_\_\_

OLD METER #: \_\_\_\_\_

OLD METER READING: 0.00000

WORK DONE BY: F.P. - B.S.

NEW METER TYPE: \_\_\_\_\_

NEW METER #: \_\_\_\_\_

NEW METER READING: \_\_\_\_\_

DATE: 11-15-16

Comments: Repaired line - used one 3" female L.P.T. x 3" SCH 40 fitting, one 3" x 4" SCH 40 glue fitting, one SCH 35 Bushing, one 4" x 4" Fernco fitting, 6' of SCH 35 Pipe, Blocking under fittings & Pipe. Backfilled around line with rock Topped off with spoil.

DATE COMPLETED: \_\_\_\_\_

FINAL BILL INFORMATION:

NAME: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

CITY/STATE/ZIP: \_\_\_\_\_

WO Number

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

INFORMATION ASSIGNED BY OFFICE

NAME:  
SERVICE ID:  
ACCOUNT NO.:  
SERVICE ID: Reading Seq.  
ADDRESS:  
METER NUMBER:

PHONE NO.:  
ISSUE DATE: 11/28/16  
PROCESS DATE: 11  
PROCESS TIME:  
REQUESTED BY: Wexler  
ASSIGNED TO: Frank

WORK ORDER CODE & DESCRIPTION:

82nd Ex. 7f (Water Infra) WATER COMING UP IN  
MIDDLE OF STREET OUT OF MAN HOLE

INFORMATION FROM THE FIELD

METER TYPE: NEW METER TYPE: \_\_\_\_\_  
OLD METER #: NEW METER #: \_\_\_\_\_  
OLD METER READING: 0.00000 NEW METER READING: \_\_\_\_\_  
WORK DONE BY: E.P. DATE: 12-28-16

Comments: BELLEVUE STATIONS BREAKER WAS KICKED  
OUT - RESET BREAKER & SHUT OFF CLUFF STATION  
DUE TO SURCHARGING MANHOLE IN STREET

DATE COMPLETED: \_\_\_\_\_

FINAL BILL INFORMATION:

NAME:  
ADDRESS:  
CITY/STATE/ZIP:



WO Number

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

**Ex. 6 (Personal Privacy)** ASSIGNED BY OFFICE

NAME: \_\_\_\_\_  
SERVICE ID: \_\_\_\_\_

PHONE NO.: \_\_\_\_\_

ISSUE DATE: 11 \_\_\_\_\_

PROCESS DATE: 11 17 \_\_\_\_\_

PROCESS TIME: \_\_\_\_\_

REQUESTED BY: melody \_\_\_\_\_

ASSIGNED TO: Gary \_\_\_\_\_

ACCOUNT NO.: \_\_\_\_\_

SERVICE ID: \_\_\_\_\_ Reading Seq.

ADDRESS: \_\_\_\_\_

METER NUMBER: \_\_\_\_\_

2nd St

**WORK ORDER CODE & DESCRIPTION:**

**Ex. 6 (Personal Privacy)**

Called In and said HE  
Think Our pumps needed to be pumped  
Down 2nd St SEWER IS BACKING  
UP

**Ex. 6 (Personal Privacy)**

**INFORMATION FROM THE FIELD**

METER TYPE: \_\_\_\_\_

NEW METER TYPE: \_\_\_\_\_

OLD METER #: \_\_\_\_\_

NEW METER #: \_\_\_\_\_

OLD METER READING: 0.00000

NEW METER READING: \_\_\_\_\_

WORK DONE BY: \_\_\_\_\_

DATE: \_\_\_\_\_

Comments:

DATE COMPLETED: \_\_\_\_\_

**FINAL BILL INFORMATION:**

NAME: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

CITY/STATE/ZIP: \_\_\_\_\_

cahworko.frx

WO Number

MSC

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

**INFORMATION ASSIGNED BY OFFICE**

NAME: \_\_\_\_\_  
SERVICE ID: \_\_\_\_\_  
ACCOUNT NO.: \_\_\_\_\_  
SERVICE ID: \_\_\_\_\_ Reading Seq. \_\_\_\_\_  
ADDRESS: \_\_\_\_\_  
METER NUMBER: \_\_\_\_\_

PHONE NO.: \_\_\_\_\_  
ISSUE DATE: 11/5/17  
PROCESS DATE: 11  
PROCESS TIME: \_\_\_\_\_  
REQUESTED BY: Melra  
ASSIGNED TO: FRANK

**WORK ORDER CODE & DESCRIPTION:**

**Ex. 7f (Water Infra)**

BACKING UP IN STREET

**INFORMATION FROM THE FIELD**

METER TYPE: \_\_\_\_\_ NEW METER TYPE: \_\_\_\_\_  
OLD METER #: \_\_\_\_\_ NEW METER #: \_\_\_\_\_  
OLD METER READING: 0.00000 NEW METER READING: \_\_\_\_\_  
WORK DONE BY: BS-KM DATE: 5-377

**Comments:**

Turned 53rd off  
for 2 HRS TO LET THE

DATE COMPLETED: \_\_\_\_\_

**Ex. 7f (Water Infra)**

**FINAL BILL INFORMATION:**

NAME: \_\_\_\_\_  
ADDRESS: \_\_\_\_\_  
CITY/STATE/ZIP: \_\_\_\_\_

CATCH UP

Number

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

INFORMATION ASSIGNED BY OFFICE

NAME: \_\_\_\_\_ PHONE NO.: \_\_\_\_\_  
SERVICE ID: \_\_\_\_\_ ISSUE DATE: 5/10-17  
ACCOUNT NO.: \_\_\_\_\_ PROCESS DATE: 11  
SERVICE ID: \_\_\_\_\_ PROCESS TIME: \_\_\_\_\_  
ADDRESS: Park Place REQUESTED BY: Sharon  
METER NUMBER: \_\_\_\_\_ ASSIGNED TO: Frank

Ex. 6 (Personal Privacy)

WORK ORDER CODE & DESCRIPTION:

Customer says sewer bubbling  
out of manhole in Alley

INFORMATION FROM THE FIELD

METER TYPE: \_\_\_\_\_ NEW METER TYPE: \_\_\_\_\_  
OLD METER #: \_\_\_\_\_ NEW METER #: \_\_\_\_\_  
OLD METER READING: 0.00000 NEW METER READING: \_\_\_\_\_  
WORK DONE BY: F.P. DATE: 5-10-17

Comments: Due to oakland station down from Rain/flood.

DATE COMPLETED: \_\_\_\_\_

FINAL BILL INFORMATION:

NAME: \_\_\_\_\_  
ADDRESS: \_\_\_\_\_  
CITY/STATE/ZIP: \_\_\_\_\_

hworko.frx



WO Number

CYCLE: ROUTE #

INFORMATION ASSIGNED BY OFFICE

NAME:  
SERVICE ID:  
ACCOUNT NO.:  
SERVICE ID:  
ADDRESS:  
METER NUMBER:

PHONE NO.:  
ISSUE DATE: 11  
PROCESS DATE: 5/16/17  
PROCESS TIME:  
REQUESTED BY:  
ASSIGNED TO:

Ex. 6 (Personal Privacy)

WORK ORDER CODE & DESCRIPTION:

SEWER BACKING UP

INFORMATION FROM THE FIELD

METER TYPE:  
OLD METER #:

NEW METER TYPE:  
NEW METER #:

OLD METER READING: 0.00000

NEW METER READING:

WORK DONE BY: F.P.-B.S.-T.C.

DATE: 6-7-17

Comments: VACUMED OUT OLD WET WELL & MANHOLE UPSTREAM  
JETTED LINES & CLEANED

DATE COMPLETED:

FINAL BILL INFORMATION:

NAME:  
ADDRESS:  
CITY/STATE/ZIP:

cahworko.frx

WO Number

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

INFORMATION ASSIGNED BY OFFICE

NAME:  
SERVICE ID:

ACCOUNT NO.:

SERVICE ID: \_\_\_\_\_ Reading Seq. \_\_\_\_\_

ADDRESS:  
METER NUMBER

Ex. 6  
(Personal  
Privacy)

82nd St

PHONE NO.:

ISSUE DATE: 11/06-19-2017

PROCESS DATE: 11

PROCESS TIME: \_\_\_\_\_

REQUESTED BY: melody

ASSIGNED TO: FRANK

WORK ORDER CODE & DESCRIPTION:

Customer called and said that on 82nd St that she see a lot of water coming up

INFORMATION FROM THE FIELD

METER TYPE:

NEW METER TYPE: \_\_\_\_\_

OLD METER #: \_\_\_\_\_

NEW METER #: \_\_\_\_\_

OLD METER READING: 0.00000

NEW METER READING: \_\_\_\_\_

WORK DONE BY: R. M.

DATE: 6-19-17

Comments: Due to Bellevue station had kicked out Breaker - Re-Set Breaker

DATE COMPLETED: \_\_\_\_\_

FINAL BILL INFORMATION:

NAME:

ADDRESS:

CITY/STATE/ZIP:

cahworko.frx

VO Number SW 27

DIG# X 1710484

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_ 6-21-17 - 9:00 A.M.

INFORMATION ASSIGNED BY OFFICE

NAME: \_\_\_\_\_

SERVICE ID: \_\_\_\_\_

ACCOUNT NO.: \_\_\_\_\_

SERVICE ID: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

METER NUMBER \_\_\_\_\_

Ex. 6 (Personal Privacy)

Ex. 7f (Water Infra)

PILL BOX

71ST.

PHONE NO.: \_\_\_\_\_

ISSUE DATE: 11-6-20-17

PROCESS DATE: 11

PROCESS TIME: \_\_\_\_\_

REQUESTED BY: F.P.

ASSIGNED TO: \_\_\_\_\_

WORK ORDER CODE & DESCRIPTION:

REPAIR BY-PASS DISCHARGE LINE

INFORMATION FROM THE FIELD

METER TYPE: \_\_\_\_\_

OLD METER #: \_\_\_\_\_

OLD METER READING: 0.00000

WORK DONE BY: F.P.-B.S.-T.C.-K.M.

NEW METER TYPE: \_\_\_\_\_

NEW METER #: \_\_\_\_\_

NEW METER READING: \_\_\_\_\_

DATE: 6-21-17

Comments: REPAIRED / REPLACED BY-PASS DISCHARGE LINE -  
USED TWO 4"X4" SOLID SLEEVES, ONE 4"X4"X4" SCH 40 TEE, ONE  
STICK OF SCH 40 4" P.V.C. - ONE SCH 40 4" GLOBE 4" BUSHING, ONE SCH 40  
4"X4" COUPLING, ONE 4"X3" SCH BUSHING, 5" SCH 40 NIPPLE, ONE 3" GLOBE X 3" I.  
FEMALE FITTING, REUSED 3" CAM LOCK MALE FITTING & DUST CAP, RESET BOX AROUND  
DATE COMPLETED: \_\_\_\_\_ FITTINGS

FINAL BILL INFORMATION:

NAME: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

CITY/STATE/ZIP: \_\_\_\_\_



CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

### INFORMATION ASSIGNED BY OFFICE

NAME:  
SERVICE ID:  
ACCOUNT NO.:  
SERVICE ID:  
ADDRESS:  
METER NUMBER:

PHONE NO.: \_\_\_\_\_  
ISSUE DATE: 8/1/17  
PROCESS DATE: 11  
PROCESS TIME: \_\_\_\_\_  
REQUESTED BY: \_\_\_\_\_  
ASSIGNED TO: Frank

WORK ORDER CODE & DESCRIPTION

Rea **Ex. 6 (Personal Privacy)**  
82nd **Ex. 6 (Personal Privacy)**

- Strong sewer  
odor

### INFORMATION FROM THE FIELD

METER TYPE:  
OLD METER #: \_\_\_\_\_  
OLD METER READING: 0.00000  
WORK DONE BY: F.C.

NEW METER TYPE: \_\_\_\_\_  
NEW METER #: \_\_\_\_\_  
NEW METER READING: \_\_\_\_\_  
DATE: 8-1-17

Comments: Due to By-Pass Pumping at Bellevue Station

DATE COMPLETED: \_\_\_\_\_

FINAL BILL INFORMATION:

NAME:  
ADDRESS:  
CITY/STATE/ZIP:

WO Number

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

INFORMATION ASSIGNED BY OFFICE

NAME:  
SERVICE ID:  
ACCOUNT NO.:  
SERVICE ID: Reading Seq.  
ADDRESS: Ex. 6 (Personal Privacy)  
METER NUMBER:

TUDOR

PHONE NO.: \_\_\_\_\_  
ISSUE DATE: 9/15/17  
PROCESS DATE: 11  
PROCESS TIME:  
REQUESTED BY: PEGGY  
ASSIGNED TO: FRANK

WORK ORDER CODE & DESCRIPTION:

sewer BACKING up

INFORMATION FROM THE FIELD

METER TYPE:  
OLD METER #: \_\_\_\_\_  
OLD METER READING: 0.00000  
WORK DONE BY: F.P.-B.S.-T.C.

NEW METER TYPE: \_\_\_\_\_  
NEW METER #: \_\_\_\_\_  
NEW METER READING: \_\_\_\_\_  
DATE: 9-15-17

Comments: JETTED LINE TO RELIEVE BACKUP

DATE COMPLETED: \_\_\_\_\_

FINAL BILL INFORMATION:

NAME:  
ADDRESS:  
CITY/STATE/ZIP:



WO Number

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

**INFORMATION ASSIGNED BY OFFICE**

NAME: \_\_\_\_\_

PHONE NO.: \_\_\_\_\_

SERVICE ID: \_\_\_\_\_

ISSUE DATE: 2-20-18

ACCOUNT NO.: \_\_\_\_\_

PROCESS DATE: 11

SERVICE ID: \_\_\_\_\_

Reading Seq. \_\_\_\_\_

PROCESS TIME: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

REQUESTED BY: PEGLEY

METER NUMBER: \_\_\_\_\_

ASSIGNED TO: BRIAN

**WORK ORDER CODE & DESCRIPTION:**

PULL pump at 50<sup>th</sup> St.

**INFORMATION FROM THE FIELD**

METER TYPE: \_\_\_\_\_

NEW METER TYPE: \_\_\_\_\_

OLD METER #: \_\_\_\_\_

NEW METER #: \_\_\_\_\_

OLD METER READING: 0.00000

NEW METER READING: \_\_\_\_\_

WORK DONE BY: BS-KM

DATE: 2-22-18

Comments: \_\_\_\_\_

DATE COMPLETED: \_\_\_\_\_

pulled pump #1

**FINAL BILL INFORMATION:**

NAME: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

CITY/STATE/ZIP: \_\_\_\_\_

AT 50<sup>th</sup>

Removed RAGS

cahworko.frz

BACK IN Service



WO Number

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

**INFORMATION ASSIGNED BY OFFICE**

NAME:  
SERVICE ID:  
ACCOUNT NO.:  
SERVICE ID:      Reading Seq.  
ADDRESS:  
METER NUMBER:

PHONE NO.: \_\_\_\_\_  
ISSUE DATE: 11  
PROCESS DATE: 2/12/18  
PROCESS TIME: \_\_\_\_\_  
REQUESTED BY: PEGGY  
ASSIGNED TO: BRIAN

**WORK ORDER CODE & DESCRIPTION:**

Remove Rags from Bridge Dale pump  
STATION

**INFORMATION FROM THE FIELD**

METER TYPE:  
OLD METER #: \_\_\_\_\_  
OLD METER READING: 0.00000  
WORK DONE BY: BS-DT

NEW METER TYPE: \_\_\_\_\_  
NEW METER #: \_\_\_\_\_  
NEW METER READING: \_\_\_\_\_  
DATE: 2-21-18

Comments:

DATE COMPLETED: \_\_\_\_\_

**FINAL BILL INFORMATION:**

NAME:  
ADDRESS:  
CITY/STATE/ZIP:

Pulled Rags  
from Pump - Re-set  
STARTER - ALL GOOD

cahworko.frx

WO Number

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

**INFORMATION ASSIGNED BY OFFICE**

NAME: \_\_\_\_\_  
SERVICE ID: \_\_\_\_\_  
ACCOUNT NO.: \_\_\_\_\_  
SERVICE ID: \_\_\_\_\_ Reading Seq. \_\_\_\_\_  
ADDRESS: \_\_\_\_\_  
METER NUMBER: \_\_\_\_\_

PHONE NO.: \_\_\_\_\_  
ISSUE DATE: 2/20/18  
PROCESS DATE: 11  
PROCESS TIME: \_\_\_\_\_  
REQUESTED BY: PEGGY  
ASSIGNED TO: BRIAN

**WORK ORDER CODE & DESCRIPTION:**

*pull pump at 50th St*

**INFORMATION FROM THE FIELD**

METER TYPE: \_\_\_\_\_  
OLD METER #: \_\_\_\_\_  
OLD METER READING: 0.00000  
WORK DONE BY: BS-Km

NEW METER TYPE: \_\_\_\_\_  
NEW METER #: \_\_\_\_\_  
NEW METER READING: \_\_\_\_\_  
DATE: 2-22-18

Comments:

DATE COMPLETED: \_\_\_\_\_

**FINAL BILL INFORMATION:**

NAME: \_\_\_\_\_  
ADDRESS: \_\_\_\_\_  
CITY/STATE/ZIP: \_\_\_\_\_

cahworko.frx

*pulled pump #1  
AT 50th  
Removed RAGS  
BACK in Service*



CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

## INFORMATION ASSIGNED BY OFFICE

NAME: \_\_\_\_\_  
SERVICE ID: \_\_\_\_\_  
ACCOUNT NO.: \_\_\_\_\_  
SERVICE ID: **Ex. 6 (Personal Privacy)**  
ADDRESS: \_\_\_\_\_  
METER NUMBER: \_\_\_\_\_

PHONE NO.: \_\_\_\_\_  
ISSUE DATE: 11-3-15-18  
PROCESS DATE: 11  
PROCESS TIME: \_\_\_\_\_  
REQUESTED BY: Melody  
ASSIGNED TO: Frank

## WORK ORDER CODE &amp; DESCRIPTION:

Customer called and stated that the  
MANHoles ARE TOO Full AND need to  
Be Pumped Down

## INFORMATION FROM THE FIELD

METER TYPE: \_\_\_\_\_ NEW METER TYPE: \_\_\_\_\_  
OLD METER #: \_\_\_\_\_ NEW METER #: \_\_\_\_\_  
OLD METER READING: 0.00000 NEW METER READING: \_\_\_\_\_  
WORK DONE BY: F.P.-B.S. **Ex. 7f (Water Infra)** 3-15-18

Comments: Due to Pump at **Ex. 7f (Water Infra)** marked out - electrical &  
Pump #1A1 out - Both pumping now.

DATE COMPLETED: \_\_\_\_\_

## FINAL BILL INFORMATION:

NAME: \_\_\_\_\_  
ADDRESS: \_\_\_\_\_  
CITY/STATE/ZIP: \_\_\_\_\_



WO Number

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

## INFORMATION ASSIGNED BY OFFICE

NAME:  
SERVICE ID:  
ACCOUNT NO.: **Ex. 7f (Water Infra)**  
SERVICE ID:  
ADDRESS:  
METER NUMBER:

market

PHONE NO.:  
ISSUE DATE: 4-20-18  
PROCESS DATE: 11  
PROCESS TIME:  
REQUESTED BY: [Signature]  
ASSIGNED TO:

## WORK ORDER CODE &amp; DESCRIPTION:

pull #2 Pump @

**Ex. 7f (Water Infra)**

Market

## INFORMATION FROM THE FIELD

METER TYPE:

NEW METER TYPE: \_\_\_\_\_

OLD METER #: \_\_\_\_\_

NEW METER #: \_\_\_\_\_

OLD METER READING: 0.00000

NEW METER READING: \_\_\_\_\_

WORK DONE BY: BS-KM-CFDATE: 9-20-18

Comments:

Pulled Pump Removed  
VALUTE & cleaned TRASH from  
IMPELLER - Re-Set  
PUMP - BACK IN SRV

DATE COMPLETED: \_\_\_\_\_

## FINAL BILL INFORMATION:

NAME:  
ADDRESS:  
CITY/STATE/ZIP:

WO Number

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

## INFORMATION ASSIGNED BY OFFICE

NAME:  
SERVICE ID:  
ACCOUNT NO.:  
SERVICE ID:  
ADDRESS:  
METER NUMBER:

Ex. 7f  
(Water  
Infra)

Reading Seq.

Superior

PHONE NO.: \_\_\_\_\_  
ISSUE DATE: 11-8-18  
PROCESS DATE: 11  
PROCESS TIME: \_\_\_\_\_  
REQUESTED BY: \_\_\_\_\_  
ASSIGNED TO: Frank

## WORK ORDER CODE &amp; DESCRIPTION:

Superior pump station  
replace float balls

## INFORMATION FROM THE FIELD

METER TYPE:

NEW METER TYPE: \_\_\_\_\_

OLD METER #: \_\_\_\_\_

NEW METER #: \_\_\_\_\_

OLD METER READING: 0.00000

NEW METER READING: \_\_\_\_\_

WORK DONE BY: F.P. - B.S.DATE: 11-7-18

Comments: Pulled Two new floatballs & wired in  
on 11-7-18

DATE COMPLETED: \_\_\_\_\_

## FINAL BILL INFORMATION:

NAME:

ADDRESS:

CITY/STATE/ZIP: ,

WO Number

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

INFORMATION ASSIGNED BY OFFICE

NAME: \_\_\_\_\_  
 SERVICE ID: Ex. 7f (Water Infra)  
 ACCOUNT NO.: \_\_\_\_\_  
 SERVICE ID: \_\_\_\_\_  
 ADDRESS: \_\_\_\_\_  
 METER NUMBER: \_\_\_\_\_

PHONE NO.: \_\_\_\_\_  
 ISSUE DATE: 11-18-18  
 PROCESS DATE: 11  
 PROCESS TIME: \_\_\_\_\_  
 REQUESTED BY: \_\_\_\_\_  
 ASSIGNED TO: Frank

WORK ORDER CODE & DESCRIPTION:

Ex. 7f (Water Infra)

Ames Pump Station  
replace Float Balls

INFORMATION FROM THE FIELD

METER TYPE: \_\_\_\_\_  
 OLD METER #: \_\_\_\_\_  
 OLD METER READING: 0.00000  
 WORK DONE BY: F.P. - B.S.

NEW METER TYPE: \_\_\_\_\_  
 NEW METER #: \_\_\_\_\_  
 NEW METER READING: \_\_\_\_\_  
 DATE: 11-14-18

Comments: INSTALLED NEW CONDUIT & FLOAT BALLS

DATE COMPLETED: \_\_\_\_\_

FINAL BILL INFORMATION:

NAME: \_\_\_\_\_  
 ADDRESS: \_\_\_\_\_  
 CITY/STATE/ZIP: \_\_\_\_\_



WO Number

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

## INFORMATION ASSIGNED BY OFFICE

NAME:

SERVICE ID:

ACCOUNT NO.:

SERVICE ID:

ADDRESS:

METER NUMBER:

PHONE NO.:

ISSUE DATE: 11-8-18PROCESS DATE: 11

PROCESS TIME: \_\_\_\_\_

REQUESTED BY: \_\_\_\_\_

ASSIGNED TO: Frank

## WORK ORDER CODE &amp; DESCRIPTION:

Ex. 7f  
(Water  
Infra)  
Reading Seq.  
Superior  
Superior pump station  
replace float ball

## INFORMATION FROM THE FIELD

METER TYPE:

OLD METER #: \_\_\_\_\_

OLD METER READING: 0.00000WORK DONE BY: F.P. - B.S.

NEW METER TYPE: \_\_\_\_\_

NEW METER #: \_\_\_\_\_

NEW METER READING: \_\_\_\_\_

DATE: 11-7-18

Comments: Pulled Two new floatballs & wired in  
on 11-7-18

DATE COMPLETED: \_\_\_\_\_

FINAL BILL INFORMATION:

NAME:

ADDRESS:

CITY/STATE/ZIP:

WO Number \_\_\_\_\_

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

## INFORMATION ASSIGNED BY OFFICE

NAME: \_\_\_\_\_  
SERVICE ID: \_\_\_\_\_  
ACCOUNT NO.: \_\_\_\_\_  
SERVICE ID: \_\_\_\_\_ Reading Seq. \_\_\_\_\_  
ADDRESS: South 88th St.  
METER NUMBER: \_\_\_\_\_

PHONE NO.: \_\_\_\_\_  
ISSUE DATE: 11/1/16/19  
PROCESS DATE: 11  
PROCESS TIME: \_\_\_\_\_  
REQUESTED BY: LINDA  
ASSIGNED TO: FRANK

## WORK ORDER CODE &amp; DESCRIPTION:

Sewer over-flowing

## INFORMATION FROM THE FIELD

METER TYPE: \_\_\_\_\_  
OLD METER #: \_\_\_\_\_  
OLD METER READING: 0.00000  
WORK DONE BY: BS-TC

NEW METER TYPE: \_\_\_\_\_  
NEW METER #: \_\_\_\_\_  
NEW METER READING: \_\_\_\_\_  
DATE: 1-17-19

Comments:

DATE COMPLETED: \_\_\_\_\_

## FINAL BILL INFORMATION:

NAME: \_\_\_\_\_  
ADDRESS: \_\_\_\_\_  
CITY/STATE/ZIP: \_\_\_\_\_

cahworko.frx

Jetted  
Line  
AT  
Ex. 6 (Personal Privacy)

WO Number

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

## INFORMATION ASSIGNED BY OFFICE

NAME: Tom @ Signal Mill Fire Dept

SERVICE ID: Ex. 6 (Personal Privacy)

ACCOUNT NO.:

SERVICE ID: (Personal Privacy) Reading Seq.

ADDRESS: Chase Ln.

METER NUMBER:

PHONE NO.:

ISSUE DATE: 11/4/19

PROCESS DATE: 11

PROCESS TIME:

REQUESTED BY: NALISTA

ASSIGNED TO:

## WORK ORDER CODE &amp; DESCRIPTION:

Ex. 6 (Personal Privacy)

Chase Ln. he said it looked like  
some one hit the fire hydrant knocked it down  
and took it.

Reported by Tom-Signal Mill Fire Dept -

## INFORMATION FROM THE FIELD

METER TYPE:

NEW METER TYPE: \_\_\_\_\_

OLD METER #:

NEW METER #:

OLD METER READING: 0.00000

NEW METER READING: \_\_\_\_\_

WORK DONE BY: F.P. - B.S.

DATE: 4-9-19

Comments: hydrant was hit & can't find hydrant - Not leaking  
Branch Valve is under water now.

DATE COMPLETED: \_\_\_\_\_

## FINAL BILL INFORMATION:

NAME:

ADDRESS:

CITY/STATE/ZIP:



WO Number

CYCLE: \_\_\_\_\_

ROUTE # \_\_\_\_\_

## INFORMATION ASSIGNED BY OFFICE

NAME: \_\_\_\_\_

SERVICE ID: \_\_\_\_\_

ACCOUNT NO.: \_\_\_\_\_

SERVICE ID: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

METER NUMBER: LAURALEE

Reading S

Ex. 7f (Water Infra)

PHONE NO.: \_\_\_\_\_

ISSUE DATE: 4/18/19

PROCESS DATE: 11

PROCESS TIME: \_\_\_\_\_

REQUESTED BY: DENNY

ASSIGNED TO: \_\_\_\_\_

## WORK ORDER CODE &amp; DESCRIPTION:

CHECK pumps &amp; Hose - SECURE AREA

## INFORMATION FROM THE FIELD

METER TYPE: \_\_\_\_\_

NEW METER TYPE: \_\_\_\_\_

OLD METER #: \_\_\_\_\_

NEW METER #: \_\_\_\_\_

OLD METER READING: 0.00000

NEW METER READING: \_\_\_\_\_

WORK DONE BY: \_\_\_\_\_

DATE: \_\_\_\_\_

Comments:

4-24-19 - F.P. & B.S. - Installed one 4'x4' Piece of 3/4" plywood  
Notched out for Hoses on manhole lid.  
5-10-19 F.P. & B.S. INSTALLED FENCING AROUND WELL

DATE COMPLETED: \_\_\_\_\_

## FINAL BILL INFORMATION:

NAME: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

CITY/STATE/ZIP: \_\_\_\_\_

WO Number

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

**Ex. 6 (Personal Privacy)**

NAME:

PHONE NO.: 1018 781-2041

SERVICE ID:

ISSUE DATE: 11/5/2/19

ACCOUNT NO:

CESS DATE: 11

SERVICE ID:

Reading Seq.

PROCESS TIME: 3:31pm

ADDRESS:

REQUESTED BY: ANVISHA

METER NUMBER:

ASSIGNED TO: FRANK

**WORK ORDER CODE & DESCRIPTION:**

sewer backing up bubbling out  
of manhole

**INFORMATION FROM THE FIELD**

METER TYPE:

NEW METER TYPE: \_\_\_\_\_

OLD METER #: \_\_\_\_\_

NEW METER #: \_\_\_\_\_

OLD METER READING: 0.00000

NEW METER READING: \_\_\_\_\_

WORK DONE BY: BS-TC

DATE: 5-3-19

Comments:

JETTED MAIN LINE  
IN front of

DATE COMPLETED: \_\_\_\_\_

**FINAL BILL INFORMATION:**

NAME:

ADDRESS:

CITY/STATE/ZIP:

**Ex. 6 (Personal Privacy)**

BATES TWO

**Ex. 6 (Personal Privacy)**

WQ Number

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

INFORMATION ASSIGNED BY OFFICE

NAME:  
SERVICE ID:

ACCOUNT NO.:

SERVICE ID:

ADDRESS:

METER NUMBER:

Reading Seq.

Ex. 6 (Personal Privacy)

PHONE NO.:

ISSUE DATE:

PROCESS DATE:

PROCESS TIME:

REQUESTED BY:

ASSIGNED TO:

WORK ORDER CODE & DESCRIPTION:

A Guy called in said water is coming  
up out of the street He think it might  
be a water main break.  
This side only

INFORMATION FROM THE FIELD

METER TYPE:

OLD METER #:

OLD METER READING:

WORK DONE BY: F.P. - B.S.

NEW METER TYPE:

NEW METER #:

NEW METER READING:

DATE: 6-17-19

Comments:

Repaired 2" P.V.C. main Break - used one  
2" S.S. Repair Clamp. Backfilled with Spoil.

DATE COMPLETED:

FINAL BILL INFORMATION:

NAME:

ADDRESS:

CITY/STATE/ZIP:

cahworko.frx



WO Number \_\_\_\_\_

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

## INFORMATION ASSIGNED BY OFFICE

NAME: \_\_\_\_\_

PHONE NO.: \_\_\_\_\_

SERVICE ID: \_\_\_\_\_

ISSUE DATE: 11

ACCOUNT NO.: \_\_\_\_\_

PROCESS DATE: 11

SERVICE ID: \_\_\_\_\_

Reading Seq. \_\_\_\_\_

ADDRESS: \_\_\_\_\_

METER NUMBER: \_\_\_\_\_

Ex. 6 (Personal Privacy)

E: \_\_\_\_\_

Y: \_\_\_\_\_

O: \_\_\_\_\_

WORK ORDER CODE &amp; DESCRIPTION:

Customer called says water  
is bubbling up in street next to curb

## INFORMATION FROM THE FIELD

METER TYPE: \_\_\_\_\_

NEW METER TYPE: \_\_\_\_\_

OLD METER #: \_\_\_\_\_

NEW METER #: \_\_\_\_\_

OLD METER READING: 0.00000

NEW METER READING: \_\_\_\_\_

WORK DONE BY: F.P.DATE: 6-7-3-19

Comments:

This is a storm sewer surcharging.  
Village problem.

DATE COMPLETED: \_\_\_\_\_

## FINAL BILL INFORMATION:

NAME: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

CITY/STATE/ZIP: \_\_\_\_\_

WQ Number

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

INFORMATION ASSIGNED BY OFFICE

NAME: \_\_\_\_\_  
SERVICE ID: Felling Springs  
ACCOUNT NO.: Ex. 6 (Personal Privacy)  
SERVICE ID: \_\_\_\_\_  
ADDRESS: \_\_\_\_\_  
METER NUMBER: \_\_\_\_\_

PHONE NO.: \_\_\_\_\_  
ISSUE DATE: 11  
PROCESS DATE: 11  
PROCESS TIME: \_\_\_\_\_  
REQUESTED BY: \_\_\_\_\_  
ASSIGNED TO: \_\_\_\_\_

WORK ORDER CODE & DESCRIPTION:

Both manholes have water coming out of them  
This side only  
✱

INFORMATION FROM THE FIELD

METER TYPE: \_\_\_\_\_  
OLD METER #: \_\_\_\_\_  
OLD METER READING: \_\_\_\_\_  
WORK DONE BY: F.P.

NEW METER TYPE: \_\_\_\_\_  
NEW METER #: \_\_\_\_\_  
NEW METER READING: \_\_\_\_\_  
DATE: 7-25-19

Comments: NOT OUR MANHOLES - VILLAGE OF CAHOOKIA

DATE COMPLETED: \_\_\_\_\_

FINAL BILL INFORMATION:

NAME: \_\_\_\_\_  
ADDRESS: \_\_\_\_\_  
CITY/STATE/ZIP: \_\_\_\_\_

cahworkco.frx

WO Number

CYCLE: ROUTE #

INFORMATION ASSIGNED BY OFFICE

NAME:

SERVICE ID:

ACCOUNT NO.:

SERVICE ID:

ADDRESS:

METER NUMBER:

PHONE NO.:

ISSUE DATE:

PROCESS DATE:

PROCESS TIME:

REQUESTED BY:

ASSIGNED TO:

WORK ORDER CODE & DESCRIPTION:

Cust complains "Raw Sewage" is spilling in his  
and all weekend - c

This side only  
\*

INFORMATION FROM THE FIELD

METER TYPE:

OLD METER #:

OLD METER READING:

WORK DONE BY: B.S. T.C. KM

Comments:

Pulled

Ex. 7f (Water Infra)

learned and replaced pump is active

NEW METER TYPE:

NEW METER #:

NEW METER READING:

DATE: 12/2/19

DATE COMPLETED: 12-2-19

FINAL BILL INFORMATION:

NAME:

ADDRESS:

CITY/STATE/ZIP:

cahworko.frx



WO Number

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

## INFORMATION ASSIGNED BY OFFICE

NAME: \_\_\_\_\_

SERVICE ID: \_\_\_\_\_

ACCOUNT NO.: \_\_\_\_\_

SERVICE ID: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

METER NUMBER: \_\_\_\_\_

PHONE NO.: \_\_\_\_\_

ISSUE DATE: 11/2-5-19PROCESS DATE: 11

PROCESS TIME: \_\_\_\_\_

REQUESTED BY: ShawlinASSIGNED TO: Van

Ex. 71 (Water Infra)

ng Seq.

Bluff

## WORK ORDER CODE &amp; DESCRIPTION:

Sewer Backing up

## INFORMATION FROM THE FIELD

METER TYPE: \_\_\_\_\_

OLD METER #: \_\_\_\_\_

OLD METER READING: 0.00000WORK DONE BY: KM

NEW METER TYPE: \_\_\_\_\_

NEW METER #: \_\_\_\_\_

NEW METER READING: \_\_\_\_\_

DATE: 12-5-19

Comments:

East St. Louis not taking sewage from belleview station causing back up and not being able to bypass at bluffDATE COMPLETED: 12-5-19

## FINAL BILL INFORMATION:

NAME: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

CITY/STATE/ZIP: \_\_\_\_\_

cahworko.frx

WO Number \_\_\_\_\_

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

## INFORMATION ASSIGNED BY OFFICE

NAME: \_\_\_\_\_

SERVICE ID: \_\_\_\_\_

ACCOUNT NO.: \_\_\_\_\_

SERVICE ID: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

METER NUMBER: \_\_\_\_\_

PHONE NO.: \_\_\_\_\_


ISSUE DATE: 12-12-19PROCESS DATE: 11

PROCESS TIME: \_\_\_\_\_

REQUESTED BY: ShaplinASSIGNED TO: Var

Ex. 6 (Personal Privacy)

## WORK ORDER CODE &amp; DESCRIPTION:

86<sup>th</sup>  Repair Road where manholes were uncovered

## INFORMATION FROM THE FIELD

METER TYPE: \_\_\_\_\_

OLD METER #: \_\_\_\_\_

OLD METER READING: 0.00000WORK DONE BY: BS-TC-Km

NEW METER TYPE: \_\_\_\_\_

NEW METER #: \_\_\_\_\_

NEW METER READING: \_\_\_\_\_

DATE: \_\_\_\_\_

Comments: Repaired Area withRockDATE COMPLETED: 1-8-20

## FINAL BILL INFORMATION:

NAME: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

CITY/STATE/ZIP: \_\_\_\_\_

WQ Number

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

INFORMATION ASSIGNED BY OFFICE

NAME:

SERVICE ID:

ACCOUNT NO.:

SERVICE ID:

ADDRESS:

METER NUMBER:

Reading Seq.

PHONE NO.:

ISSUE DATE:

PROCESS DATE:

PROCESS TIME:

REQUESTED BY:

ASSIGNED TO:

WORK ORDER CODE & DESCRIPTION:

Cust advise 'Water Main Break'  
at Beatrice &

INFORMATION FROM THE FIELD

METER TYPE:

OLD METER #:

OLD METER READING:

WORK DONE BY:

NEW METER TYPE:

NEW METER #:

NEW METER READING:

DATE:

Comments:

This is just snow melt. - No Leak.

DATE COMPLETED:

FINAL BILL INFORMATION:

NAME:

ADDRESS:

CITY/STATE/ZIP:

cahworko, frx



WO Number

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

INFORMATION ASSIGNED BY OFFICE

NAME:  
SERVICE ID:

ACCOUNT NO.:

SERVICE ID:

ADDRESS:

METER NUMBER:

Reading Seq.

PHONE NO.:

ISSUE DATE:

PROCESS DATE:

PROCESS TIME:

TESTED BY:

ASSIGNED TO:

11-12-23-19

11

Felicia

Frank

Ex. 6 (Personal Privacy)

WORK ORDER CODE & DESCRIPTION:

Up the hill + on the right water is  
bubbling + it smells.

This side only



INFORMATION FROM THE FIELD

METER TYPE:

OLD METER #:

OLD METER READING:

WORK DONE BY: F.P.-D.T.

NEW METER TYPE:

NEW METER #:

NEW METER READING:

DATE: 12-26-19

Comments:

JETTED, MANHOLE AT BLUFF TO  
RELIEVE BACKUP

Ex. 6 (Personal Privacy)

DATE COMPLETED:

FINAL BILL INFORMATION:

NAME:

ADDRESS:

CITY/STATE/ZIP:

canworko, inc

WQ Number

CYCLE:

ROUTE #

Ex. 6 (Personal Privacy)

OFFICE

NAME:

SERVICE ID:

ACCOUNT NO.:

SERVICE ID:

ADDRESS:

METER NUMBER:

BATES

PHONE NO.:

ISSUE DATE:

PROCESS DATE:

PROCESS TIME:

REQUESTED BY:

ASSIGNED TO:

12/27/19

12/27/19

P. G. G. Y.

FRANK

WORK ORDER CODE & DESCRIPTION:

SEWER BACKING UP

INFORMATION FROM THE FIELD

METER TYPE:

OLD METER #:

OLD METER READING:

WORK DONE BY: F.P. - D.T.

NEW METER TYPE:

NEW METER #:

NEW METER READING:

DATE: 12-30-19

Comments:

Jettied line a

Relieve Backup.

Bates to

DATE COMPLETED:

FINAL BILL INFORMATION:

NAME:

ADDRESS:

CITY/STATE/ZIP:

canworko.frx

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

Ex. 6 (Personal Privacy) BY OFFICE

1/3/2020

NAME: \_\_\_\_\_

PHONE NO.: \_\_\_\_\_

SERVICE ID: \_\_\_\_\_

ISSUE DATE: 11 - \_\_\_\_\_

ACCOUNT NO.: \_\_\_\_\_

PROCESS DATE: 11 - \_\_\_\_\_

SERVICE ID: \_\_\_\_\_

Reading Seq. \_\_\_\_\_

PROCESS TIME: 4:30 AM

ADDRESS: \_\_\_\_\_

REQUESTED BY: \_\_\_\_\_

METER NUMBER: \_\_\_\_\_

ASSIGNED TO: \_\_\_\_\_

## WORK ORDER CODE &amp; DESCRIPTION:

Sensor Backing up again  
allon Bates - Ex. 6 (Personal Privacy)

Ex. 6 (Personal Privacy)

Sensor Backing up into  
Units - Same Problem Recently  
this side only  
Ex. 6 (Personal Privacy)

## INFORMATION FROM THE FIELD

METER TYPE: \_\_\_\_\_

NEW METER TYPE: \_\_\_\_\_

OLD METER #: \_\_\_\_\_

NEW METER #: \_\_\_\_\_

OLD METER READING: \_\_\_\_\_

NEW METER READING: \_\_\_\_\_

WORK DONE BY: BS km

DATE: 1-3-20

Comments: \_\_\_\_\_

DATE COMPLETED: 1-3-20

## FINAL BILL INFORMATION:

NAME: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

CITY/STATE/ZIP: \_\_\_\_\_

Jetted line  
ON BATES



COMMONFIELDS OF CAHOKIA  
UTILITY SERVICE ORDER

Service Order #: 1061665  
Scheduled Date: 02/05/2020  
Scheduled Time:

CUSTOMER INFORMATION

Customer No.: 12010 00  
Customer Name: Ex. 6 (Personal Privacy)  
Mailing Address: Ex. 6 (Personal Privacy)  
CAHOKIA, IL 62206-2302  
Service Address: Ex. 6 (Personal Privacy)

Description: SEWER BACKING UP  
Assigned To: FRANK  
Created By: felicia  
Meter Rte/Seq: Route:0 Sequence: 0

Special Instructions: SEWER BACKING UP IN TUB PER CUST

Completed Comments:

checked manholes behind Ex. 6 (Personal Privacy) our  
lines are down - Cust. Problem

READING INFORMATION

Description: SEWER BACKING UP  
METER MAKE:  
Meter Number:  
EMR ID:

Meter Size:  
Previous Read:  
Previous Read Date:  
Read:

Service Person

Reading

Date Completed

Job Start Time:

Job End Time:

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

**Ex. 6 (Personal Privacy)** BY OFFICE

NAME: \_\_\_\_\_

SERVICE ID: \_\_\_\_\_

ACCOUNT NO.: \_\_\_\_\_

SERVICE ID: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

METER NUMBER: \_\_\_\_\_

PHONE NO.: \_\_\_\_\_

ISSUE DATE: 11-2-00

PROCESS DATE: 11

PROCESS TIME: \_\_\_\_\_

REQUESTED BY: FELICIA

ASSIGNED TO: FRANK

WORK ORDER CODE & DESCRIPTION:

Cust~~a~~ Called from Granville, Said there is  
a hole in the road site passed driveway of  
it is in line w/ sewer. it seems as if the road is  
washing away into the sewer. He put a 2x4 into  
this hole so cars will not hit it.

INFORMATION FROM THE FIELD

METER TYPE: \_\_\_\_\_

OLD METER #: \_\_\_\_\_

OLD METER READING: \_\_\_\_\_

WORK DONE BY: \_\_\_\_\_

Comments: \_\_\_\_\_

NEW METER TYPE: \_\_\_\_\_

NEW METER #: \_\_\_\_\_

NEW METER READING: \_\_\_\_\_

DATE: \_\_\_\_\_

DATE COMPLETED: \_\_\_\_\_

FINAL BILL INFORMATION: \_\_\_\_\_

NAME: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

CITY/STATE/ZIP: \_\_\_\_\_

canworko.frx

WO Number

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

10653-63

**Ex. 6 (Personal Privacy)**

NAME:

SERVICE ID:

ACCOUNT NO.:

SERVICE ID:

ADDRESS:

METER NUMBER:

Reading Seq.

**Ex. 6 (Personal Privacy)**

Drexel DR

PHONE NO.:

ISSUE DATE:

PROCESS DATE:

PROCESS TIME:

REQUESTED BY:

ASSIGNED TO:

11-1-13-21

11

Felicia

Frank

WORK ORDER CODE & DESCRIPTION:

**Ex. 6 (Personal Privacy)**

Cust @

DR Called in Said

Sewer is backing up & odor is getting

Unbearable. House is Right of hers

This side only



INFORMATION FROM THE FIELD

METER TYPE:

OLD METER #:

OLD METER READING:

WORK DONE BY:

F.P.

NEW METER TYPE:

NEW METER #:

NEW METER READING:

DATE:

1-13-21

Comment:

**Ex. 6 (Personal Privacy)**

is Backed up & surcharging out  
of Clean out/lateral flooding Back yard. - our  
lines are down & flowing - Talked to cust. at

DATE COMPLETED:

**Ex. 6 (Personal Privacy)**

FINAL BILL INFORMATION:

NAME:

ADDRESS:

CITY/STATE/ZIP:

cahworko,lr



WO Number

1065518

CYCLE: \_\_\_\_\_ ROUTE # \_\_\_\_\_

INFORMATION ASSIGNED BY OFFICE

NAME:

Ex. 6 (Personal Privacy)

PHONE NO.:

SERVICE ID:

ISSUE DATE: 11

ACCOUNT NO.:

PROCESS DATE: 11

SERVICE ID:

ing Seq.

PROCESS TIME:

ADDRESS:

REQUESTED BY:

METER NUMBER:

S 54<sup>th</sup> St

ASSIGNED TO:

WORK ORDER CODE & DESCRIPTION:

Cost called to inform us sewer is  
backing up on S 54<sup>th</sup> St.

This sale only



INFORMATION FROM THE FIELD

METER TYPE:

NEW METER TYPE:

OLD METER #:

NEW METER #:

OLD METER READING:

NEW METER READING: N/A

WORK DONE BY:

KM, T.C, BS

DATE:

1-27-21

Comments:

Ex. 6 (Personal Privacy)

Pulled Pump, disassembled bypass  
Pump & reassembled after trash removal and replaced

DATE COMPLETED:

1-27-21

FINAL BILL INFORMATION:

NAME:

ADDRESS:

CITY/STATE/ZIP: