

Date 3-31-16

## Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W.O.
	LOCATES
	RE-READS
Jobs Completed	HAULED BUCKET OF C-M-G ROCK & FILLED IN ROAD WHERE VALVE WAS REPLACED AT ANGELO Ex. 6 (Personal Privacy)
Employees on Job F.P. - G.F. 4HR 4HR	
Vehicles or Equip. Used  2-11	

Sewer Department

Address	JETTED MAIN LINE & CLEANED & PUMPED MANHOLE WITH 3" PUMP TO TRY & RELIEVE BACKUP AT IN LATERAL Ex. 6 (Personal Privacy)
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT 7. Ex. 7f (Water Infra.) RILL BOX
Employees on Job F.P. J.H. 4HR	
Vehicles or Equip. Used  7-9	

Meter Readers

Employees on Job G.F. 4HR	FINISHED 142
Areas - Read	
Vehicles Used 11	

General Foreman Franky Price

Date 3-30-16

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address	SERVICE TRUCK W.O.
Jobs Completed	
Employees on Job G.F.	
Vehicles or Equip. Used 11	

**Sewer Department**

Address	PUMPED DOWN M.H. WITH 3" GAS PUMP JETTED & CLEANED LINE & VACUMED OUT M.H. ON CALVIN BLVD
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT <b>Ex. 7f (Water Infra.)</b> AMELIA
Employees on Job J.H. - F.P. 4HR	
Vehicles or Equip. Used 7-2-9	

**Meter Readers**

Employees on Job F.P. 4HR	FINISHED 16, 25, 27, 30
Areas - Read	STARTED 1
Vehicles Used 11	

General Foreman

Frank J. Pace



Date 3-29-16

Daily Job Sheet

Sheet 01**Water Department****Comments**

Address

SERVICE TRUCK W.O. - SHUT OFFS

Jobs Completed

CRIMPED OFF SERVICE LINE IN BOX &  
REPLACED SHUT OFF AT **Ex. 6 Personal Privacy**

Employees on Job

F.P. - B.S. - G.F.  
JHRDUG OUT BOX & EXPOSED LEAK AT BOTTOM  
OF BOX ON CUST. SIDE - IS ON METER SET &  
SERVICE NEEDS REBUILT AT **Ex. 6 (Personal Privacy)**

Vehicles or Equip. Used

11 - 14

**Sewer Department**

Address

Job Completed

BY-PASS PUMPED WITH 3" GAS PUMP AT  
**Ex. 7f (Water Infra.)** PILL BOX, JUDITH **Ex. 7f (Water Infra.)**

Employees on Job

J. H.  
GHR

Vehicles or Equip. Used

7

**Meter Readers**

Employees on Job

F.P. - B.S.  
GHRFINISHED  
29

Areas - Read

Vehicles Used

3

General Foreman

Frank J. Pace

Date 3-22-16

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address

SERVICE TRUCK W.D.

Jobs Completed

REBUILT SERVICE AT  
USED ONE  $\frac{1}{2}$ " X  $\frac{3}{4}$ " COMP. FITTING, ONE  $\frac{1}{2}$ " P.V.C. DIRECT  
BY-PASS FITTING, ONE METER SAUTOFF, ONE METER COUPLING,  
8' OF  $\frac{3}{4}$ " COPPER TUBING, ONE 18" X 30" P.V.C. METER BOX

Ex. 6 (Personal Privacy)

Employees on Job

F.P. - B.S. - G.F.  
GHRBACKFILLED WITH ONE BACKHOLE BUCKET OF SAND &  
SPOIL - RE-USED RING & LID

Vehicles or Equip. Used

11-14 - BACKHOLE

DUG UP SERVICE & CHECKED FOR LEAKS AT  
LEAK WAS ON CUST. LINE ABOUT  
10' FROM METER BOX - NOT OURS

Ex. 6 (Personal Privacy)

Sewer Department

Address

INSTALLED PUMP IN FIELD FROM RENOIS

Job Completed

BY-PASS PUMPED WITH 3" GAS PUMP AT  
PILL BOX,  
CALVIN BLVD.

Ex. 7f (Water Infra.)

Ex. 7f (Water Infra.)

Ex. 7f (Water Infra.)

Employees on Job

J.H. - F.P. - B.S.  
GHR

Vehicles or Equip. Used

7-14 - BACKHOLE

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace



Date 3-22-16

Daily Job Sheet

Sheet     of    **Water Department****Comments**

Address

SERVICE TRUCK W.O.

Jobs Completed

Employees on Job

B.S.

GHR

Vehicles or Equip. Used

11

**Sewer Department**

Address

JETTED &amp; CLEANED LINE 6 ON 55TH ST. &amp;

Ex. 6 Personal Privacy

Job Completed

Employees on Job

B.S. - J.H.

2142

Vehicles or Equip. Used

7-9

**Meter Readers**

Employees on Job

F.P.

FINISHED

23

Areas - Read

STARTED

24

Vehicles Used

General Foreman

Frank J. Pace

Date 3-25-16

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

**Water Department****Comments**

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

**Sewer Department**

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman Frank J. Pace

HOLIDAY

GOOD

FRIDAY



Date 3-24-16

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address	SERVICE TRUCK W.O.
	LOCATES
	READ PIT METERS
Jobs Completed	
Employees on Job F.P. - B.S. 6      3	
Vehicles or Equip. Used 2-11	

**Sewer Department**

Address	PULLED PUMP IN FIELD FROM RENOIS & TOOK TO IL-MO - JERRY CALLED & SAID HANK WEAVE WAS CAUGHT IN BEHIND GRINDER - READY TO BE PICKED UP MONDAY
	Job Completed BY-PASS PUMPED WITH 3" GAS PUMPS AT Ex. 7f (Water Infra.) MANHOLE IN FIELD FROM RENOIS Ex. 7f (Water Infra.)
Employees on Job J.H. - F.P. - B.S. 2	TURNED ON VOLT Ex. 7f (Water Infra.)
Vehicles or Equip. Used 7-14-BACKHOLE	

**Meter Readers**

Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman Frank J. Pace

Date 3-23-16

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address		SERVICE TRUCK W.O.
Jobs Completed		
Employees on Job B.S.		
Vehicles or Equip. Used 11		
Sewer Department		
Address		
Job Completed		BY-PASS PUMPED WITH 3" GAS PUMP AT 30K, <b>Ex. 7f (Water Infra.)</b>
Employees on Job J.H.		CYCLED STATIONS AT 73RD, OAKLAND TURNED ON PUMP AT <b>Ex. 7f (Water Infra.)</b> BETWEEN
Vehicles or Equip. Used 7		
Meter Readers		
Employees on Job F.P.		FINISHED 22-24-26
Areas - Read		LOCATES
Vehicles Used 2		
General Foreman		Frank J. Pace



Date 3-21-16

Daily Job Sheet

Sheet     of    **Water Department****Comments**

Address

REPLACED VALVE # 3-2-15 AT ANGLOP  
Ex. 6 (Personal Privacy) USED TWO SOI DRESSERS,  
ONE 2" GATE VALVE, 44" OF 50R 21-2" P.V.C. PIPE  
ONE NEW VALVE BOX - BACKFILLED WITH ROCK

Jobs Completed

REPAIRED DRIVEWAY ON JULIEN WHERE  
MAIN BREAK WAS REPAIRED WITH ONE BUCKET  
OF ROCK

Employees on Job

F.P. - B.S.

Vehicles or Equip. Used

14 - BACKHOLE

**Sewer Department**

Address

Job Completed

BX-BASS PUMPED WITH 3" GAS PUMP AT  
Ex. 7f (Water Infra.) PILL BOX,

Employees on Job

J.H.  
GHR

Vehicles or Equip. Used

7

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman Frank J. Pace

Sheet 1 of 1

Water Department		Comments	
Address			
Jobs Completed			
Employees on Job			
Vehicles or Equip. Used			
Sewer Department			
Address		By PASS Pump AND violet	
Job Completed			
Employees on Job			
Vehicles or Equip. Used			
Meter Readers			
Employees on Job		READ AREA #19 STARTED #22	
Areas - Read			
Vehicles Used			
General Foreman			



Date 3-17-16

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT  
Ex. 7f (Water Infra.) PILL BOX  
CALVIN BLVD.

Job Completed

REPAIRED SEWER MAIN & LATERAL  
LAKE DR. - USED ONE 8" CONCRETE 8" P.V.C.  
PERNCO, 9' OF SCH. 35 SEWER PIPE P.V.C., ONE  
BUCKET OF QUICK PLUG HYDROLIC CEMENT

Employees on Job

J.H. - F.P. - B.S.

ONE 8" X 6" TAPPING SADDLE, ONE 6" X 4" REDUCER  
4" X 4" P.V.C. RISER, ONE 45° 4" FITTING, 11' OF 4"  
SCH. 35 P.V.C. SEWER PIPE, ONE 4" X 4" PERNCO  
MAP ON WORK ORDER

Vehicles or Equip. Used

7-14-BACKHOE

Meter Readers

Employees on Job

G.F.  
6 HRFINISHED  
20921

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 3-14-16

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

SERVICE TRUCK W.O.

Jobs Completed

Employees on Job

① G.F.  
5 HR

Vehicles or Equip. Used

11**Sewer Department**

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT**Ex. 7f (Water Infra.)** Box

Job Completed

EXPOSED LATERAL FOR  
FOUND HOLE IN SEWER MAIN WHERE TAP WAS,  
EXPOSED MAIN FROM M.H. OUT 14' TO GOOD PIPE  
CLEANED & CUT OUT MAIN IN PREP FOR TOMORROW**Ex. 6 (Personal Privacy)**

Employees on Job

J.H. - F.P. - B.S8" MAIN 10.40 O.D.

Vehicles or Equip. Used

7-14-BACKHOE

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 3-15-16

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

SERVICE TRUCK W.O. / SHUT OFFS

Jobs Completed

REPLACED SERVICE LINE UNDER ROAD AT  
**Ex. 6 (Personal Privacy)** USED ONE  $\frac{3}{4}$ " FLARE BY  $\frac{3}{4}$ " COMP.  
ONE  $\frac{3}{4}$ " X  $\frac{3}{4}$ " COMP., ONE METER SHUT OFF, ONE METER COUPLING  
50' OF  $\frac{3}{4}$ " COPPER TUBING, ONE 18" X 30" CLAY TILE

Employees on Job

F.P. - B.S. - G.P.

Vehicles or Equip. Used

11-14-BACKHOLE

**Sewer Department**

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace



Date 3-14-10

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address		SERVICE TRUCK W.O. / SHUT OFFS
Jobs Completed		REPAIRED SERVICE LEAK AT <span style="background-color: black; color: red;">Ex. 6 Personal Privacy</span> USED TWO 3/4" P.V.C BARBX 3/4" COMP. FITTINGS, AND 2' OF 3/4" COPPER TUBING, BACKFILLED ROAD WITH ROCK FROM SHOP-HAULED SPOIL TO SHOP
Employees on Job F.P.-B.S.-G.F. 7 PRR		EXPOSED 4" C.T. MAIN & SERVICE TAP FOR <span style="background-color: black; color: red;">Ex. 6 (Personal Privacy)</span> IN PREP FOR PULL JOB
Vehicles or Equip. Used 2-14-11-BACKHOE		
<hr/>		
Sewer Department		
Address		REMOVED OLD CHECK VALVE + INSTALLED PLATE & GASKET ON GATE VALVE AT LAURALEE STATION
Job Completed		BY-PASS PUMPED WITH 3" GAS PUMP AT <span style="background-color: black; color: red;">Ex. 7f (Water Infra.)</span> PILL BOX, <span style="background-color: black; color: red;">Ex. 7f (Water Infra.)</span>
Employees on Job J.H. F.P.-B.S., 1 PRR		
Vehicles or Equip. Used 7-14		
<hr/>		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		

Date 3-11-16

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

Water Department

## Comments

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

Sewer Department

Address

2 HR OVERTIME

Job Completed

JETTED LINE BETWEEN  
& LAURA LEE TO RELIEVE BACKUP

Ex. 6 (Personal Privacy)

Employees on Job

J.H. - G.F.

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman Frank J. Pace

Date 7-11-16

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address

SERVICE TRUCK W.O.

Jobs Completed

EXPOSED 4" C.I. MAIN IN FRONT OF  
LORRAINE & LOOKED FOR LEAK - EXPOSED  
MAIN FROM DRIVEWAY TO DRIVEWAY & DIDNT FIND  
LEAK

Ex. 6 (Personal Privacy)

Employees on Job

F.P. - G.F. - B.S.

Vehicles or Equip. Used

BOTH  
74-11- BACKHOESSewer Department

Address

Job Completed

BY-PASS PUMPED WITH 3" GAS PUMP AT  
PILL BOX,

Ex. 6 Personal Privacy

Ex. 6 (Personal Privacy)

Employees on Job

J.H.

Vehicles or Equip. Used

7-9

JETTED LINE BETWEEN  
LAURALEE TO RELIEVE BACKUP

Ex. 6 (Personal Privacy)

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace



Water Department		Comments
Address		SERVICE TRUCK W/O. INSTALLED REPAIR KIT ON HYDRANT IN FRONT OF [REDACTED] ON NOW
Jobs Completed		REPAIRED SERVICE LEAK AT [REDACTED] USED ONE 3/4" FLARE X 3/4" COMP. FITTING, ONE 3/4" COMP X 3/4" P.I.C. BARB FITTING & 3' OF COPPER TUBING. BACKFILLED WITH SPOIL
Employees on Job		
F.P. - B.S. - G.F. GMR GMR GMR		
Vehicles or Equip. Used		
11-14-BACKHOE		

Sewer Department		
Address		INSTALLING & WIRED UP PUMP AT [REDACTED] WELL WAS DOWN AT END OF DAY
Job Completed		BY-PASS PUMPED WITH 3" GAS PUMP AT [REDACTED] EONA
Employees on Job		JETTED LINE TO RELIEVE BACKUP AT [REDACTED]
J.H. - F.P. - B.S. - G.F. 2 PER		
Vehicles or Equip. Used		
11-7-14-BACKHOE		

Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		

General Foreman Frank J. Pace

Date 3-9-14

Daily Job Sheet

Sheet      of     

**Water Department**

**Comments**

Address	SERVIC TRUCK W.O.
Jobs Completed	
Employees on Job B.S.	
Vehicles or Equip. Used 11	

**Sewer Department**

Address	JETTED LINE BEHIND STERLING
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT CALVIN BLVD. & <span style="background-color: black; color: red;">Ex. 7f (Water Infra.)</span>
Employees on Job J.H.	
Vehicles or Equip. Used 7	

**Meter Readers**

Employees on Job F.P. - G.F.	FINISHED 13414 - F.P.      17418 - G.F.
Areas - Read	
Vehicles Used 2-3	

General Foreman Frank J. Pace



Date 3-8-16

Daily Job Sheet

Sheet     of    **Water Department****Comments**

Address

SERVICE TRUCK W/O.

Jobs Completed

Employees on Job

B.S.  
4 HR

Vehicles or Equip. Used

11

**Sewer Department**

Address

WORKED ON SNOWS STATION  
PUMPED WRT WELL AT LAURALIE ON HAND  
PUMPED WELLS AT 73RD & AT OAKLAND ON HAND

Job Completed

BY-PASS PUMPED WITH 3" GAS PUMP AT  
ELL BOX,**Ex. 7f (Water Infra.)**

Employees on Job

J.H. - B.S.  
2 HR

Vehicles or Equip. Used

7-14

**Meter Readers**

Employees on Job

F.P. - G.F.

FINISHED  
F.P.  
11-12-15 G.F.

Areas - Read

STARTED  
17 G.F. 13-F.P.

Vehicles Used

General Foreman

Frank J. Pace



Date 3-7-16

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

**Water Department****Comments**

Address

SERVICE TRUCK W/O.

Jobs Completed

Employees on Job

F.P. - G.F.  
4 HR 2 HR

Vehicles or Equip. Used

11-2

**Sewer Department**

Address

VACUMED NET WELL & GOT ONE PUMP  
PUMPING AT SNOWS STATION

Job Completed

BY-PASS PUMPED WITH 3" GAS PUMP AT  
Ex. 7f (Water Infra.) PILL BOX

Employees on Job

F.P. - B.S.  
2 HR

Vehicles or Equip. Used

2-7-9

**Meter Readers**

Employees on Job

F.P. - G.F.  
2 HR 6 HRFINISHED  
5-F.P. & 9-G.F.

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 3-4-16

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		<u>Comments</u>
Address	SERVICE TRUCK W.O.	
Jobs Completed		
Employees on Job B.S. DNR		
Vehicles or Equip. Used 11		
<u>Sewer Department</u>		
Address		
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT <b>Ex. 7f (Water Infra.)</b> RILL BOX,	
Employees on Job J.H. B.S. 4 NR 2 NR		
Vehicles or Equip. Used		
<u>Meter Readers</u>		
Employees on Job F.R. - G.F.	FINISHED 4-F.P. - 7-8-G.F.	
Areas - Read	STARTED 5-F.P.	
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		

Water Department		Comments
Address		
Jobs Completed		
Employees on Job		
Vehicles or Equip. Used		
Sewer Department		
Address		
Job Completed		
Employees on Job	Ex. 6 (Personal Privacy) <i>ected line</i>	
<i>J. H</i>	<i>WORKED ON FLOAT BALL AT SUPERIOR</i>	
Vehicles or Equip. Used		
<i>7-14</i>		
Meter Readers		
Employees on Job		
<i>BS-GF</i>		
Areas - Read	<i>STARTED + FINISHED 3.6 + 10</i>	
<i>3.4.6.10</i>	<i>STARTED #4</i>	
Vehicles Used	<i>3-14</i>	
General Foreman		<i>B. J. J. J.</i>



Water Department	Comments
Address	Service TRUCK work orders Read meters
Jobs Completed	
Employees on Job GF 8 HRS BS 6 HRS	
Vehicles or Equip. Used	

Sewer Department	
Address	
Job Completed	
Employees on Job JH 8 HRS BS 2 HRS	BS checked some STATIONS & Pulled #2 MOTOR AT SNOWS JH - Pumped Ex. 7f (Water Infra.)
Vehicles or Equip. Used #7 - #14	

Meter Readers	
Employees on Job BS 4 HRS	
Areas - Read 25-27-16-30	STARTED + FINISHED ALL 4 AREAS
Vehicles Used #3	
General Foreman	B. Hunt

Date 3-1-16

Daily Job Sheet

Sheet 1 of 1

Water Department		Comments
Address		Service TRUCK WORK ORDERS
Jobs Completed		
Employees on Job GF 8 HRS BS 2 HRS		
Vehicles or Equip. Used #11 #3		
Sewer Department		
Address		By PASSED CALVIN BLVD 71ST ST- LAURALEE wet well
Job Completed		
Employees on Job JH		
Vehicles or Equip. Used #7		
Meter Readers		
Employees on Job BS 6 HRS		
Areas - Read #1 #2		STARTED & FINISHED 1 + 2
Vehicles Used #3		
General Foreman		B. [Signature]

Water Department		Comments
Address		Service TRUCK 4 HRS Doing WORK orders
Jobs Completed		
Employees on Job		
Vehicles or Equip. Used # 11		
Sewer Department		
Address		By PASSECK, Pumped 71st + Pill Box excised 73rd + 73rd Pulled RACS from BRIDGE AVE Ex. 7f (Water Infra.)
Job Completed		
Employees on Job JH		
Vehicles or Equip. Used #7		
Meter Readers		
Employees on Job GF 8 HRS BS 4 HRS		
Areas - Read FINISHED 4 + 7 STATED 5 + 8		
Vehicles Used #3 - #11		
General Foreman B. Smith		



Water Department		Comments
Address		Service TRUCK 5 HRS
Jobs Completed		
Employees on Job BS		
Vehicles or Equip. Used #2		
Sewer Department		
Address		
Job Completed		By PASSED TEHH Ex. 7f (Water Infra.) Ex. 7f (Water Infra.) pulled RAGS from Bridge Ave Twice
Employees on Job JH		
Vehicles or Equip. Used 7		
Meter Readers		
Employees on Job BS- GF		
Areas - Read #3 started #4 #7 started #10		
Vehicles Used 2-11		
General Foreman B. Smith		

<u>Water Department</u>	
Address	SERVICE TRUCK 8 HRS
Jobs Completed	SPREAD ROCK AT <b>Ex. 6 (Personal Privacy)</b>
Employees on Job BS	
Vehicles or Equip. Used #2 BACK HOE	

<u>Sewer Department</u>	
Address	
Job Completed	BY PASSED JUDITH 73RD & PILL BOX CYCLED 73RD - <b>Ex. 7f (Water Infra.)</b>
Employees on Job JH	
Vehicles or Equip. Used #7	

<u>Meter Readers</u>	
Employees on Job GF	
Areas - Read 16 25 27 STARTED 30	
Vehicles Used #11	

General Foreman
-----------------

Date 4-26-16

Daily Job Sheet

Sheet 1 of 1

<u>Water Department</u>		Comments
Address	WORK ORDERS FOR 2 HRS	
Jobs Completed		
Employees on Job GF		
Vehicles or Equip. Used 11		
<u>Sewer Department</u>		
Address		
Job Completed	Jettered LINE for customer Removed & Replaced 2 HP motor for Bridgeline - Pumped 75TH-cycled PERSHING - TURNED ON 73rd	
Employees on Job JH- BS	Ex. 7f (Water Infra.)	
Vehicles or Equip. Used 14- 7- VAC TRUCK		
Meter Readers		
Employees on Job GF		
Areas - Read 1 & 2		
Vehicles Used 11		
General Foreman	B. Smith	



Date 4-25-16

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address		
Jobs Completed		
Employees on Job		
Vehicles or Equip. Used		
<u>Sewer Department</u>		
Address		removed pumps at 73 RD - 73 RD Ex. 7f (Water Infra.) Pumped 71 <sup>ST</sup> PILL BOX - JUDITH AND INSTALLED PUMP IN FIELD FOR RENDIS LN.
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
Meter Readers		
Employees on Job		
Areas - Read		FINISHED 29
Vehicles Used		11
General Foreman		B. Smith

Water Department		Comments
Address		SERVICE TRUCK W.O.
Jobs Completed		
Employees on Job G.F.		
Vehicles or Equip. Used 11		

Sewer Department		
Address		PULLED BOTH PUMPS & CLEANED OUT RAGS Ex. 7f (Water Infra.) - VACUMED WELL - RE-SET PUMPS & TRANSDUCER - PUMPING NOW
Job Completed		PULLED BACK OFF PUMP & CLEANED OUT RAGS AT BRIDGEDALE - PUMPING NOW
Employees on Job F.P. - J.H. - B.S.		
Vehicles or Equip. Used BACKHOLE 2-14-7-9-6" PUMP		

Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		

General Foreman	Frank J. Price
-----------------	----------------

Date 4-22-14

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

Water Department

## Comments

Address

 $\frac{1}{2}$  Hour O.T. LUNCH HOUR

Jobs Completed

Employees on Job

Vehicles or Equip. Used

Sewer Department

Address

Job Completed

Employees on Job

F.P. - J.H. - B.S.

PULLED PUMPS & CLEANED RAGS OUT,  
VACUMED WELL & RESET PUMPS AT  
Ex. 7f (Water Infra.)

Vehicles or Equip. Used

6" PUMP  
7-14-9-BACKHOC

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace



Water Department		Comments
Address		SERVICE TRUCK W.O.
Jobs Completed		
Employees on Job F.P. GHR		
Vehicles or Equip. Used  11		
Sewer Department		
Address		CHECKED STATIONS - NEED TO CLEAN OUT PUMP AT BRIDGE DALE CYCLED PUMPS AT OAKLAND Ex. 7f (Water Infra.)
Job Completed		BY-PASS PUMPED WITH BOTH 3" PUMPS AT Ex. 7f (Water Infra.)
Employees on Job J.H. - B.S. - F.P. 2 HR		TRIED TO PULL PUMPS AT Ex. 7f (Water Infra.)
Vehicles or Equip. Used  7-14-9 - BACKHOE		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Franky Pace</u>		

Water Department		Comments
Address		SERVICE TRUCK W.O. / SHUT OFFS
Jobs Completed		
Employees on Job G.F. F.P. 2 HR		
Vehicles or Equip. Used 2x11		
Sewer Department		
Address		CLEANED OUT RAGS FROM PUMP IN FIELD FROM RENOIS IN SHOP - NEED TO INSTALL IN M.H. BY-PASS PUMPED WITH 3" GAS PUMP AT
Job Completed		CHECKED STATIONS ON SOUTH SIDE - 53RD DOWN NOT PUMPING - BRIDGE DALE NOT PUMPING & PUMPING HALF PIPE
Employees on Job J.H. - B.S. - F.P. 2 HR		PULLED BACKS OFF PUMPS & CLEANED OUT RAGS AT BRIDGE DALE & CENTREVILLE PUMPING NOW
Vehicles or Equip. Used 7-14-3-BACKHOLE		
Meter Readers		
Employees on Job F.P. 2 HR		STARTED 29 F.P.
Areas - Read		
Vehicles Used		
General Foreman <u>Franky Pace</u>		

Date 4-19-16

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

SERVICE TRUCK W.O.  
RE-READS

Jobs Completed

HOOKED UP NEW P.V.C. WATER SERVICE  
LINK TO BACKSIDE. - USED ONE 3/4" COAPX  
3/4" P.V.C. BARB FITTING

Employees on Job

F.P. G.F. B.S.  
W. G.S. 2.5 HR  
2 HR

Vehicles or Equip. Used

2-0-14-11-BACKHOE

**Sewer Department**

Address

TURNED ON PUMPS AT BLUFF  
CYCLED PUMPS AT OAKLAND

Ex. 7f (Water Infra.)

Ex. 7f (Water Infra.)

Job Completed

INSTALLED STARTERS AT SNOWS STATION  
POOLED PUMP FROM M. H. IN FIELD FOR RENOIS  
TOOK TO SHOP - BY-PASS PUMPED FOR HOUR

Employees on Job

B.S. G.F. J.H.  
5.5 HR 1.5 HR

Vehicles or Equip. Used

7-14-BACKHOE

Meter Readers

Employees on Job

F.P.  
6 HRFINISHED  
24 x 26

Areas - Read

Vehicles Used

3 &amp; 2

General Foreman

Frank J. Pace



Date 4-18-16

Daily Job Sheet

Sheet     of    

Water Department		Comments
Address	SERVICE TRUCK W.O. / RE-READS	
Jobs Completed		
Employees on Job G.F. 4 NR		
Vehicles or Equip. Used 11		
Sewer Department		
Address	CHANGED OIL IN 3" GAS PUMP	
Job Completed	BY-PASS PUMPED WITH 2" GAS PUMP AT WELL BOX Ex. 7f (Water Infra.) Ex. 7f (Water Infra.) Ex. 7f (Water Infra.)	
Employees on Job B.S.	PUMP IN FIELD FROM RENOSIS NOT PUMPING NEEDS PULLED	
Vehicles or Equip. Used 7	LATE W.O. ABOUT SEWER BACKING UP + RUNNING IN DITCH ON BOTH ST.	
Meter Readers		
Employees on Job F.P. - G.F. 4 NR	FINISHED 18-G.F. F.P. 23-F.P.	
Areas - Read	STARTED 24-F.P.	
Vehicles Used 3		
General Foreman <u>Franky Pace</u>		

Date 4-14-16

## Daily Job Sheet

Sheet      of     

<u>Water Department</u>	
Comments	
Address	SERVICE TRUCK W/O RE-READS
Jobs Completed	REPAIRED PULL CABLE
Employees on Job F.P. - B.S. 2 HR	
Vehicles or Equip. Used 2-11	

<u>Sewer Department</u>	
Address	REPLACED DISCHARGE HOSE ON PUMP IN M.H. ON BLOCKHOUSE LINE FROM GROUTED IN 3" TARRASSED P.V.C. THROUGH 14" & HOOKED UP TO HARDWALL P.V.C. DISCHARGE Ex. 6 (Personal Privacy)
Job Completed	LINE - USED 55' OF SCH. 35 P.V.C., ONE 3"x4" REDUCER, ONE 3" TO 4" SHIM, ONE 4"x4" COUPLING BACKFILLED AROUND MANHOLE
Employees on Job J.H. - E.P. - B.S. 6 HR	RY-PASS PUMPED WITH 3" GAS PUMP AT PILE BOX Ex. 7f (Water Infra.) Ex. 7f (Water Infra.)
Vehicles or Equip. Used 7-14- BACKHOL	ADJUSTED FLOAT BALLS & HUNG SENSOR WIRES ON CHAIN AT LAURALIE WET WELL

Meter Readers	
Employees on Job C.F.	FINISHED 20421
Areas - Read	
Vehicles Used 3	
General Foreman	Frank J. Pace



Date 4-13-14

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed	GRADED ROCK IN ROAD WHERE MAIN WAS REPAIRED AT <b>Ex. 6 (Personal Privacy)</b>	
Employees on Job <u>F.P. - B.S.</u> 2 HR		
Vehicles or Equip. Used  14-2-11-BACKHOE		
<b>Sewer Department</b>		
Address	W. J. T. T. D. FOR CITY OF CENTREVILLE AT <b>Ex. 6 (Personal Privacy)</b> & VACUUMED M.H.	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT JUDITH <b>Ex. 7f (Water Infra.)</b>	
Employees on Job <u>B.S. - F.P.</u> J.H. 6 HR 6 HR	PUMPED DOWN M.H. IN FIELD FROM RENOIS & PULLED PUMP - RE INSTALLED PUMP IN MANHOLE AFTER 12-MO CLEANED IT OUT	
Vehicles or Equip. Used  14-9-7-BACKHOE	SET FLOAT BALLS IN WET WIRE AT VIOLAT <b>Ex. 6 (Personal Privacy)</b>	
<b>Meter Readers</b>		
Employees on Job  G.F 7HR	FINISHED 14418	
Areas - Read		
Vehicles Used  3		
General Foreman	<u>Frank Pace</u>	



Date 4-12-14

## Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O. - SHUT OFFS	
Jobs Completed	RE-READS / LOCATES	
Employees on Job F.P. - B.S.		
Vehicles or Equip. Used		
<u>Sewer Department</u>		
Address		
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT Ex. 7f (Water Infra.) RILEY BOX	
Employees on Job J.H. B.S. 4MR 2MR	WIRED FLOATBALLS IN AT LAURALAKE WET WALL	
Vehicles or Equip. Used 7-14		
Meter Readers		
Employees on Job G.F.	FINISHED 13 PIT MATHES	
Areas - Read	STARTED 14	
Vehicles Used 3		
General Foreman	<u>Franky Pace</u>	

Water Department		Comments
Address		SERVICE TRUCK W.O., - A.B. SHOT OFFS
Jobs Completed		
Employees on Job F.P. - G.F. 4 HR 3 HR		
Vehicles or Equip. Used 11-3		
Sewer Department		
Address		
Job Completed		BY-PASS PUMPED WITH 3" GAS PUMP AT Ex. 7f (Water Infra.) PILE BOX
Employees on Job J.H.		CYCLED PUMPS AT OAKLAND, CAVALIER WET WELL Ex. 7f (Water Infra.)
Vehicles or Equip. Used 2		
Meter Readers		
Employees on Job B.S. - G.F. LMR		FINISHED 15+17-B.S. 11-G.F.
Areas - Read		
Vehicles Used 2-3		
General Foreman <u>Frank J. Pace</u>		

Date 4-8-16

Daily Job Sheet

Sheet 1 of 1Water Department

## Comments

Address

Service TRUCK w/o's

Jobs Completed

HAULED OFF DIRT from

Ex. 6 Personal Privacy

Employees on Job

BS-JH 4HRS

Vehicles or Equip. Used

BACK HOE  
DUMP TRUCKSewer Department

Address

Job Completed

BY PASSED 7151 JUDITH  
+ Ex. 7f (Water Infra.)

Employees on Job

J.H

Vehicles or Equip. Used

# 7

Meter Readers

Employees on Job

BS-GF

STARTED + FINISHED 6-12  
STARTED 15

Areas - Read

Vehicles Used

3-11

General Foreman





Date 4-15-16

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address	SERVICE TRUCK W.O. RE-ROADS	
Jobs Completed	EXPOSED 4" C.I. MAIN, TWO SADDLES, ONE TAPPING SLAVE, ONE CAP LOOKING FOR LEAK - DID NOT FIND LEAK AT <b>Ex. 6 (Personal Privacy)</b>	
Employees on Job	G.F. - F.P. B.S. 1.5 hrs 6 hrs	
Vehicles or Equip. Used	11-14-BACKHOE	
<b>Sewer Department</b>		
Address	WORKED ON FLOATBALLS AT SNOWS	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT <b>Ex. 7f (Water Infra.)</b> PILL BOX,	
Employees on Job	CYCLED PUMPS AT OAKLAND <b>Ex. 7f (Water Infra.)</b>	
J.H. - F.P. - B.S. 2 hrs		
Vehicles or Equip. Used	7-14	
Meter Readers		
Employees on Job	G.F. FINISHED 6.5 hrs 22	
Areas - Read		
Vehicles Used	3	
General Foreman <u>Franky - dace</u>		

Water Department		Comments
Address		SERVICE TRUCK W.O. - SAUT OFFS
Jobs Completed		BROKE CONCRETE PATCH OUT ON RANGELANE IN FRONT OF [REDACTED] FOR VILLAGE OF CAHOKIA
Employees on Job B.S. - G.F. JMR		SPREAD ROCK IN ROAD WHERE MAIN BREAK WAS REPAIRED AT [REDACTED]
Vehicles or Equip. Used 3-11 - BACKHOE BREAKER		
Sewer Department		
Address		
Job Completed		BY-PASS PUMPED WITH 3" GAS PUMP AT PILL BOX, JUDITH
Employees on Job J. H.		CYCLED PUMPS AT OAKLAND, 73RD ST., LAURA LEE WET WELL
Vehicles or Equip. Used 7		
Meter Readers		
Employees on Job F.P. - G.F. GMR		FINISHED 5-G.F. - 9-P.P.
Areas - Read		STARTED 6-G.F.
Vehicles Used 2-3		
General Foreman <u>Frank J. [Signature]</u>		



Date 4-6-14

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address		SERVICE TRUCK W.O.
Jobs Completed		HAVLED IN DIRT GRADED SEEDD & STRAWED YARDS WHERE REPAIRS WERE MADE Ex. 6 (Personal Privacy) SANDY RIDGE
Employees on Job F.P. - B.S. 4HR 6HR		
Vehicles or Equip. Used 14-11-BACKHOLE		

Sewer Department		
Address		EXPOSED MANHOLE TO JET LINE BETWEEN MARYLAND Ex. 7f (Water Infra.)
Job Completed		JETTED LINE TO RELIEVE BACKUP AT Ex. 6 (Personal Privacy)
Employees on Job J.H. - B.S. - G.F. 3HR 1HR		CYCLED PUMPS AT LAUREL WET WELL OAKLAND Ex. 7f (Water Infra.)
Vehicles or Equip. Used 3-7-9-14		

Meter Readers		
Employees on Job G.F. F.P. 7 4		FINISHED 4-G.F. 8-F.P.
Areas - Read		STARTED 5-G.F.
Vehicles Used 2-3		
General Foreman <u>Frank J. Pace</u>		



Date 4-5-16

Daily Job Sheet

Sheet     of    **Water Department****Comments**

Address

SERVICE TRUCK W.O. - INSTALLS

Jobs Completed

Employees on Job

G.F.  
1 HR

Vehicles or Equip. Used

11

**Sewer Department**

Address

EXPOSED 6" CLAY LATERAL NEAR ROAD, CUT  
OUT 60" OF LATERAL, JETTED LATERAL TO CLEAR  
BLOCK, INSTALLED 6" CLEAN OUT IN LATERAL

Job Completed

Ex. 6 (Personal Privacy)

USED ONE 6"X6"X6" TEE SWEEP, TWO  
6" CLAYX6" P.V.C. FERNOS, 92" OF 6" SCH 35  
P.V.C. PIPE & ONE 6" SCH 35 CAP AT

Ex. 6 (Personal Privacy)

Employees on Job

F.P. - J.H. - G.F.  
7HRBY-PASS PUMPED WITH 3" GAS PUMP AT  
CALVIN BLVD.

Vehicles or Equip. Used

2-14-7-9-BACKHOLE

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank P. Pace

Date 4-4-16

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

SERVICE TRUCK W.O. - INSTALLS

Jobs Completed

Employees on Job

G.F.  
1 HR

Vehicles or Equip. Used

11

**Sewer Department**

Address

CYCLED 73RD Ex. 6 (Personal Privacy) OAKLAND

Job Completed

BY-PASS PUMPED WITH 3" GAS PUMP AT  
Ex. 7f (Water Infra.) WELL BOX

Employees on Job

J. H.

BLUFF IS UP &amp; RUNNING

Vehicles or Equip. Used

7

**Meter Readers**

Employees on Job

F.P. G.F.  
7 HR

FINISHED

3-G.F. 7-10-F.P.

Areas - Read

STARTED

4-G.F. 8-F.P.

Vehicles Used

2-11

General Foreman

Frank J. Pace

Date 4-1-16

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

SERVICE TRUCK W/O.

Jobs Completed

Employees on Job

G.F.  
4HR

Vehicles or Equip. Used

11

**Sewer Department**

Address

CHECKED STATIONS

PUT UP FENCING AROUND HOLE WHERE SEWER  
COLLAPSED AT **Ex. 6 (Personal Privacy)**

Job Completed

DUG TO FIND LATERAL AT ROAD TO RELIEVE  
BACKUP AT **Ex. 6 (Personal Privacy)**  
FIND- HUNTER COULDN'T GET THROUGH WITH  
SNAKE - WENT IN 100'

Employees on Job

J.H.-F.P. - G.F.  
4HR

BY-PASS PUMPED WITH 3" GAS PUMP AT

**Ex. 7f (Water Infra.)** PILL BOX **Ex. 7f (Water Infra.)**

Vehicles or Equip. Used

7-14- BACKHOLE

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace



Date 5-31-16

Daily Job Sheet

Sheet      of     

**Water Department**

**Comments**

Address

SERVICE TRUCK W/O.

Jobs Completed

Employees on Job

G.F.

Vehicles or Equip. Used

11

**Sewer Department**

Address

Job Completed

BY-PASS PUMPED WITH 3" GAS PUMP AT BOX

**Ex. 7f (Water Infra.)**

Employees on Job

B.S.

CYCLED PUMP AT

**Ex. 6 (Personal Privacy)**

CYCLED BLOWERS AT OAKLAND AND AT

**Ex. 7f (Water Infra.)**

Vehicles or Equip. Used

3

PUMP IN FIELD FROM RENOIS IS OUT  
SNOWS IS OUT

Meter Readers

Employees on Job

F.P. - T.C.

FINISHED

344 - T.C.

7410 - F.P.

Areas - Read

STARTED

5 - T.C.

Vehicles Used

8-14

General Foreman

Frank J. Pace

Date 5-27-16

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

SERVICE TRUCK W.O.

Jobs Completed

Employees on Job

F.P.  
2-3  
NRZ

Vehicles or Equip. Used

8

**Sewer Department**

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT  
Ex. 7f (Water Infra.)  
Ex. 7f (Water Infra.)

Job Completed

CYCLED PUMP AT Ex. 6 Personal Privacy IN THE  
MORNING & THE AFTERNOON

Employees on Job

G.F.

CYCLED BLOWERS AT OAKLAND AND AT  
Ex. 7f (Water Infra.) IN THE MORNING AND  
IN THE AFTERNOON

Vehicles or Equip. Used

3

**Meter Readers**

Employees on Job

F.P.  
5-10 HRSSTARTED  
AREA 3

Areas - Read

Vehicles Used

8

General Foreman

Frank J. Pare

Date 5-30-16

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

**Water Department****Comments**

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

**Sewer Department**

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Rane

H

OL

1 DAY

ME

MORIAL

DAY



Date 5-26-16

Daily Job Sheet

Sheet      of     

<u>Water Department</u>	
Comments	
Address	SERVICE TRUCK W.O. / LOCATES LOCATED & EXPOSED BURIED METER BOXES
Jobs Completed	INSTALLED CHLORINATING LINE AT FALLING SPRINGS TANK - REMOVED OLD LINE
Employees on Job F.P. - B.S. - G.F. 2 HR	INSTALLED MOTOR MOUNT / SHOCK ABSORBERS ON 3" PUMP
Vehicles or Equip. Used 11-14 - BACKHOE	

<u>Sewer Department</u>	
Address	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT Ex. 7f (Water Infra.) PILL BOX & CALVIN-BLV.
Employees on Job G.F. 6 HR	CYCLED PUMP AT Ex. 6 (Personal Privacy) CYCLED BLOWERS AT OAKLAND TA Ex. 7f (Water Infra.)
Vehicles or Equip. Used 3	

Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	
General Foreman	<u>Frank J. Rice</u>

Water Department		Comments
Address		SERVICE TRUCK W/O. LOCATES
Jobs Completed		
Employees on Job F.P. - G.F. 2HR		
Vehicles or Equip. Used 8-11		
Sewer Department		
Address		
Job Completed		BY-PASS PUMPED WITH 3" GAS PUMP AT MILL BOX
Employees on Job B.S.		Ex. 7f (Water Infra.)
Vehicles or Equip. Used 3		
Meter Readers		
Employees on Job F.P. 6HR		FINISHED 16, 25, 27, 30
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		

Date 5-24-16

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

SERVICE TRUCK W.O. - SHUT OFFS

Jobs Completed

REBUILT SERVICE AT **Ex. 6 (Personal Privacy)**  
USED ONE  $\frac{3}{4}$ " $\times$  $\frac{3}{4}$ " COMP. FITTING, ONE  $\frac{3}{4}$ " P.V.C. GARB  
 $\times$   $\frac{3}{4}$ " COMP. FITTING, 8' OF  $\frac{3}{4}$ " COPPER TUBING, ONE  
METER SHUT OFF, ONE 18"  $\times$  30" P.V.C. METER BOX -

Employees on Job

F.P. - B.S. - G.F.  
5.5 HRLEFT BACKSIDE OFF DUE TO TAMPERING - NEED  
TO INSTALL BACKSIDE WHEN METER IS  
INSTALLED

Vehicles or Equip. Used

14-11 - BACKHOE

**Sewer Department**

Address

Job Completed

BY-PASS PUMPED WITH 3" GAS PUMP AT  
82ND ST, **Ex. 6 (Personal Privacy)**

Employees on Job

J.H.  
4 HR

Vehicles or Equip. Used

7

Meter Readers

Employees on Job

G.F. 2.5 HR

STARTED  
16

Areas - Read

Vehicles Used

3

General Foreman

Frank J. Pace



Water Department		Comments
Address		SERVICE TRUCK W.O. LOCATES
Jobs Completed		
Employees on Job F.P. G.F. JMR JMR		
Vehicles or Equip. Used 2-11		
Sewer Department		
Address		INSTALLED FLOAT BALL BEHIND LAVAZZEL CHECKED STATIONS / TURNED ON BEELVIEW
Job Completed		BY-PASS PUMPED WITH 3" GAS PUMP AT PILL BOX
Employees on Job F.P. - B.S. - J.H. JMR JMR		CYCLED PUMP AT
Vehicles or Equip. Used 14-7- BACKHOLE		CYCLED BLOWERS AT OAKLAND
Meter Readers		
Employees on Job G.F. GMR		FINISHED 142
Areas - Read		
Vehicles Used 3		
General Foreman <u>Frank J. Pace</u>		

Water Department		Comments
Address		SERVICE TRUCK W.O.
Jobs Completed		
Employees on Job G.F. JMR		
Vehicles or Equip. Used  11		
Sewer Department		
Address		
Job Completed		BY-PASS PUMPED WITH 3" GAS PUMP AT Ex. 7f (Water Infra.) FILL BOX
Employees on Job G.F. GMR		CYCLED BLOWERS AT OAKLAND 2 AT 73RD CYCLED PUMPS AT Ex. 6 (Personal Privacy) AT BEHIND Ex. 6 (Personal Privacy)
Vehicles or Equip. Used  7		
Meter Readers		
Employees on Job F.P. - B.S		FINISHED 29
Areas - Read		
Vehicles Used 3		
General Foreman <u>Frank J. Pace</u>		

Date 5-18-16

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address	SERVICE TRUCK W.D. RE-READS / REMOVES	
Jobs Completed		
Employees on Job F.P. - G.F. GHR		
Vehicles or Equip. Used 2-11		
Sewer Department		
Address	INSTALLED STARTER AT LAURALLE WRT WELL CHECKED STATIONS	
Job Completed	CYCLED PUMPS AT <span>Ex. 6 (Personal Privacy)</span> + BEHIND <span>Ex. 6 Personal Privacy</span> - CYCLED BLOWERS AT <span>Ex. 7f (Water Infra.)</span> + OAKLAND	
Employees on Job B.S. - J.H.	RV-PASS PUMPED WITH 3" GAS PUMP AT <span>Ex. 7f (Water Infra.)</span> + CC BOX,	
Vehicles or Equip. Used 7-14		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Price</u>		



Water Department		Comments
Address		SERVICE TRUCK W.O.
Jobs Completed		
Employees on Job G.F.		
Vehicles or Equip. Used 11		
Sewer Department		
Address		MADE TAP & HOOKED UP SEWER LINE AT Ex. 6 (Personal Privacy) SED ONE 3" CONCRETE 26" P.V.C. SADDLE, 36" OF 6" SCH 35 P.V.C., ONE 6" X 6" 45° ONE 6" X 4" REDUCER, 136" OF 4" P.V.C., + ONE 4" X 4" GUR COUPLING - BACKFILL & WITH S&B CYCLED PUMPS AT Ex. 6 (Personal Privacy) CYCLED BLOWERS AT OAKLAND Ex. 7f (Water Infra.)
Job Completed		
Employees on Job F.P. - B.S. - J.H. GAR		BY-PASS PUMPED WITH 3" BAS PUMP AT Ex. 7f (Water Infra.) PILL BOX
Vehicles or Equip. Used 14-7- BACKHOLE		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman		

Date 5-17-16

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address		SERVICE TRUCK W.O. - SHUT OFFS
Jobs Completed		
Employees on Job F.P. - B.S. 4 HR		
Vehicles or Equip. Used 2-11		
Sewer Department		
Address		PULLED PUMPS AT REAR 50TH ST. & CLEANED OUT RAGS - PUMPING NOW CYCLED OAKLAND, 73RD, & LAUREL
Job Completed		PULLED PUMP BEHIND BAD FLOATBALL WIRE, WIRED PUMP INTO BREAKER & PUMPED DOWN SYSTEM MANUALLY
Employees on Job F.P. - B.S. 4 HR		BY-PASS PUMPED WITH 3" GAS PUMP AT ONE HOUR AT
Vehicles or Equip. Used 7-14 - BACKHOLE		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		



Water Department		Comments
Address		SERVICE TRUCK W.O.
Jobs Completed		
Employees on Job F.P. 1 HR		
Vehicles or Equip. Used  2		
Sewer Department		
Address		REMOVED MOTOR FROM [REDACTED] SENT IN TO SHOP INSTALLED NEW MOTOR PUMPING NOW [REDACTED] Ex. 6 (Personal Privacy)
Job Completed		CYCLED BLOWERS AT [REDACTED] AT OAKLAND CYCLED PUMPS ON HAND AT LARRAINE WETWELL [REDACTED] PUMP OFF AT [REDACTED] [REDACTED] Ex. 6 (Personal Privacy) Ex. 7f (Water Infra.) Ex. 6 (Personal Privacy)
Employees on Job J.H. B.S. G.H.R.		RY-CASS PUMPED WITH 9" GAS PUMP AT [REDACTED] RILL BOX [REDACTED] Ex. 7f (Water Infra.)
Vehicles or Equip. Used  7-14		PUMPS AT [REDACTED] IN FIELD FROM RENOIS NOT PUMPING [REDACTED] Ex. 6 (Personal Privacy)
Meter Readers		
Employees on Job F.P. - G.F. 7 HR		FINISHED 242 26-F.P. 212 22-G.F.
Areas - Read		
Vehicles Used 2-3		
General Foreman <u>Frank J. Pace</u>		



Date 5-13-16

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

**Water Department****Comments**

Address

SERVICE TRUCK W.O.

Jobs Completed

Employees on Job

F.P.  
2000

Vehicles or Equip. Used

2

**Sewer Department**

Address

Job Completed

BY-PASS PUMPED WITH 3" GAS PUMP AT  
WELL BOX**Ex. 7f (Water Infra.)**

Employees on Job

J.H.

Vehicles or Equip. Used

7

**Meter Readers**

Employees on Job

G.F. F.P.  
CNR

FINISHED

19-F.P. &amp; G.F. - 20-G.F. - 28-F.P.

Areas - Read

Vehicles Used

2-3

General Foreman Frank J. Pace

Date 5-12-16

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

SERVICE TRUCK W.O.

Jobs Completed

POURED CONCRETE PATCH IN ROAD WHERE  
MAIN BREAK WAS REPAIRED AT

Ex. 6 (Personal Privacy)

Employees on Job

F.P. - G.F. - B.S. - J.H.  
GMR 4MR

Vehicles or Equip. Used

14-7-3-11

**Sewer Department**

Address

CHECKED STATIONS - 50TH ST. KICKED  
Ex. 6 (Personal Privacy) FLOATBALL HUNG UP ON  
SOLIDS - NEEDS VACUMED OUT - BOTH PUMPING  
NOW

Job Completed

CYCLED PUMP AT LAURALER WET WELL  
CYCLED BLOWERS AT  
AT OAKLAND

Ex. 7f (Water Infra.)

Employees on Job

J. H.  
4MR

Vehicles or Equip. Used

7

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 5-11-16

Daily Job Sheet

Sheet     of    **Water Department****Comments**

Address	SERVICE TRUCK W.O.
Jobs Completed	CUT ROAD, REMOVED ASPHALT, GRADED ROCK FOR CONCRETE POUR AT <b>Ex. 6 Personal Privacy</b>
Employees on Job F.R. - G.F. - B.S.	
Vehicles or Equip. Used 11-14 - BACKHOE	

**Sewer Department**

Address	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT <b>Ex. 7f (Water Infra.)</b> RILL BOX
Employees on Job J. H.	CYCLED PUMP AT LAURALER WET WELL CYCLED BLOWERS AT <b>Ex. 7f (Water Infra.)</b>
Vehicles or Equip. Used 7	BELLEVUE WAS KICKED OUT CAUSING BLUFF TO SURCHARGE IN STREET - TURNED OFF BLUFF & LET BELLEVUE CATCH UP - BOTH ON NOW

**Meter Readers****Employees on Job****Areas - Read****Vehicles Used**General Foreman Frank J. Pace



Water Department		Comments
Address		SERVICE TRUCK W/O.
Jobs Completed		REBUILT SERVICE AT <span>Ex. 6 (Personal Privacy)</span> USED ONE 2" FLARE X 3/4" COMP, ONE METER COUPLING, ONE METER SHUT OFF, ONE 3/4" X 3/4" COMP, ONE 18" X 30" P.V.C. METER BOX, 20' OF COPPER, INSTALLED METER ON
Employees on Job F.P. - B.S. - G.F.		REBUILT SERVICE AT <span>Ex. 6 Personal Privacy</span> USED ONE 2" FLARE X 3/4" COMP, ONE METER COUPLING, ONE METER SHUT OFF, ONE 3/4" X 3/4" COMP, ONE 18" X 30" METER BOX, 13' OF 3/4" COPPER, INSTALLED METER - LEFT OFF
Vehicles or Equip. Used 11-14- BACKHOL		CYCLD PDAP AT LAUREL WET WELL CYCLD BLOWERS AT <span>Ex. 7f (Water Infra.)</span>
Sewer Department		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		

Date 5-9-16

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

SERVICE TRUCK W/O.

LOCATES

RE-GRADS

Jobs Completed

Employees on Job

F.P. G.F.  
1.5 hr 6 hr

Vehicles or Equip. Used

2-11

**Sewer Department**

Address

DISASSEMBLED PUMP & CLEANED OUT RAGS &  
INSTALLED IN M.H. IN FIELD FROM RENVOIS  
PUMPING JOW

Job Completed

CYCLED PUMP IN LAURIE WET WELL  
CYCLED BLOWERS AT Ex. 7f (Water Infra.)

Employees on Job

F.P. B.S.  
1.5 hr 1 hrBY-PASS DUMPED WITH 3" GAS PUMP AT  
Ex. 7f (Water Infra.) ALL BOX  
Ex. 7f (Water Infra.)

Vehicles or Equip. Used

ADJUSTED FLOATBALLS AT Ex. 7f (Water Infra.)

7-14-BACKHOL

Meter Readers

Employees on Job

F.P. G.F.  
5 hr 2 hr

FINISHED

15-G.F. - 18-F.P.

Areas - Read

Vehicles Used

2-3

General Foreman

Frank J. Pace



Date 5-6-16

Daily Job Sheet

Sheet     of    **Water Department****Comments**

Address

SERVICE TRUCK W/O.

Jobs Completed

Employees on Job

F.B.-B.S.  
1.5 HR

Vehicles or Equip. Used

2-11

**Sewer Department**

Address

PULLED PUMP AT Ex. 6 (Personal Privacy) - CLEANED  
OUTRAGE & SET BACK IN - PUMPING NOW  
INSTALLED BELTS & CHANGED OIL IN BLOWER AT  
BELLEVUE

Job Completed

PULLED PUMP AT LAUREL WET WELL - WIRED  
INTO TOP OF STARTER - PUMPING NOW  
Ex. 7f (Water Infra.) BLOWER AT ORLANDA

Employees on Job

F.P.-B.S.  
6.5 HRPULLED PUMP IN FIELD FROM RENNOIS &  
TOOK TO SHOP BY-PASS PUMPED M.H.  
WITH 3" PUMP

Vehicles or Equip. Used

14- BACKHOE

BLUFF OFF UNTIL BELLEVUE CATCHES  
UP - WAS SURCHARGING IN STREET

Meter Readers

Employees on Job

G.F.  
G.D.R.FINISHED  
13:14

Areas - Read

STARTED  
15

Vehicles Used

General Foreman

Frank J. Pace



Water Department		Comments
Address		SERVICE TRUCK W.O.
Jobs Completed		
Employees on Job F.P. 2 HR		
Vehicles or Equip. Used 2		
Sewer Department		
Address		
Job Completed		BY-PASS PUMPED WITH 3" PUMP AT BO. Ex. 7f (Water Infra.)
Employees on Job B.S.		
Vehicles or Equip. Used 7		
Meter Readers		
Employees on Job G.F. - F.P. WHR		FINISHED 12-G.F. - 17-F.P.
Areas - Read		STARTED 13-G.F.
Vehicles Used 2-3		
General Foreman <u>Franky Bee</u>		

Water Department		Comments
Address		SERVICE TRUCK W.O.
Jobs Completed		
Employees on Job F.P. - B.S. 4 HR		
Vehicles or Equip. Used 2-11		
Sewer Department		
Address		PULLED JUMP PUMP, TOOK OFF BOTTOM & CLEANED OUT RAGS, & CLEANED OUT SUM. HOLE AT BRIDGE DALE
Job Completed		PULLED PUMP & CLEANED OUT RAGS AT Ex. 7f (Water Infra.)
Employees on Job F.P. - B.S. 4 HR		
Vehicles or Equip. Used 2-14- BACKHOE		
Meter Readers		
Employees on Job G.F.		FINISHED 9/11
Areas - Read		
Vehicles Used		
General Foreman <u>Franky Pace</u>		

Water Department		Comments
Address		
Jobs Completed		
Employees on Job		
Vehicles or Equip. Used		
Sewer Department		
Address		BY-PASS PUMPED WITH 3" GAS PUMP AT Ex. 7f (Water Infra.)
Job Completed		PULLED BACK OFF PUMP & CLEANED OUT RAGS PUMPED DOWN WET WELL WITH 6" PUMP & JACKETED HEADER AT BRIDGEDALE - PUMPING NOW - SUMP PUMP CLOGGED UP & NEEDS WORK
Employees on Job F.P. - B.S. - J.H.		
Vehicles or Equip. Used 2-14-7-6" PUMP, BACKHOLE		
Meter Readers		
Employees on Job G.F.		FINISHED 6
Areas - Read		STARTED 9
Vehicles Used		
General Foreman <u>Frank J. Price</u>		



Date 5-2-16

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed	REBUILT SERVICE AT [REDACTED] LEAK ON METER SET (OUR SIDE) - USED ONE FLAREX COMP. ONE METER COUPLING, ONE METER SHUT OFF, ONE 3/4" X 3/4" COMP, 14' OF 3/4" COPPER TUBING, ONE 1/2" X 3/4" P.V.C. METER BOX, BACKFILLED WITH SPOIL - YARD NEEDS WORK	
Employees on Job	F.P. - B.S. 4 HR.	
Vehicles or Equip. Used	2-14-BACKHOE	

Sewer Department	
Address	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT [REDACTED] CLINTON
Employees on Job	CYCLAD OAKLAND & [REDACTED]
Vehicles or Equip. Used	7

Meter Readers	
Employees on Job	STARTED B.S. & C.G.F.
Areas - Read	FINISHED B.S. & C.G.F.
Vehicles Used	

General Foreman Franky Pace

Date 6-30-16

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

SERVICE TRUCK W.O.

Jobs Completed

Employees on Job

G.F.  
JHR

Vehicles or Equip. Used

11

**Sewer Department**

Address

INSTALLED 10" CONC. X 6" SADDLE, 24" OF 6" SCH 35 P.V.C. RISER, 6" X 6" 45° FITTING, 30" OF 6" SCH 35 P.V.C., 6" X 6" 22½° FITTING, 6" X 4" REDUCER, 9" OF 4" SCH 35 P.V.C., 4" X 4" 22½° FITTING,

Job Completed

28" OF 4" SCH 35 P.V.C., 4" SCH 40 X 4" SCH 35 COUPLING, BACKFILLED AROUND SEWER MAIN &amp; TAP WITH TRUCKLOAD OF CLEAN ROCK, TOPPED OFF WITH TRUCK LOAD OF GRADE 8 ROCK,

Employees on Job

F.P. - B.S. - T.C.

HAULED OFF ONE TRUCKLOAD OF SPOIL TO SHOP

Vehicles or Equip. Used

CYCLED PUMP AT

Ex. 6 (Personal Privacy)

6-14- BACKHOLE

CHECKED M.H. ON RENOIS - IT WAS DOWN - NEED TO CHECK AGAIN ON 7-1-16

Meter Readers

Employees on Job

G.F.  
GHR

FINISHED

7

Areas - Read

STARTED

8

Vehicles Used

8

General Foreman

Frank J. Pace



Date 6-29-76

Daily Job Sheet

Sheet      of     **Water Department****Comments****Address**

SERVICE TRUCK W/O.  
TOOK UNIT 11 TO ALL TYPE FOR TIRES

**Jobs Completed****Employees on Job**

G.F.  
C.H.R.

**Vehicles or Equip. Used**

2-11

**Sewer Department****Address**

BY-PASS PUMPED M.H. WITH 3" PUMP,  
VACUMED OUT SLUDGE & SOLIDS FROM M.H.  
IN FIELD FROM RENOIS + INSTALLED ELECTRIC

**Job Completed**

WORKED ON LATERAL TAP FOR  
VUE - JETTED DOWN RISER, BUT DIDN'T GET  
THROUGH. EXPOSED WHERE RISER TAPS INTO  
MAIN, REMOVED RISER & JETTED MAIN LINE

**Employees on Job**

F.P. - B.S. - T.C. - G.F.  
L.W.  
J.H.R.

GOOT MAIN TO BRAIN SLOWLY - DIDN'T GET  
TOTALLY THROUGH BLOCK - PREPPED FOR  
SADDLE & NEW RISER -

**Vehicles or Equip. Used**

2-14-9- BACKHOLE

PHONE LINE WAS ALREADY HIT & BROKEN  
BY TIGER PLUMBING BEFORE WE STARTED  
DIGGING - TOOK PHOTO ON PHONE F.P.

**Meter Readers****Employees on Job****Areas - Read****Vehicles Used****General Foreman**

Frank J. Pace

Ex. 6 (Personal Privacy)



Date 6-28-16

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W.O. / SHUT OFFS
Jobs Completed	REMOVED SADDLE + CORP FOR MOVED SERVICE LINE OUT FROM UNDER DRIVEWAY OF <span style="background-color: black; color: red;">Ex. 6 Personal Privacy</span> - INSTALLED 4" AD X 8" S.S. REPAIR CLAMP OVER TAP HOLE
Employees on Job F.P. - B.S. G.F. 4 HR	USED ONE 3/4" P.V.C. BARB X 3/4" COMP. FITTING 4 3' OF 3/4" COPPER TUBING (INSTALLED SADDLE + CORP ON 6-27-16)
Vehicles or Equip. Used	
11-14-BACKHOLE	

Sewer Department

Address	INSTALLED REBUILT GRINDER PUMP IN FIELD FROM RENOIS
Job Completed	CHECKED SEWER BACKUP AT <span style="background-color: black; color: red;">Ex. 6 (Personal Privacy)</span> NEED TO SET RISER + TRUNK LINE TOMORROW
Employees on Job F.P. - B.S. 4 HR 2-BACKHOLE-14	
Vehicles or Equip. Used	
2-14-BACKHOLE	

Meter Readers

Employees on Job T.Cr	FINISHED 5
Areas - Read	STARTED 7
Vehicles Used 8	

General ForemanFrank J. Pace

Date 6-27-16

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address	SERVICE TRUCK W.O. FLUSHED LINES ON	
Jobs Completed	EXPOSED MAIN, INSTALLED SADDLE & CORP STOP, MADE 3/4" TAP OUTSIDE DRIVEWAY AT	
Employees on Job	F.P. - B.S.	
Vehicles or Equip. Used	14-BACKHOLE	
Sewer Department		
Address		
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT PILL BOX,	
Employees on Job	Cycled blowers at Oakland and at 73rd	
Vehicles or Equip. Used	3	
Meter Readers		
Employees on Job	T.C.	
Areas - Read	STARTED 5	
Vehicles Used	8	
General Foreman	Frank J. Pace	

Ex. 6 Personal Privacy

Ex. 6 Personal Privacy

Ex. 6 Personal Privacy

Ex. 7f (Water Infra.)

Ex. 7f (Water Infra.)

Ex. 7f (Water Infra.)

1/2 HR AT RENOS FIELD M.H.

Ex. 6 Personal Privacy

Ex. 6 Personal Privacy



Date 6-24-16

Daily Job Sheet

Sheet      of     **Water Department****Comments**

<b>Address</b>	SERVICE TRUCK W.O. LOCATES
<b>Jobs Completed</b>	
<b>Employees on Job</b> F.P. CNR	
<b>Vehicles or Equip. Used</b> 2-11	

**Sewer Department**

<b>Address</b>	TOOK 3" SUCTION HOSE TO 12-MO PUMPS AND HAD IT RE-BANDED - WORKING NOW
<b>Job Completed</b>	BY-PASS PUMPS WITH 3" GAS PUMP AT <b>Ex. 7f (Water Infra.)</b> <b>Ex. 7f (Water Infra.)</b> FIELD FROM RENOV
<b>Employees on Job</b> F.P. B.S. JMR 4MR	CYCLD PUMP AT <b>Ex. 6 (Personal Privacy)</b> CYCLD BLOWERS AT OAKLAND AVE AT <b>Ex. 7f (Water Infra.)</b>
<b>Vehicles or Equip. Used</b> 2-3	

**Meter Readers**

<b>Employees on Job</b> T.C.	FINISHED 3-4
<b>Areas - Read</b>	STARTED
<b>Vehicles Used</b> 8	
<b>General Foreman</b>	<u>Franky Pace</u>



Date 0-23-16

Daily Job Sheet

Sheet     of    

Water Department		Comments
Address	SERVICE TRUCK W/O. RR. READS	
Jobs Completed	REPLACED DOUBLESAT T-BAR AT Ex. 6 Personal Privacy - USED ONE $\frac{3}{4}$ " x $\frac{3}{4}$ " COMP. FITTING ONE DOUBLESAT, TWO METER SHUTOFF	
Employees on Job F.P. - B.S. 7 HR	WITH THREAD ON PIPE THREAD, 8" OF $\frac{3}{4}$ " COPPER TUBING	
Vehicles or Equip. Used	2-11-14- BACKHOL	
Sewer Department		
Address		
Job Completed	PULLED PUMP & CLEANED OUT RAGS AT 50TH Ex. 7f (Water Infra.)	
Employees on Job F.P. - B.S. 1 HR	CYCLED PUMP AT Ex. 6 Personal Privacy	
Vehicles or Equip. Used	14- BACKHOL	
Meter Readers		
Employees on Job T.C.	FINISHED 25-30-10	
Areas - Read	STARTED 4	
Vehicles Used 8		
General Foreman	Frank J. Pace	

Date 6-22-16

Daily Job Sheet

Sheet     of    **Water Department****Comments**

Address

SERVICE TRUCK W.O.

LOCATING

Jobs Completed

Employees on Job

F.P.

Vehicles or Equip. Used

11

**Sewer Department**

Address

Job Completed

BY-PASS PUMPED WITH 3" GAS PUMP AT  
WELL BOX**Ex. 7f (Water Infra.)**

Employees on Job

B.S.

CYCLAD PUMP AT  
CYCLAD BLOWERS AT OAKLAND AND AT**Ex. 6 Personal Privacy****Ex. 6 (Personal Privacy)**

Vehicles or Equip. Used

3

Meter Readers

Employees on Job

T.C.

FINISHED  
1-2-16-27

Areas - Read

STARTED  
25

Vehicles Used

8

General Foreman

Frank J. Pace

Date 6-21-16

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address

SERVICE TRUCK W.O.  
RE-READS

Jobs Completed

Employees on Job

B.S. F.P.  
5.5 HR 3 HR

Vehicles or Equip. Used

2-11

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP  
AT MAN HOLE IN FIELD FROM RENOIS

Job Completed

Employees on Job

B.S.  
2.5 HR

Vehicles or Equip. Used

3

Meter Readers

Employees on Job

T.C. - F.P.  
5 HR

STARTED

1-T.C. - 16-F.P. &amp; T.C.

Areas - Read

FINISHED

29-T.C. &amp; F.P.

PIT METERS

Vehicles Used

General Foreman

Frank J. Pace



Date 6-20-16

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

SERVICE TRUCK W.O.

Jobs Completed

Employees on Job

Vehicles or Equip. Used

**Sewer Department**

Address

Ex. 6 (Personal Privacy)

CYCLED PUMP AT  
CYCLED BLOWERS AT ORKLAND AVE AT  
73RD ST

Ex. 6 (Personal Privacy)

Job Completed

JETTIED LINE TO RELIEVE BACKUP AT  
Ex. 6 (Personal Privacy)

Employees on Job

F.P. - T.C. B.S.  
1 HRBY-PASS PUMPED WITH 3" GAS PUMP AT  
BOX,

Ex. 6 (Personal Privacy)

Vehicles or Equip. Used

11-9 - 3

NEED TO PULL PUMP + CHECK FOR RAGS  
AT Ex. 6 (Personal Privacy) + ONE PUMP  
PUMPING

Meter Readers

Employees on Job

F.P. - T.C.  
7 HRSTARTED  
29

Areas - Read

Vehicles Used

11

General Foreman

Franky. Lee

Date 6-17-16

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address	SERVICE TRUCK W/O. LOCATLS	
Jobs Completed	REBUILT SERVICE & MOVED BOX ABOUT 4' TO THE EAST TO GET IT OUT OF DRIVEWAY, USED ONE 3/4" X 3/4" COMP. FITTING, ONE METER SHUT-OFF, ONE METER COUPLING, 12" OF 3/4" COPPER TUBING, ONE 18" X 30" CONCRETE METER BOX FROM SHOP, RING & LID FROM SHOP. BACKSIDE COPPER PIGTAIL IS RUN OUT OF BOX ABOUT 4' BUT NOT CONNECTED DUE TO COST	
Employees on Job F.P. - B.S.		
Vehicles or Equip. Used 14-11 - BACKHOE	NOT HAVING RUN THEIR SERVICE LINE YET. TAPED OFF END & DROVE LATH AT END OF LINE. AT	

Ex. 6 (Personal Privacy)

Sewer Department		
Address	CHANGED OIL IN BLOWER AT BLUEVIEW	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT BOX;	
Employees on Job T.C.	CYCLED PUMP AT	
Vehicles or Equip. Used 3	CYCLED BLOWERS AT 73RD ST AND AT OAKLAND	

Ex. 6 (Personal Privacy)

Ex. 6 Personal Privacy

Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	
General Foreman	Frank Pace



Date 6-16-16

Daily Job Sheet

Sheet      of     **Water Department****Comments**

<b>Address</b>	SERVICE TRUCK W.O. RE-READS
<b>Jobs Completed</b>	REBUILT SERVICE AT USED TWO 3/4"X3/4" COMP. FITTINGS, ONE METER SHUT OFF, ONE METER COUPLING, 6' OF 3/4" COPPER TUBING, ONE 18"X30" P.V.C. BOX Ex. 6 (Personal Privacy)
<b>Employees on Job</b> G.F. - F.P. - B.S. - T.C. 4 HR	
<b>Vehicles or Equip. Used</b> 8-11-14-BACKHOLE	

**Sewer Department**

<b>Address</b>	FILLED IN AROUND M.H. IN RIGHT OF WAY FROM RENOIS & FILLED IN RUTS IN YARD BY RIGHT OF WAY FROM RENOIS TO FIELD.
<b>Job Completed</b>	PULLED ELECTRIC PUMP FROM M.H. IN FIELD FROM RENOIS & TOOK TO SHOP - BY-PASS PUMPED M.H. IN FIELD FROM RENOIS WITH 3" GAS PUMP.
<b>Employees on Job</b> F.P. - B.S. - G.F. - T.C. 4 HR	BY-PASS PUMPED WITH 3" GAS PUMP AT CALVIN BLVD, & 71ST CLEANED FLOATBALLS AT BELL VIEW Ex. 7f (Water Infra.)
<b>Vehicles or Equip. Used</b> 8-3-14-BACKHOLE	CYCLED PUMP AT CYCLED BLOWERS AT OAKLAND AND AT 73RD ST. Ex. 6 (Personal Privacy)

**Meter Readers****Employees on Job****Areas - Read****Vehicles Used****General Foreman**Frank Pace



Date 6-15-16

Daily Job Sheet

Sheet      of     **Water Department****Comments****Address**TRUCK 11 SERVICE TRUCK W.O.  
LOCATES**Jobs Completed**DISCONNECTED SERVICE LINE BEHIND  
BOX AT **Ex. 6 (Personal Privacy)** CUT COPPER LINE  
WITH CUT-OFF SAW**Employees on Job**F.P. - B.S. - G.F.  
4 HR**Vehicles or Equip. Used**11-14- BACKHOE**Sewer Department****Address**HOOKED UP DISCHARGE FOR PUMP IN FIELD  
FROM RENOIS - PUMPED FOR LESS THAN  
2 HOURS + STOPPED - NEED TO BY-PASS &  
PULL PUMP TOMORROW**Job Completed**BY-PASS PUMPED WITH 3" GAS PUMP AT  
**Ex. 6 (Personal Privacy)** WELL BOX**Employees on Job**F.P. - B.S. - T.C.  
4 HRCYCLED PUMP AT **Ex. 6 (Personal Privacy)**  
CYCLED BLOWERS AT OAKLAND, AND AT  
**Ex. 6 (Personal Privacy), Ex. 7 (Water Infra.)**  
73RD**Vehicles or Equip. Used**14- 3**Meter Readers****Employees on Job****Areas - Read****Vehicles Used****General Foreman**Frank J. Pace

Date 6-14-76

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

**Water Department****Comments****Address**

SERVICE TRUCK W.O.

**Jobs Completed****Employees on Job**

G.F.

**Vehicles or Equip. Used**

11

**Sewer Department****Address**PUMPED DOWN WELL, CLEANED OUT A  
FLOAT BALL THAT WAS LODGED IN HEADER,  
PRIMED PUMP AT SNOWS STATION -  
NEED TO INSTALL ALTERNATOR**Job Completed**CYCLED PUMP AT Ex. 6 Personal PrivacyBY-PASS PUMPED WITH 3" GAS PUMP AT  
CALVIN BLVD & FIELD FROM RENOIS**Employees on Job**

F.P. - B.S. - T.C.

PULLED PUMP IN FIELD FROM RENOIS &  
CLEANED OUT HAIR & RAGS - NEED TO  
CONNECT IN MORNING**Vehicles or Equip. Used**

8-14-BACKHOE

**Meter Readers****Employees on Job****Areas - Read****Vehicles Used****General Foreman**

Frank J. Pace



Date 6-13-16

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address	SERVICE TRUCK W.O. RE-READS LOCATES	
Jobs Completed	RE-BUILT BACKSIDE AT USED ONE METER COUPLING, ONE 1/2" X 3/4" COMP. FITTING, 4' OF COPPER TUBING, ONE 18" X 30" P.V.C. METER BOX - BACKFILLED WITH SPOK (MUDAY) NEED TO REPAIR YARD AT LATER DATE	
Employees on Job F.P. - B.S. - G.F.	CLEANED OUT 3" PUMP - NOT MUCH IN PUMP MAY NOT HAVE BEEN PROBLEM ??	
Vehicles or Equip. Used 11-14 - BACKHOE	TOOK 2" PUMP & PUMP FROM BEHIND LAURALEE TO LAURALEE TO	

Ex. 6 Personal Privacy

Ex. 6 (Personal Privacy)

Ex. 6 (Personal Privacy)

Sewer Department	
Address	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT METER BOX
Employees on Job T.C.	
Vehicles or Equip. Used 3	

Ex. 6 (Personal Privacy)

Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	
General Foreman	Frank Pace



Water Department		Comments
Address		Service TRUCK WORK ORDERS 4 HRS
Jobs Completed		
Employees on Job		
Vehicles or Equip. Used # 11		
Sewer Department		
Address		
Job Completed		BY PASSED 71 ST BOTH SPOTS CYCLED 73rd PUMPS <div>Ex. 6 (Personal Privacy)</div> <div>Ex. 6 Personal Privacy</div>
Employees on Job BS		
Vehicles or Equip. Used # 3		
Meter Readers		
Employees on Job TC GE 4 HRS 8 HRS		STARTED & FINISHED 26 FINISHED 20-22 - START-FINISH 19
Areas - Read		
Vehicles Used # 2 # 8 # 11		
General Foreman		B. Level

Date 6-9-16

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

**Water Department****Comments****Address**SERVICE TRUCK W.O.  
RE-RAADS**Jobs Completed**Exposed 4" C.I. water main in front of  
Ex. 6 Personal Privacy - FOLLOWED UNTIL CRACK IN  
MAIN WAS FOUND - REPAIRED WITH 8" X 4" C.I.  
S.S. REPAIR CLAMP - BACKFILLED WITH SPOIL**Employees on Job**F.P. - B.S. - G.F.  
3 HRSET METER BOX & VALVE BOX & BACKFILLED  
AROUND THEM. Ex. 6 (Personal Privacy) SANK  
OUT DITCHES AT  
HAULED OFF EXCESS SPOIL - NEEDS MORE**Vehicles or Equip. Used**

GRADING AFTER IT DRIES OUT

2-11 - BACKHOLE

**Sewer Department****Address****Job Completed****Employees on Job****Vehicles or Equip. Used****Meter Readers****Employees on Job**G.F. - T.C.  
SNR.FINISHED  
20-23-T.C. 24-G.F.**Areas - Read**STARTED  
22-T.C.**Vehicles Used**

2-11

**General Foreman**

Frank J. Pace



Date 6-8-16

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address

TRUCK #11 SERVICE TRUCK W.O.

Jobs Completed

PUMPED OUT DITCH IN PREP FOR JOB  
TOMORROW AT Ex. 6 (Personal Privacy)

Employees on Job

G.F. - F.P. - B.S.  
2 HR

Vehicles or Equip. Used

2-11 - BACKHOLE

Sewer Department

Address

DISASSEMBLED PUMP FROM RENOIS & CLEANED  
OUT MOP FROM BEHIND GRINDER, INSTALLED  
IN M.H. IN FIELD FROM RENOIS - PUMPING NOW

Job Completed

CLEANED SUMP HOLE SO PUMP WOULD PUMP  
& TOOK MEASUREMENTS OF DISCHARGE LINES  
AT SUPERIOR STATION

Employees on Job

F.P. - B.S.  
GHRCYCLED PUMP AT Ex. 6 Personal Privacy  
CYCLED BLOWERS AT OAKLAND STATION  
AND 73RD Ex. 6 (Personal Privacy) STATION

Vehicles or Equip. Used

2 - BACKHOLE

Meter Readers

Employees on Job

T.C.

FINISHED  
18-~~00~~ 21

Areas - Read

STARTED  
20

Vehicles Used

8

General Foreman

Franky Pace



Date 6-7-16

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

SERVICE TRUCK W.O. / SHUT OFFS

Jobs Completed

Employees on Job

F.P. - B.S.  
3 HR.

Vehicles or Equip. Used

11-3

**Sewer Department**

Address

PULLED PUMP IN FIELD FROM RENOIS  
AND BROUGHT TO SHOP TO DISASSEMBLE &  
CLEAN

Job Completed

BY-PASS PUMPED WITH 3" GAS PUMP AT  
M.H. IN FIELD FROM RENOIS  
CALVIN BLVD

Employees on Job

B.S. - G.F.  
5 HR 1 HR

CYCLED PUMP AT

Ex. 6 Personal Privacy

Vehicles or Equip. Used

2-3-BACKHOE

**Meter Readers**

Employees on Job

G.F. THK - T.C.

FINISHED

13-G.F. 17-T.C.

Areas - Read

STARTED  
18-T.C.

Vehicles Used

General Foreman

Frank J. Pace

Date 6-6-14

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

SERVICE TRUCK W.O.

RE-READS

LOCATES

Jobs Completed

Employees on Job

F.P.

4 HR

Vehicles or Equip. Used

11

**Sewer Department**

Address

CHECKED STATIONS - PUMP IN FIELD FROM  
RENOIS IS NOT PUMPING - NEEDS PULLED  
WATER IN BOTTOM OF CAN AT SUPERIOR - USED  
TO CHECK SUMP PUMP

Job Completed

BY-PASS PUMPED WITH 3" GAS PUMP AT

**Ex. 6 (Personal Privacy)**

Employees on Job

B.S. - F.P.  
4 HRCYCLED PUMP AT **Ex. 6 Personal Privacy**CYCLED BLOWERS AT 1320 **Ex. 6 (Personal Privacy)**  
OAKLAND

Vehicles or Equip. Used

3-11

**Meter Readers**

Employees on Job

G.F. - T.C.

FINISHED

14415-T.C.

11412-G.F.

Areas - Read

Vehicles Used

8-14

General Foreman

Frank J. Pace



Date 6-3-16

Daily Job Sheet

Sheet      of     **Water Department****Comments****Address**

SERVICE TRUCK W.O.  
SHUT OFF VALVES AT FALLING SPRINGS TANK

**Jobs Completed****Employees on Job**

F.P. - B.S. - G.F.  
4 HR

**Vehicles or Equip. Used**

14-11

**Sewer Department****Address**

INSTALLED TWO NEW FLOATBALLS AT SNOWY  
CYCLING NOW ON AUTOMATIC  
CHECKED STATIONS ON SOUTH END &  
BELLVIEW + BLUFF

**Job Completed**

BY-PASS PUMPED WITH 3" GAS PUMP AT

**Ex. 6 (Personal Privacy)**

**Employees on Job**

F.P. - B.S. - G.F. - T.C.  
4 HR

CYCLED PUMP AT **Ex. 6 Personal Privacy**  
CYCLED BLOWERS AT OAKLAND STATION &  
**Ex. 6 (Personal Privacy)** STATION (73RD)

**Vehicles or Equip. Used**

14-3

**Meter Readers****Employees on Job**

T.C.  
4 HR

FINISHED  
AREA 8

**Areas - Read****Vehicles Used****General Foreman**

Frank J. Pace



Date 6-2-16

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

SERVICE TRUCK W.O.

Jobs Completed

INSTALLED METER BOX AROUND CURB  
COCK VALVE AT FALLING SPRINGS TANK

Employees on Job

F.P. - B.S.

4 HR

Vehicles or Equip. Used

14 - BACKHOE

**Sewer Department**

Address

CYCLED PUMP AT

Ex. 6 (Personal Privacy)

CYCLED BLOWERS AT OAKLAND AND AT  
73RD ST

Ex. 6 (Personal Privacy)

Job Completed

WORKED ON SNOWS STATION

CHECKED BELLEVUE & BLUFF &  
Ex. 7f (Water Infra.) - ALL GOOD

Employees on Job

F.P. - B.S.

4 HR

Vehicles or Equip. Used

14-3

**Meter Readers**

Employees on Job

G.F. - T.C.

FINISHED  
PIT METERS & AREA 9 - G.F. / AREA 6 T.C.

Areas - Read

STARTED  
AREA 8 T.C.

Vehicles Used

8-11

General Foreman

Frank J. Pace

Date 6-1-14

## Daily Job Sheet

Sheet      of     Water Department

## Comments

Address

SERVICE TRUCK W.O.

Jobs Completed

REPLACED BROKEN RING AT  
DUG OUT ROCK AROUND RING & BRICKS, CUT 1 1/2" CLAY RISER AT SHOP, INSTALLED RISER, RING & LID  
FILLED IN AROUND RING WITH COLD PATCH & TAMPED

Ex. 6 (Personal Privacy)

Employees on Job

G.F. - F.P. - B.S.  
6 HROPEN & CLOSED 12" VALVES, REPLACED CURB-CK  
BOX WITH METER BOX AT FALLING SPRINGS TANK  
NEED TO BACKFILL BOX

Vehicles or Equip. Used

11-14-BACKHOLE

Sewer Department

Address

Job Completed

WORKED ON SNOWS - PUMP RUNS ON HAND ONLY  
USED GENERATOR TO PUMP OUT CAN WITH  
SUMP PUMP - NO 110 ELEC. OUT OF G.F.I.

Employees on Job

F.P. - B.S.  
2 HR

Vehicles or Equip. Used

3-14

Meter Readers

Employees on Job

T.C.

FINISHED  
5

Areas - Read

STARTED  
6

Vehicles Used

8

General Foreman

Frank J. Pace



Date 7-29-16

Daily Job Sheet

Sheet      of     **Water Department****Comments****Address**SERVICE TRUCK W.O. / RE-READS  
LOCATESCHECKED SEWER STATIONS ON  
SOUTH END - BELLEVUE/BLUFF**Jobs Completed**WRECKED FORMS & GRADED ROCK IN DRIVE  
WHERE CONCRETE PATCH WAS POURED AT

Ex. 6 (Personal Privacy)

**Employees on Job**F.P. - G.F. T.C.  
1 HRRE-BUILT SERVICE AT  
USED ONE 3/4" FLARE X 3/4" COMP. FITTING, ONE 1/2" X  
3/4" COMP. FITTING, ONE METER SHUT OFF, ONE

Ex. 6 (Personal Privacy)

**Vehicles or Equip. Used**

3-14-BACKHOL

METER COUPLING, ONE 18" X 30" P.V.C. METER  
BOX, 10' OF 3/4" COPPER TUBING - BACKFILLED WITH  
SPILL - NEED TO HAUL OFF SPILL & CLEAN UP YARD**Sewer Department****Address****Job Completed**BY-PASS PUMPED WITH 3" GAS PUMP AT  
C BOX,

Ex. 6 (Personal Privacy)

**Employees on Job**T.C.  
7 HRCYCLED BLOWERS AT OAKLAND AND AT  
73RD ST

Ex. 6 (Personal Privacy)

**Vehicles or Equip. Used**

3

**Meter Readers****Employees on Job****Areas - Read****Vehicles Used****General Foreman**

Frank J. Pace



Date 7-28-16

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address	SERVICE TRUCK W.O. / RE-READS REMOVED ROCK & EXPOSED METER BOX FOR RE-READ AT <b>Ex. 6 (Personal Privacy)</b> GRADES ROCK AROUND BOX	
Jobs Completed	POURED CONCRETE PATCH IN DRIVEWAY APRON AT <b>Ex. 6 (Personal Privacy)</b> WHERE 4" MAIN BREAK WAS REPAIRED	
Employees on Job <u>F.P. - B.S. - T.C.</u> - G.F. 6 HR	SAW CUT PATCHES WHERE REPAIRS WERE MADE IN PREP FOR ASPHALT AT <b>Ex. 6 (Personal Privacy)</b> <b>Ex. 6 (Personal Privacy)</b>	
Vehicles or Equip. Used		
11-8-14 - BACKHOE		
Sewer Department		
Address	RE-SET STARTER AT <b>Ex. 6 (Personal Privacy)</b>	
	STATION - PUMPING NOW - 1	
Job Completed	<b>Ex. 6 (Personal Privacy)</b> EXPOSED M.H. BEHIND <b>Ex. 6 (Personal Privacy)</b> DOWN IN CHANNEL - DUE TO CALL IN ABOUT BACKUP AT <b>Ex. 6 (Personal Privacy)</b> WOKED TO COST	
Employees on Job <u>F.P. - B.S. - T.C.</u> 2 HR	<b>Ex. 6 (Personal Privacy)</b> WAS FLOWING THROUGH LATERAL CLEAN OUT & NOT BACKING UP AT CLEAN OUT	
Vehicles or Equip. Used		
8-14 - BACKHOE		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		

Date 7-27-16

Daily Job Sheet

Sheet      of     

Water Department

Comments

Address

SERVICE TRUCK W.O.

RE-READS

Jobs Completed

GRADED ROCK & SET UP FORM FOR CONCRETE  
POUR AT **Ex. 6 (Personal Privacy)**

Employees on Job

G.F. - F.P. - B.S.  
5 HRINSTALLED BACKSIDE METER COUPLING & METER  
**Ex. 6 (Personal Privacy)** - MAY HAVE NEW LEAK  
DUE TO TAMPERING - MAY NEED NEW SHUT-OFF  
ALSO

Vehicles or Equip. Used

2-14-11 - BACKHOE

Sewer Department

Address

JACKETED LINE & LATERAL TO RELIEVE  
BACKUP AT **Ex. 6 (Personal Privacy)**

Job Completed

BY-PASS PUMPED WITH 3" GAS PUMP AT

**Ex. 6 (Personal Privacy)**

Employees on Job

T.C. - B.S. - F.P.  
3 HRCYCLED BLOWERS AT OAKLAND AND AT  
73RD **Ex. 6 (Personal Privacy)**

Vehicles or Equip. Used

2-9-3-

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace



Date 7-26-16

Daily Job Sheet

Sheet      of     **Water Department****Comments****Address**SERVICE TRUCK W/O / SHUT-OFFS  
RE-READS**Jobs Completed****Employees on Job**

G.P. - T.C.

**Vehicles or Equip. Used**

8-11

**Sewer Department****Address**JETTED LINE TO RELIEVE BACKUP AT  
Ex. 6 (Personal Privacy) FOR CENTREVILLE**Job Completed**WORKED ON SNOWS STATION ALTERNATOR &  
MOVED TREES THAT WERE DUMPED  
WORKED ON Ex. 6 (Personal Privacy) PUMPING & CYCLING  
NOW - CLEANED FLOAT BALLS**Employees on Job**B.S. - T.C. F.P.  
2 HR 6 HRCHECKED STATIONS ON NORTHEAST  
WORKED AT SUPERIOR ON JOB PREP**Vehicles or Equip. Used**

9-2-14 - BACKHOP

**Meter Readers****Employees on Job**F.P. - T.C.  
2 HR 2 HRFINISHED  
AREA 5 - T.C. & F.P.**Areas - Read****Vehicles Used**

2-8

**General Foreman**

Frank J. Pace



Date 7-22-10

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed		
Employees on Job G.F.		
Vehicles or Equip. Used 11		
<b>Sewer Department</b>		
Address		
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT <b>Ex. 6 (Personal Privacy)</b>	
Employees on Job B.S.	CYCLED PUMP AT <b>Ex. 6 (Personal Privacy)</b> CYCLED BLOWERS AT OAKLAND <b>Ex. 6 (Personal Privacy)</b>	
Vehicles or Equip. Used 3	TURNED ON <b>Ex. 6 (Personal Privacy)</b> AMCS STATIONS BELLVIEW & BLUFF ON	
<b>Meter Readers</b>		
Employees on Job F.P. - T.C.	FINISHED 7 & 8 - F.P. 3 & 4 T.C.	
Areas - Read	STARTED 6	
Vehicles Used 2 - 8		
General Foreman	Frank J. Pace	

Date 7-21-16

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address		SERVICE TRUCK W.O.
Jobs Completed		
Employees on Job	G.F. 4 HR	
Vehicles or Equip. Used	11	

Sewer Department		
Address		SWITCHED STARTER WIRES TO GOOD BREAKER + REMOVED BAD BREAKER AT Ex. 6 (Personal Privacy)
Job Completed		CHANGED OIL IN BLOWERS AT BEECHLAND, 63RD Ex. 7f (Water Infra.) BELLEVUE, 73RD Ex. 6 (Personal Privacy)
Employees on Job	F.P. - B.S.	CHECKED STATIONS ON NORTH SIDE DIPPED OUT WATER & REPLACED LIN+TARPAT BEECHLAND, REPLACED TARPAT Ex. 7f (Water Infra.)
Vehicles or Equip. Used	14	E1ST LOUIS STILL UP AT 73RD Ex. 6 (Personal Privacy) TURNED ON BELLEVUE

Meter Readers		
Employees on Job	G.F. 4 HR T.C.	FINISHED 29-T.C.+G.F. - 10-G.F.
Areas - Read		STARTED 3-T.C.
Vehicles Used		

General Foreman Frank J. Pace



Date 7-20-16

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

SERVICE TRUCK W/O.

Jobs Completed

Employees on Job

G.F.

Vehicles or Equip. Used

11

**Sewer Department**

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT

Ex. 6 (Personal Privacy)

Ex. 6 Personal Privacy

Job Completed

CYCLED PUMP AT Ex. 6 (Personal Privacy)

COULDN'T CYCLE OAKLAND OR 73RD AVE  
TO E. ST. LOUIS BACKED UP

Employees on Job

B.S.

BELLEVUE & BLUFF OFF DUE TO E. ST.  
LOUIS BACKED UP & NOT TAKING

Vehicles or Equip. Used

3

Ex. 6 (Personal Privacy) STATION NOT PUMPING

Meter Readers

Employees on Job

F.P. - T.C.

FINISHED

142 - T.C.

27+30 F.P.

Areas - Read

STARTED

29 - F.P. &amp; T.C.

Vehicles Used

2-8

General Foreman

Frank Pace



Date 7-19-76

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

SERVICE TRUCK W/O.

LOCATES

RE-READS - T.C.

Jobs Completed

SET 3 VALVE BOXES & BACKFILLED HOLE WITH  
ROCK WHERE CROSS TIE REPLACEMENT CUT & CAP  
WAS DONE AT **Ex. 6 (Personal Privacy)**

Employees on Job

G.P. - F.P. - B.S.  
6 4

Vehicles or Equip. Used

11-14-BACKHOE

**Sewer Department**

Address

CHECKED BELLEVIEW - STILL PUMPING,  
BUT WELL WAS UP DUE TO RAIN - LEFT  
BLUFF OFF - F.P.

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

F.P. - B.S. - T.C.  
2 4

FINISHED

19-F.P.+B.S. - 24-T.C.

16+25-B.S.

Areas - Read

STARTED  
2-T.C.

Vehicles Used

8-2

General Foreman

Frank J. Pace

Date 7-12-16

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

SERVICE TRUCK W.O. / RE-READS

Jobs Completed

INSTALLED 4" CAP + BLOCKING AT  
**Ex. 6 (Personal Privacy)** HAULLED IN SOME  
ROCK AROUND VALVES - STILL NEED TO SET  
BOXES

Employees on Job

G.F. E.P. - B.S.  
1 HR 5 HR

Vehicles or Equip. Used

11-14-2 - BACKHOE

**Sewer Department**

Address

REPLACED TWO FLOAT BALLS AT I.C. TRACKS  
TURNED ON CHURCH RD. STATION - PUMPING  
FULL PIPE

Job Completed

SHOT OFF BLUFF DUE TO BELLEVUE  
BACKED UP - BREAKER AT BELLEVUE WAS  
KICKED OUT - RE-SET + PUMPING NOW

Employees on Job

G.F. E.P. - B.S.  
7 HR 3 HR

Vehicles or Equip. Used

HAULLED IN 6" SUCTION HOSES FROM I.C.  
TRACKS  
CYCLED STATIONS AT **Ex. 6 (Personal Privacy)** OAKLAND**Ex. 7f (Water Infra.)**

BY-PASS PUMPED WITH 3" GAS PUMP AT

**Ex. 6 (Personal Privacy)**

3-14-2

Meter Readers

Employees on Job

T.C.

FINISHED  
23 + 26

Areas - Read

STARTED  
24

Vehicles Used

8

General Foreman

Frank J. Pace

Date 7-15-14

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

**Sewer Department**

Address

2 HR CALL OUT - OVERTIME

Job Completed

HAULED IN 6" DIESEL PUMP FROM  
I.C. TRACKS STATION

Employees on Job

G.F.

Vehicles or Equip. Used

14

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace



Date 7-15-16

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

REMOVED 6" CROSS TIE LINE AT  
- REPLACED OUT OF 8"X8"X6' A.C. TEE  
WITH GASKET FROM SHOP, 7' OF 6" C-900 P.V.C.,  
6"X6" 90° FITTING, 45" OF 6" C-900 P.V.C., ONE

Ex. 6 (Personal Privacy)

Jobs Completed

6" GATE VALVE, TWO 6" MEGA LUG FLANGES  
ON 90°. BACKFILLED AROUND MAINS & VALVES  
WITH CLEAN ROCK, ISOLATED 8" TRANS. LINE

Employees on Job

F.P. - B.S. - G.F.

BY SHUTTING OFF VALVES -

Vehicles or Equip. Used

2-14 - BOTH BACKHOES

**Sewer Department**

Address

BY-PASS PUMPED WITH 6" DIESEL PUMP  
AT I.C. TRACKS STATION

Job Completed

BY-PASS PUMPED WITH 3" GAS PUMP AT

Ex. 6 (Personal Privacy)

Employees on Job

T.C.

Vehicles or Equip. Used

6" PUMP - 3' - 3" PUMP

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Franky Pace

Date 7-15-16

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

1 HR. OVERTIME - LUNCH HOUR  
NEVER TOOK LUNCH ON CROSS TIE  
REPLACEMENT JOB AT **Ex. 6 (Personal Privacy)**

Jobs Completed

Employees on Job

B.S. - F.P. - G.F.

Vehicles or Equip. Used

2-14 - BOTH BACKHOES**Sewer Department**

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 7-14-16

Daily Job Sheet

Sheet      or     **Water Department****Comments**

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

**Sewer Department**

Address

O.T. - CALL OUT

Job Completed

Employees on Job

F.P.

CHECKED I.C. TRACKS STATION -  
ELECTRIC OUT DUE TO STORM - CAUSING  
BACKUPS ON CHURCH RD.

Vehicles or Equip. Used

2

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace



Date 7-14-10

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

SERVICE TRUCK W.O.

Jobs Completed

REPLACED VALVE BOXES + VALVE BOX LIDS  
**Ex. 6 (Personal Privacy)** AND AT LAURALKE +  
**Ex. 6 (Personal Privacy)** OLD LIDS + BOXES FROM SHOP

Employees on Job

F.P. - B.S. - G.F.

EXPOSED MAINS + VALVES IN PREP FOR  
VALVE INSTALL AT **Ex. 7f (Water Infra.)**

Vehicles or Equip. Used

OPENED CROSSTIE AT VIOLAT

11-14-BACKHOLE

**Sewer Department**

Address

TURNED ON BLUFF

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

T.C.

FINISHED  
21-22

Areas - Read

STARTED  
24

Vehicles Used

General Foreman

Frank J. Pace

Date 7-13-16

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address	SERVICE TRUCK. W.O.	
Jobs Completed	REPAIRED SERVICE LINE LEAK LAURALEE - USED TWO 3/4" P.V.C. BARB X 3/4" COMP. FITTINGS + 18" OF 3/4" COPPER TUBING BACKFILLED WITH 4 BACKHOLE BUCKETS ROCK	
Employees on Job	CUT & CAPPED 2" A.C. MAIN IN FRONT JUDITH - DUE TO MAIN COLLAPSING IN HOLE FROM EXTREME & ONE 4" CAP WITH P.V.C. NIPPLE	
Vehicles or Equip. Used	BLOCKED AGAINST EXISTING MAIN - BACKFILLED WITH SPOIL	
14 - BACKHOLE		

Ex. 6 (Personal Privacy)

Ex. 6 (Personal Privacy)

Ex. 6 (Personal Privacy)

Sewer Department	
Address	
Job Completed	
Employees on Job	
Vehicles or Equip. Used	

Meter Readers	
Employees on Job	T.C. FINISHED 20
Areas - Read	STARTED 22
Vehicles Used	

General Foreman Franky Pace



Date 7-12-16

Daily Job Sheet

Sheet      OF     **Water Department****Comments****Address**

SERVICE TRUCK W/O.  
RE-READS  
SWEEP SHOP

Ex. 6 (Personal Privacy)

**Jobs Completed**

DISCONTINUED SERVICE AT  
EXPOSED MAIN & TAP - SHUT OFF CORP. -  
REMOVED BOX & FILLED YARD WITH DIRT

**Employees on Job**

F.P. - B.S. - G.F. T.C.  
7 HR 1 HR

REPLACED CRUSHED PAPER BOX WITH NEW  
18" X 30" P.V.C. METER BOX AT  
BROUGHT HYDRANT THAT WAS BROKEN OFF INTO  
SHOP FROM

Ex. 6 (Personal Privacy)

Ex. 6 (Personal Privacy)

**Vehicles or Equip. Used**

14-11-8- Backhoe

**Sewer Department****Address**

FILLED IN HOLE IN ROAD AT  
BLUFF WITH 2" CLEAN ROCK

Ex. 7f (Water Infra.)

**Job Completed**

CLEANED FLOAT BALLS AT CENTREVILLE  
PUMPING HOLE - NOTICED  
WIRE NOT ON TOP OF STARTER IS STRIPPED

Ex. 6 (Personal Privacy)

**Employees on Job**

B.S. - F.P.  
1 HR

BELLEVUE WAS OUT - JIGGLED FLOAT BALLS  
TO GET PUMPING - LEFT BLUFF OFF

**Vehicles or Equip. Used**

14

**Meter Readers****Employees on Job**

T.C.  
7 HR

FINISHED  
14 & 18

**Areas - Read****Vehicles Used**

8

**General Foreman**

Frank J. Pace



Date 7-11-16

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address		SERVICE TRUCK W.O.
Jobs Completed		
Employees on Job F.P. 1/2 HR		
Vehicles or Equip. Used 11		
Sewer Department		
Address		JETTED LINE BEHIND TO RELIEVE ODOR PROBLEM. Ex. 6 (Personal Privacy)
Job Completed		CYCLED BLOWERS AT CYCLED PUMP AT Ex. 7f (Water Infra.) Ex. 6 Personal Privacy
Employees on Job F.P. - T.C. - B.S. 1.5 HR		TURNED ON BELLEVUE STATION
Vehicles or Equip. Used 2-14-9-3		
Meter Readers		
Employees on Job F.P. - T.C. 6.0 HR		FINISHED 13-T.C. - 17-F.P.
Areas - Read		STARTED 14-T.C.
Vehicles Used 2-8		
General Foreman		Frank J. Pace

Water Department		Comments
Address		WORK SERVICE TRUCK W.O.
Jobs Completed		
Employees on Job F.P		
Vehicles or Equip. Used 11		
Sewer Department		
Address		
Job Completed		BY-PASS PUMPED WITH 3" GAS PUMP AT <b>Ex. 6 (Personal Privacy)</b>
Employees on Job T.C.		CYCLED PUMP AT <b>Ex. 6 (Personal Privacy)</b> CYCLED BLOWERS AT <b>Ex. 7f (Water Infra.)</b> AND AT <b>Ex. 6 Personal Privacy</b>
Vehicles or Equip. Used 3		BELLEVUE OFF DUE TO E. ST. LOUIS NOT TAKING SEWAGE
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Rose</u>		

Water Department		Comments
Address		SERVICE TRUCK W.O.
Jobs Completed		SWEPT UP SHOP
Employees on Job F.P. B.S. 4HR 2HR		
Vehicles or Equip. Used  11		
Sewer Department		
Address		PULLED MOTOR AT Ex. 6 (Personal Privacy) INSTALLED MOTOR AT Ex. 6 Personal Privacy INSTALLED PULLEY ON MOTOR
Job Completed		WORKED ON BELLEVUE - INSTALLED NEW WIRE ON STARTER - LEFT OFF DUE TO E. ST. LOUIS NOT TAKING
Employees on Job B.S. 6HR		CYCLED PUMP AT Ex. 6 Personal Privacy
Vehicles or Equip. Used  14		
Meter Readers		
Employees on Job F.P. - T.C. 4HR		FINISHED 15 - F.P. - 11-12 - T.C.
Areas - Read		STARTED 13 - T.C.
Vehicles Used 2-8		
General Foreman Frank J. Pace		



Date 7-6-14

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

**Water Department****Comments**

Address

SERVICE TRUCK W.O.

Jobs Completed

Employees on Job

F.P.

Vehicles or Equip. Used

11

**Sewer Department**

Address

CHECKED STATIONS

MOTOR AT **Ex. 6 (Personal Privacy)** 15 OUT

Job Completed

CYCLED BLOWERS AT **Ex. 7f (Water Infra.)**CYCLED PUMP AT **Ex. 6 Personal Privacy**

Employees on Job

B.S.

BY-PASS PUMPED WITH 3" GAS PUMP AT **Ex. 6 (Personal Privacy)**

Vehicles or Equip. Used

3

CHANGED OIL IN 3" PUMP

**Meter Readers****Employees on Job****Areas - Read****Vehicles Used****General Foreman**

Franky Pace

Date 7-5-16

Daily Job Sheet

Sheet     of    **Water Department****Comments**

Address

SERVICE TRUCK W/O.  
LOCATES

Jobs Completed

Employees on Job

F.P.

Vehicles or Equip. Used

11

**Sewer Department**

Address

CHECKED FOR BACKUP AT **Ex. 6 (Personal Privacy)**  
CLEAN OUTS WHERE DOWN - BY-PASS PUMPED  
MAIN LINE

Job Completed

BY-PASS PUMPED WITH 3" GAS PUMP AT  
**Ex. 6 (Personal Privacy)** PILL BOX  
~~AT~~ CALVIN BLVD.

Employees on Job

T.C.

CYCLED BLOWERS AT OAKLAND + AT 73RD  
CYCLED PUMP AT **Ex. 6 Personal Privacy**

Vehicles or Equip. Used

3

**Meter Readers****Employees on Job****Areas - Read****Vehicles Used****General Foreman**

Frank Pace

Date 7-4-1962

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

**Sewer Department**

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. PaceH  
O  
L  
I  
D  
A  
YI  
N  
D  
E  
P  
E  
N  
D  
E  
N  
C  
EA  
Y



Date 7-1-16

Daily Job Sheet

Sheet      of     **Water Department****Comments****Address**

Service TRUCK WORK orders

**Jobs Completed****Employees on Job**

BS 4 HRS

**Vehicles or Equip. Used**

#11

**Sewer Department****Address**BY PASSED 71 ST BOTH LOCATIONS  
Ex. 6 (Personal Privacy) CALVIN  
CYCLED Ex. 6 (Personal Privacy) 73rd**Job Completed**

CHECKED STATIONS

**Employees on Job**

GF - BS

**Vehicles or Equip. Used**

#3 #11

**Meter Readers****Employees on Job**

T.C.

**Areas - Read**FINISHED 8  
FINISHED 9**Vehicles Used**

#8

**General Foreman**

B. Smith

Date 8-31-16

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

<u>Water Department</u>		Comments
Address		SERVICE TRUCK W.O.
Jobs Completed		
Employees on Job G.F. G.S.H.R.		
Vehicles or Equip. Used  11		
<u>Sewer Department</u>		
Address		REMOVED 6"X6"X4" TEE, 6" FLANGE X 6" M.S. FROM DISCHARGE LINE IN CAN AT SUPERIOR. REPLACED 6"X6"X4" TEE, 6" FLANGE X 8" LONG TAIL 6" SOLID SLEEVE, TWO M.S. PACKS, 2-6" GASKETS
Job Completed		ONE 4" GASKET - PUMPING NOW REPAIRED CORD HOLDING DISCHARGE LINE HIT BY MOWER AT <b>Ex. 7f (Water Infra.)</b>
Employees on Job T.C. - F.P. - B.S. - G.F. JHR 1.5 HR		CYCLED BELLEVUE, CYCLED BLOWERS AT OAKLAND & <b>Ex. 7f (Water Infra.)</b> PUMPED/DIPPED OUT CAN A. <b>Ex. 6 (Personal Privacy)</b>
Vehicles or Equip. Used  2-14-11		RV PACE DUMPED WITH 3" GAS PUMP AT <b>Ex. 7f (Water Infra.)</b> <b>Ex. 6 (Personal Privacy)</b> ON HAND PUMPED DOWN
<u>Meter Readers</u>		
Employees on Job T.C. G.H.R.		FINISHED 17 & 18
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		

Date 8-30-16

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address

SERVICE TRUCK W.O. - SHUT OFFS

Jobs Completed

Employees on Job

G.F.

Vehicles or Equip. Used

11

Sewer Department

Address

PUMPED DOWN Ex. 6 (Personal Privacy) ON HAND  
WORKED FLOATBALLS & CHECKED PANEL WIRES  
BUT PUMP WON'T SHUT OFF ON AUTO - OFF AT POLE

Job Completed

WORKED FLOATBALLS MANUALLY AT BELLVIEW  
WELL WAS DOWN & CYCLING

Employees on Job

F.P. - B.S.

REMOVED FLAPPER, BROKE BOLTS LOOSE & CHECKED  
TO SEE IF DISCHARGE WILL DRAIN INTO WELL IN  
PREP FOR M.J. REPLACEMENT JOB AT SUPERIOR

Vehicles or Equip. Used

14

Meter Readers

Employees on Job

T.C.

FINISHED

13 &amp; 15

Areas - Read

STARTED

17

Vehicles Used

8

General Foreman

Frank J. Pace



Date 8-29-16

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address	SERVICE TRUCK W.O. <u>LOCATED</u>	
Jobs Completed		
Employees on Job G.F. - F.P. 4 HR 2 HR		
Vehicles or Equip. Used 11-2		
Sewer Department		
Address	BY-PASS PUMPED WITH 3" CAS PUMP AT Ex. 6 (Personal Privacy) LAKE PILL BOX PUMPED Ex. 6 (Personal Privacy) ON HAND	
Job Completed	CYCLED BLOWERS AT OAKLAND Ex. 6 (Personal Privacy) SHUT OFF Ex. 6 (Personal Privacy) AT POLE DUE TO IT WONT SHUT OFF AUTOMATICALLY	
Employees on Job B.S. - F.P. 2 HR	PULLED BACK OFF PUMP & CLEANED OUT MOP HEAD AT Ex. 6 (Personal Privacy) CAUSING BACK UPS AT Ex. 6 (Personal Privacy)	
Vehicles or Equip. Used 14-3		
Meter Readers		
Employees on Job	FINISHED 11 & 12 - T.C. 14 - F.P.	
Areas - Read	STARTED 13 - T.C. 15 - G.F.	
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		

Date 8-26-16

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address	<u>SERVICE TRUCK N.O.</u> <u>RE-READS</u>	
Jobs Completed	REBUILT SERVICE AT <span>Ex. 6 (Personal Privacy)</span> APT. A - USED ONE 5/8" BARB X 1/2" I.P. FITTING, ONE 1/2" X 3/4" BUSHING ONE 3/4" X I.P. X 3/4" COMP. FITTING, ONE METER COUPLING, 7' OF 3/4" COPPER TUBING, RE-USED BOX, RING & LID	
Employees on Job F.P. - B.S. - T.C. 2 HR	REPLACED SHUT OFF & GALVANIZED BACKSIDE AT <span>Ex. 6 (Personal Privacy)</span> CRIMPED LINE, REPLACED SHUT OFF. USED ONE 1/2" I.P. X 3/4" COMP. FITTING, ONE METER COUPLING 3' OF COPPER, 18" X 30" METER BOX	
Vehicles or Equip. Used  8-14-BACKHOC		
Sewer Department		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT <span>Ex. 6 (Personal Privacy)</span> PILL BOX	
Job Completed	CYCLED BLOWERS AT OAKLAND AND AT <span>Ex. 7f (Water Infra.)</span>	
Employees on Job T.C. 6 HR	RESET BREAKER AT BELLEVUE TWICE A.M. & P.M.	
Vehicles or Equip. Used  3		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Franky Pace</u>		

Date 8-25-16

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O. LOCATES RE-READS	
Jobs Completed		
Employees on Job F.P. - G.F.		
Vehicles or Equip. Used 2-11		
<u>Sewer Department</u>		
Address	CHECKED STATIONS - RESET BREAKER AT BELL VIEW, TWICE A.M. & P.M. - PULLING 24 AMPS THE REST OF STATIONS GOOD	
Job Completed		
Employees on Job B.S. - T.C.	BY-PASS PUMPED WITH 3" GAS PUMP AT PILL BOX	
Vehicles or Equip. Used 3-14		
<u>Meter Readers</u>		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman	Frank J. Pace	



Water Department		Comments
Address		SERVICE TRUCK W.O. LOCATES
Jobs Completed		
Employees on Job G.F. F.P. 2HR		
Vehicles or Equip. Used 2-11		
Sewer Department		
Address		PULLED PUMP & CLEANED OUT RAGS AT Ex. 6 Personal Privacy STATION - PUMPING NOW
Job Completed		INSTALLED PUMP FROM IL-MO BEHIND Ex. 6 Personal Privacy PUMPING NOW - INSTALLED NEW S.S. CHAIN ON PUMP - PUT PALLET OVER MANHOLE TO REPLACE BROKEN LID
Employees on Job F.P. - B.S. - T.C. 6HR 5HR		CHECKED STATIONS ON NORTH END - BECEVIEW KICKED OUT BREAKER - RESET TWICE AM & P.M. CHECKED FOR ODOR ON SUPERIOR - ONLY ODOR WAS AROUND TREATMENT PLANT - NOT OURS
Vehicles or Equip. Used 2-14-3-BACKHOL		BY-PASS PUMPED WITH 3" GAS PUMP AT Ex. 6 Personal Privacy BEHIND Ex. 6 Personal Privacy
Meter Readers		
Employees on Job T.C. 3HR		FINISHED 9
Areas - Read		
Vehicles Used 8		
General Foreman <u>Frank J. Pace</u>		

Water Department

Comments

Address	REPAIRED MAIN BREAK BEHIND Ex. 6 (Personal Privacy) - USED ONE 6" X 4" M. T. RAFTER 40" OF C-900 6" P.V.C. PIPE, ONE 6" 501 EXTREME DRESSER, ONE BACKHOE BUCKET OF ROCK FROM SHOP
Jobs Completed	
Employees on Job	F.P. - B.S. 4 HR 4 HR
Vehicles or Equip. Used	14 - BACKHOE

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT BEHIND Ex. 6 (Personal Privacy)
Job Completed	BY-PASS PUMPED, WORKED CHECK ON PUMP 2 TOOK PLATE OFF CHECK ON PUMP 1 & CLEANED OUT SAND & DEBRIS, BOTH PUMPS PUMPING ON HAND
Employees on Job	G.F. - F.P. - B.S. 4 HR
Vehicles or Equip. Used	14-3 - BACKHOE

Meter Readers

Employees on Job	G.F. 4 HR	READ METERS IN AREA 9
Areas - Read		
Vehicles Used	8	

General Foreman

Frank J. Pace

Date 8-22-16

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed	CRIMPED OFF SERVICE LINE OUTSIDE WATER BOX AT <b>Ex. 6 (Personal Privacy)</b>	
Employees on Job F.P. - B.S.	EXPOSED SEWER LATERAL & FOLLOWED TO SEPTIC TANK - NO LINE COMING OUT OF TANK TO MAIN AT <b>Ex. 6 (Personal Privacy)</b>	
Vehicles or Equip. Used 14 - BACKHOLE		
<u>Sewer Department</u>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT <b>Ex. 6 (Personal Privacy)</b> PICE BOX, BEHIND	
Job Completed	CYCLED BLOWERS AT OAKLAND & AT <b>Ex. 7f (Water Infra.)</b>	
Employees on Job G.F.	BREAKER AT BELLEVIEW KICKED OUT - RE-SET BREAKER TWICE - A.M. & P.M. WELL STILL UP	
Vehicles or Equip. Used 3		
Meter Readers		
Employees on Job T.C.	FINISHED 648	
Areas - Read	STARTED 9	
Vehicles Used 8		
General Foreman	Frank J. Pace	



Date 8-19-16

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

<u>Water Department</u>		Comments
Address	WORK ORDERS	
Jobs Completed		
Employees on Job	GF	
Vehicles or Equip. Used	#11	
<u>Sewer Department</u>		
Address	Ex. 6 (Personal Privacy) Pulled Pump out for Repair and Pumped Down	
Job Completed	ALSO BY PASSED 71ST- CYCLED BLOWERS	
Employees on Job		
Vehicles or Equip. Used		
<u>Meter Readers</u>		
Employees on Job	TC	
Areas - Read	FINISHED 3-5 STARTED 6	
Vehicles Used	8	
General Foreman	B. Lenz	

Water Department		Comments
Address	#11 work orders	
Jobs Completed		
Employees on Job	BS GF	
Vehicles or Equip. Used	#3 #11	
Sewer Department		
Address	Ex. 6 (Personal Privacy) By PASSED these 4 SPOTS WITH 3" Pump	
Job Completed	TURNED ON Cycled 73rd ST Ex. 7f (Water Infra.)	
Employees on Job	BS- GF	
Vehicles or Equip. Used	3- 11	
Meter Readers		
Employees on Job	TC	
Areas - Read	#4 - #7 FINISHED STARTED #3	
Vehicles Used	8	
General Foreman	B. Linn	

Date 8-17-16

## Daily Job Sheet

Sheet 1 of 1Water Department

## Comments

Address

Service TRUCK WORK orders  
8 HRS

Jobs Completed

Employees on Job

G.F

Vehicles or Equip. Used

11

Sewer Department

Address

Cycled Blowers AT 73rd - Re-set  
STARTER AT 63rd - TRIED TO RUN  
Bellevue BUT ESTL NOT TAKING

Job Completed

Checked SOME STATIONS  
DRILLED HOLES AT Ex. 6 Personal Privacy FOR  
WIRES

Employees on Job

BS

Vehicles or Equip. Used

3

Meter Readers

Employees on Job

TC

FINISHED 30  
FINISHED 1 + 2 + 25 + 16 + 10

Areas - Read

STARTED AREA 4

Vehicles Used

8

General Foreman

B. Smith



Water Department		Comments
Address	Service TRUCK work orders 8 HRS	
Jobs Completed		
Employees on Job	GF	
Vehicles or Equip. Used	11	
Sewer Department		
Address	TURNED ON STATION + checked ON 73rd ST STATION- LEFT OFF	
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
Meter Readers		
Employees on Job	BS-TC	
Areas - Read	Finished 29 11 27 STARTED 30 STARTED 1	
Vehicles Used	3- 8	
General Foreman	B. Linn	

Date 8-15-16

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	Service TRUCK 2 HRS	
Jobs Completed		
Employees on Job GF		
Vehicles or Equip. Used #11		
<u>Sewer Department</u>		
Address	BY PASSED TEST - Pick Box DAN BLOWERS - TURNED OFF Bellevue AMES	
Job Completed	Checked STATIONS	
Employees on Job BS-GF-TC		
Vehicles or Equip. Used #14		
Meter Readers		
Employees on Job BS-GF		
Areas - Read #10 STARTED #29		
Vehicles Used 14		
General Foreman	B. Smith	

Date 8-12-16

Daily Job Sheet

Sheet 1 of 1

Water Department		Comments
Address		Service TRUCK WORK orders 6 HRS
Jobs Completed		
Employees on Job	GF	
Vehicles or Equip. Used	#11	
Sewer Department		
Address	Ex. 6 (Personal Privacy)	SET BOTH PUMPS IN WELL CLEANED BRUSH AWAY FROM FENCE
Job Completed		ALSO BY PASSED Ex. 6 (Personal Privacy) JUDITH AND TIST ALSO TURNED BLOWERS ON
Employees on Job	BS - GF - TC - GF	MOVED WIRES TO OTHER 40 AMP BREAKER AT BELLEVUE
Vehicles or Equip. Used	#3 - 14 - 2 - 11	
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman	B. Daniel	



Date 8-11-16

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address		SERVICE TRUCK W.O.
Jobs Completed		REPLACED BROKEN SHUT OFF & BROKEN PAPER BOX AT [REDACTED] - USED ONE THREADED METER SHUT OFF & ONE 18"X30" P.V.C. METER BOX - BACKFILLED WITH SAIL
Employees on Job G.F. F.P. - B.S. - T.C. 4HR 2HR 4HR		CLEANED WEEDS & BRUSH FROM AROUND HYDRANT ACROSS FROM [REDACTED] Ex. 6 (Personal Privacy)
Vehicles or Equip. Used		
11-2-14 - BACKHOE		
<u>Sewer Department</u>		
Address		40 AMP TRIPLE BREAKER BELLEVUE BREAKER KICKED OUT TWICE RESET TWICE - NOTICED WIRES LOOSE ON MAIN BREAKER & TIGHTENED ADDED OIL TO BLOWER
Job Completed		CHECKED [REDACTED] CLINTON - BOTH GOOD - CHECKED PARKFIELD PUMPS TRENOIS PUMP - ALL GOOD
Employees on Job F.P. - B.S. 2HR		
Vehicles or Equip. Used		
2		
Meter Readers		
Employees on Job F.P. - B.S. T.C. 2HR 4HR		FINISHED 19 - B.S. & F.P. 24 - T.C.
Areas - Read		
Vehicles Used		
2-8		
General Foreman		Frank J. Rose

Date 8-10-10

Daily Job Sheet

Sheet     of    **Water Department****Comments**

Address

SERVICE TRUCK W.D.  
RE-READS  
LOCATES

Jobs Completed

Employees on Job

G.F. - F.P.  
GKR

Vehicles or Equip. Used

2-11

**Sewer Department**

Address

RY-PASS PUMPED WITH 3" GAS PUMP AT  
Ex. 7f (Water Infra.) ALL BOX

Job Completed

CYCLED RIGGERS AT OAKLAND AND AT  
Ex. 6 (Personal Privacy)

Employees on Job

B.S.  
GKRCHECKED STATIONS ON NORTH END  
GOOD - BELLEVUE BREAKER NICKED  
OUT IN MORNING & AFTERNOON - BLUFA OFF

Vehicles or Equip. Used

3

**Meter Readers**

Employees on Job

F.P. - B.S.  
2 HR T.C.STARTED  
19 - F.P. & B.S. 24 - T.C.

Areas - Read

FINISHED  
22 & 26 - T.C.

Vehicles Used

8

General Foreman

Frank J. Pace



Date 8-9-16

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

SERVICE TRUCK W.O.

Jobs Completed

REBUILT SERVICE AT **Ex. 6 Personal Privacy** - USED  
ONE  $\frac{3}{4}$ " I.P. x  $\frac{3}{4}$ " COMP., ONE METER COUPLING, ONE  
METER SHUT OFF, ONE  $\frac{3}{4}$ " x  $\frac{3}{4}$ " COMP. FITTING, ONE  
18" x 30" P.V.C. METER BOX, 18' OF  $\frac{3}{4}$ " COPPER  
BACKFILLED WITH SOIL

Employees on Job

F.P. - B.S. G.F.  
4 HR 6 HR

Vehicles or Equip. Used

14-11-BACKHOE

**Sewer Department**

Address

INSTALLED TWO FLOATBALLS AND ONE  
STARTER AT **Ex. 6 (Personal Privacy)** M.P.E.D  
DOWN WELL ON HAND FIRST

Job Completed

CYCLED BLOWERS AT OAKLAND AND AT  
73RD **Ex. 6 (Personal Privacy)**

Employees on Job

F.P. - B.S. G.F.  
4 HR 2 HR

Vehicles or Equip. Used

3-14

BY-PASS PUMPED WITH 3" GAS PUMP AT  
JUDITH **Ex. 6 (Personal Privacy)**

Meter Readers

Employees on Job

T.C.

STARTED  
22

Areas - Read

FINISHED  
20 + 21 + 23

Vehicles Used

8

General Foreman

Frank J. Pace



Date 8-8-16

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

SERVICE TRUCK W/O.

Jobs Completed

REPAIRED 2" C.T. MAIN BREAK A FALLING SPRINGS ROAD ON WALNUT - USED ONE 8" x 2" S.S. REPAIR CLAMP &amp; C.M. 6 ROCK FROM SHOP

Ex. 6 (Personal Privacy)

Employees on Job

F.P. - B.S. - T.C. - G.F.  
3.5 HR

Vehicles or Equip. Used

6-14 - BACKHOE - 11

**Sewer Department**

Address

CHECKED FLOATBALLS AT MANUALLY PUMPED DOWN WELL ON HAND. FLOATBALLS ARE BAD &amp; STARTER NEEDS REPLACED

Ex. 6 (Personal Privacy)

Job Completed

REPLACED HOSE &amp; DISSASSEMBLED CHECK VALVE TO CLEAN AIR LINE AT BELL VIEW - PUMPING NOW.

Employees on Job

F.P. - B.S. - T.C.  
4.5 HR

BY-PASS PUMPED WITH 3" PUMP AT

Ex. 7f (Water Infra.)

PILL BOX

CYCLED BLOWERS AT OAKLAND

Ex. 6 (Personal Privacy)

Vehicles or Equip. Used

JETTED LATERAL TO RELIEVE BACKUP AT

Ex. 6 (Personal Privacy)

2-14-3-9

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 8-8-16

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

**Water Department****Comments**

Address

CALL OUT O.T.

Jobs Completed

SHUT OFF BRANCH VALVE TO HYDRANT  
BY OUR METER PIT AT FRESH WAREHOUSE  
FOR CHURCH R.

Ex. 6 (Personal Privacy)

Employees on Job

F.P.

Vehicles or Equip. Used

2

**Sewer Department**

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Rice

Date 8-5-16

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address

SERVICE TRUCK W.O.  
LOCATES

Jobs Completed

Employees on Job

G.F. - F.P.  
3 PR

Vehicles or Equip. Used

2-11

Sewer Department

Address

CHECKED STATIONS - **Ex. 6 (Personal Privacy)** WAS  
KICKING ON & OFF - TURNED OFF PUMP - LAURKEE  
**Ex. 6 (Personal Privacy)** MAIN BREAKER WAS DISCONNECTED -  
CONNECTED BREAKER & PUMPING NOW - REPAIRS O.K.

Job Completed

BY-PASS PUMPED WITH 3" GAS PUMP AT

**Ex. 6 (Personal Privacy)**

Employees on Job

T.C.

CYCLED BLOWERS AT OAKLAND **Ex. 6 (Personal Privacy)**  
BELLEVUE BREAKER KICKED OUT THIS MORNING  
BLOWER DOESN'T SEEM TO BE MAKING AIR -  
TURNED OFF

Vehicles or Equip. Used

2-3

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pae



Date 8-4-16

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

SERVICE TRUCK W.D.

LOCATES

RE-READS

Jobs Completed

CYCLED BLOWERS AT OAKLAND

Ex. 6 (Personal Privacy)

TO RELIEVE BACKUP AT

Ex. 6 (Personal Privacy)

BREAKER KICKED OUT AT BELLEVUE - RE SET

Employees on Job

F.P. - G.F.  
W  
JHR

INSTALLED ANTENNAS

Vehicles or Equip. Used

2-11

**Sewer Department**

Address

Job Completed

Employees on Job

T.C.  
JHRBY-PASS PUMPED WITH 3" GAS PUMP AT  
CALVIN BLVD.

Vehicles or Equip. Used

3

Meter Readers

Employees on Job

T.C. - G.F.  
W  
JHR

FINISHED

13414 - T.C. 18 - G.F.

Areas - Read

Vehicles Used

2-8

General Foreman

Frank J. Pace

Date 8-3-16

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address

SERVICE TRUCK W.O.  
LOCATED

Jobs Completed

CHECKED PRESSURE AT  
BROKE BACKSIDE OF METER & CHECKED WITH  
CUSTOMER PRESENT - GOOD PRESSURE THROUGH  
METER.

Ex. 6 (Personal Privacy)

Employees on Job

F.P. - G.F.  
1.5

Vehicles or Equip. Used

2 - 11

Sewer Department

Address

Job Completed

BY-PASS PUMPED WITH 3" GAS PUMP AT

Ex. 6 (Personal Privacy)

Employees on Job

T.C.

CYCLED BLOWERS AT OAKLAND AND AT

Ex. 7f (Water Infra.)

Vehicles or Equip. Used

3

Meter Readers

Employees on Job

G.S. F.P.

FINISHED  
15417

Areas - Read

Vehicles Used

2

General Foreman

Frank J. Pace

Date 8-2-16

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

**Water Department****Comments**

Address

SERVICE TRUCK W.O.

Jobs Completed

SWAPT SHOP

Employees on Job

F.P. - G.F. - T.C.  
4HR 6HR 2HR

Vehicles or Equip. Used

2-11

**Sewer Department**

Address

PUMPED & DIPPED OUT WATER FROM CAN  
Ex. 7f (Water Infra.) TURNED ON Ex. 7f (Water Infra.)  
BLUFF STILL OFF

Job Completed

Employees on Job

F.P. - G.F.  
2HR 2HR

Vehicles or Equip. Used

11-14

Meter Readers

Employees on Job

T.C. - F.P.  
2HR 3HRFINISHED  
11-12 T.C.

Areas - Read

STARTED  
15-F.P. - 14-T.C.

Vehicles Used

2-8

General Foreman

Frank J. Pace



Date 8-1-16

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

SERVICE TRUCK W.O.  
LOCATES

Jobs Completed

Employees on Job

F.P.-T.C.  
GHR

Vehicles or Equip. Used

2-1

**Sewer Department**

Address

VACUUMED OUT WELL AT Ex. 6 Personal Privacy  
CHECKED STATIONS - BELLEVUE OFF DUE  
TO E. ST. LOUIS - BLUFF OFF

Job Completed

DUMPED Ex. 6 Personal Privacy  
CYCLED BLOWERS AT Ex. 7f (Water Infra.)

Employees on Job

G.F. - F.P.-T.C.  
DHR

Vehicles or Equip. Used

2-3-9

RV PUMP PUMPED WITH 2" GAS PUMP AT

Ex. 7f (Water Infra.)

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 9-30-16

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address		SERVICE TRUCK W/O.
Jobs Completed		FILLED IN ROAD WHERE PULL WAS MADE Ex. 6 (Personal Privacy) HAULED OFF SPOIL USED ONE LOAD CLEAN ROCK FROM QUARRY
Employees on Job F.P. - B.S. - T.C. G.F. 4 HR 2 HR		HAULED OFF SPOIL WHERE LEAK WAS REPAIRED AT Ex. 6 (Personal Privacy)
Vehicles or Equip. Used 11-6-BACKHOLE		
<b>Sewer Department</b>		
Address		JETTED LINE TO RELIEVE BACKUP AT Ex. 6 (Personal Privacy) - JETTED LINE ON BATHS
Job Completed		JETTED LINE TO RELIEVE BACKUP AT Ex. 6 (Personal Privacy) - OUR LINE DOWN & COST, STILL HAS PROBLEM
Employees on Job F.P. - B.S. G.F. 2 HR 4 HR 6 HR		RYDACE PUMPED WITH 3" GAS PUMP AT PILL BOX, Ex. 7f (Water Infra.)
Vehicles or Equip. Used 9-3-8		CYCLER BLOWERS AT Ex. 7f (Water Infra.) CYCLER Ex. 6 (Personal Privacy) BELLEVUE & BLUFF ON CYCLING
<b>Meter Readers</b>		
Employees on Job F.P. G.F. 2 HR		FINISHED 18
Areas - Read		
Vehicles Used 8		
General Foreman <u>Frank J. Puel</u>		



Water Department		Comments
Address		SERVICE TRUCK W/O.
Jobs Completed		PULLED NEW LINE UNDER ROAD AT Ex. 6 (Personal Privacy) USED 30' OF 3/4" COPPER TUBING, ONE 3/4" FLARE X 3/4" COMP. FITTING,
Employees on Job F.P. - B.S. - G.F.		ONE 3/4" X 3/4" COMP. FITTING
Vehicles or Equip. Used 2-14 - BACKHOLE		
Sewer Department		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
Meter Readers		
Employees on Job T.C.		FINISHED 15 + 17
Areas - Read		STARTED 18
Vehicles Used 8		
General Foreman		Frank J. Pace



Date 9-28-16

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W.O. LOCATES - F.P.-B.S.
Jobs Completed	
Employees on Job G.F. GHR	
Vehicles or Equip. Used 2-11	

Sewer Department

Address	INSTALLED 12' 3" OF 10" P.V.C. SEWER MAIN INTO DISCHARGE M.H. FROM BELLEVIEW USED ONE 10" CONCRETE X 10" P.V.C. FERNCO FITTING, TWO BUCKETS OF HYDRAULIC CEMENT, ONE B.O.L.B.
Job Completed	BAG OF GROUT (TOPPING MIX), ONE DUMP TRUCK LOAD OF CLEAN ROCK, BLOCKING UNDER MAIN BACKFILLED WITH SPOIL
Employees on Job F.P.-B.S. T.C. GHR	FOUND LEAK ON JET HOSE ABOUT 15' FROM WHERE HOSE CONNECTS TO SPOOL ON TRUCK
Vehicles or Equip. Used 14-9-6-BACKHOC	

Meter Readers

Employees on Job G.F. T.C. GHR	FINISHED 13-G.F. 14-T.C.
Areas - Read	STARTED 15-T.C.
Vehicles Used 8	

General Foreman

Frank J. Pace

Date 9-27-16

Daily Job Sheet

Sheet      of     

<u>Water Department</u>	<u>Comments</u>
-------------------------	-----------------

Address	SERVICE TRUCK W.O. LOCATHS-F.P.
Jobs Completed	
Employees on Job G.F.	
Vehicles or Equip. Used 11	

<u>Sewer Department</u>	<u>Comments</u>
-------------------------	-----------------

Address	CHIPPED OUT CONCRETE SEWER MAIN FROM MANHOLE IN <span style="background-color: black; color: red;">Ex. 6 (Personal Privacy)</span> BELLEVUE STATION
Job Completed	
Employees on Job F.P. - B.S.	
Vehicles or Equip. Used 2-14-BACKHOE	

<u>Meter Readers</u>	<u>Comments</u>
----------------------	-----------------

Employees on Job T.C.	FINISHED 11-12
Areas - Read	STARTED 13
Vehicles Used 8	

General Foreman <u>Frank J. Pace</u>	
--------------------------------------	--

Date 9-26-16

Daily Job Sheet

Sheet      of     

**Water Department** **Comments**

Address	SERVICE TRUCK W.O.
Jobs Completed	CHECKED SOME STATIONS ON SOUTH END
Employees on Job F.P.	
Vehicles or Equip. Used 11	

**Sewer Department**

Address	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT <b>Ex. 7f (Water Infra.)</b> RILL BOX, BLVD.
Employees on Job T.C.	CYCLED BLOWERS AT OAKLAND <b>Ex. 7f (Water Infra.)</b> CYCLED PUMP AT <b>Ex. 6 (Personal Privacy)</b>
Vehicles or Equip. Used 3	

Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman Frank J. Pace



Date 9-25-16

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

**Water Department**

**Comments**

Address

CALL OUT - DOUBLE TIME

Jobs Completed

LOCATED LINKS AT **Ex. 7f (Water Infra.)**  
FOR AMEREN - POLE REPLACEMENT

Employees on Job

F.P.

Vehicles or Equip. Used

2

**Sewer Department**

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 9-23-16

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address		SERVICE TRUCK W/O.
Jobs Completed		CHECKED FOR SEWER BACKUP AT [REDACTED] CYNTHIA - OUR LINES ARE DOWN & FLOWING CUST. PROBLEM - NO ONE HOME
Employees on Job F.P. 6 PR		MET WITH CUST. AT [REDACTED] EXPLAINED WHERE OUR SEWER MAIN IS
Vehicles or Equip. Used 11		

Sewer Department		
Address		
Job Completed		BY-PASS PUMPED WITH 3" GAS PUMP AT [REDACTED] EX. 7f (Water Infra.)
Employees on Job T.G.		CYCLED BLOWERS AT [REDACTED] EX. 7f (Water Infra.) CYCLING PUMPS AT [REDACTED] EX. 6 (Personal Privacy)
Vehicles or Equip. Used 3		

Meter Readers		
Employees on Job F.P. 2 PR		FINISHED 7
Areas - Read		PUMPED OUT BOXES & READ METERS IN AREA 9
Vehicles Used 8		
General Foreman		Frank J. Pace

Date 9-22-14

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

**Water Department****Comments**

Address	SERVICE TRUCK W/O.
Jobs Completed	CONNECTED PIG TAIL OUTSIDE BOX TO NEW WATER LINE AT <b>Ex. 6 (Personal Privacy)</b> USED ONE 3/4" X 3/4" COMP. FITTING
Employees on Job F.P.	
Vehicles or Equip. Used 11 - BACKHOE	

**Sewer Department**

Address	
Job Completed	BY-PASS DUMPED WITH 3" GAS PUMP AT <b>Ex. 7f (Water Infra.)</b>
Employees on Job T.C. JMR	
Vehicles or Equip. Used 3	

**Meter Readers**

Employees on Job T.C. GMR	FINISHED 9
Areas - Read	STARTED 7
Vehicles Used 8	

General Foreman

Franky Pace



Date 9-21-16

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address

SERVICE TRUCK W.O.

Jobs Completed

REPAIRED 6" A.C. MAIN BREAK UNDER  
PRESSURE - USED ONLY 6" S.S. REPAIR  
CLAMP AT

Ex. 6 (Personal Privacy)

Employees on Job

F.P. - B.S. - G.F.  
4 HR

Vehicles or Equip. Used

14-11- BACKHOC

Sewer Department

Address

TRIED TO JET DISCHARGE LINE FROM  
BELLEVIEW STATION - COULDN'T GET THROUGH  
EXPOSED 10" CONCRETE SEWER LINE ~

Job Completed

TOOK OUT 13' OF SEWER LINE & REMOVED  
ROOTS FROM LINE

Employees on Job

F.P. - B.S. - T.C.  
4 HR 2 HR

Vehicles or Equip. Used

14-9- BACKHOC

Meter Readers

Employees on Job

G.H.R.  
T.C.FINISHED  
6 & 8

Areas - Read

STARTED  
9

Vehicles Used

8

General Foreman

Franky Pace

Date 9-20-16

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address		SERVICE TRUCK W.O.
Jobs Completed		
Employees on Job	G.F.	
Vehicles or Equip. Used	11	
<b>Sewer Department</b>		
Address		WORKED WITH E. ST. LOUIS CREW TO JET LINES ON 82ND ST FROM OUR STATION M.H. TO THEIR LINE/M.H.
Job Completed		CLEARED ALLEY OF TREES & DEBRIS TO LOCATE OUR MANHOLE AT BELLVIEW STATION - TRIED TO GET CAP OFF EDUCTOR
Employees on Job	F.P. - B.S.	BUT COULD NOT.
Vehicles or Equip. Used	14- BACKHOLE	CYCLED BLOWERS AT <b>Ex. 7f (Water Infra.)</b> CYCLED PUMP AT <b>Ex. 6 (Personal Privacy)</b>
Meter Readers		
Employees on Job	T.C.	FINISHED 5
Areas - Read		STARTED 6
Vehicles Used	8	
General Foreman	Franky Pace	



Date 9-19-16

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

Water Department		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed		
Employees on Job G.F.		
Vehicles or Equip. Used 11		
<b>Sewer Department</b>		
Address	VACUUMED WET WELL AT FOR CENTREVILLE CHECKED STATIONS BY-PASS PUMPED WITH 3" GAS PUMP AT PILL BOX, CYCLED BLOWERS AT OAKLAND CYCLED PUMPS AT BELLEVIEW PUMPING, BUT ALOT OF BLOW BACK - BLUFF OFF - SHUT BELLEVIEW OFF AT END OF DAY	
Job Completed	Ex. 7f (Water Infra.) Ex. 6 (Personal Privacy)	
Employees on Job B.S. F.P. - T.C. 5 HR	Ex. 7f (Water Infra.) Ex. 6 (Personal Privacy)	
Vehicles or Equip. Used 3-2-9		
<b>Meter Readers</b>		
Employees on Job T.C. 3 HR	STARTED 5	
Areas - Read	FINISHED 3	
Vehicles Used		
General Foreman	Frank J. Pace	



Water Department		Comments
Address	SERVICE TRUCK W.O. RE READS LOCATES	
Jobs Completed		
Employees on Job	G.F. ~ F.P. JMR	
Vehicles or Equip. Used	11 - 2	
Sewer Department		
Address	CHECKED STATIONS BELLEVUE & BLUFF OFF DUE TO RAIN & BACKUP - E. ST. LOUIS NOT TAKING	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT PILL BOX	
Employees on Job	CYCLED BLOWERS AT OAKLAND CYCLED PUMPS AT	
Vehicles or Equip. Used	3 - 14	
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman Frank J. Pace		

Date 9-15-16

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	<u>SERVICE TRUCK W.O.</u> <u>LOCATING</u>	
Jobs Completed	REPLACED BROKEN SHUT OFF AT CRIMPED LINE OUTSIDE BOX & REPLACED METER SHUT OFF.	
Employees on Job	G.P. - <u>F.P. - B.S.</u> 4 HR	
Vehicles or Equip. Used	11-14-BACKHOE	
<u>Sewer Department</u>		
Address	REPLACED BROKEN AIR LINE AT BELLEVUE USA ONE 10' PIECE OF 2" CONDUIT & 40' OF 2" GALVANIZED PIPE & ONE 2" SS. REPAIR CLAMP	
Job Completed	BACK FILLED AROUND AIR LINE WITH ROCK STILL NEED TO DRESS UP ROAD PUMPED OUT WATER FROM CANS AT BLUFF & BELLEVUE	
Employees on Job	F.P. - B.S. 4 HR	
Vehicles or Equip. Used	14-BACKHOE	
Meter Readers		
Employees on Job	FINISHED 10-4 T.C.	
Areas - Read	STARTED 3	
Vehicles Used	8	
General Foreman	<u>Frank Pace</u>	

Ex. 6 (Personal Privacy)

Date 9-14-16

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

<u>Water Department</u>		Comments
Address		SERVICE TRUCK W.O.
Jobs Completed		
Employees on Job G.F.		
Vehicles or Equip. Used 11		
<u>Sewer Department</u>		
Address		EXPOSED & REPAIRED CONDUIT, PULLED NEW FLOATBALLS & WIRED INTO PANEL AT BELLEVUE
Job Completed		EXPOSED AIR LINE & REMOVED BAD SECTION OF PIPE. NEED MORE 8" PIPE TO COMPLETE JOB AT BELLEVUE
Employees on Job F.P. - B.S.		
Vehicles or Equip. Used 14 - BACKHOLE		
<u>Meter Readers</u>		
Employees on Job T.C.		1-2-25-27-30-46 FINISHED
Areas - Read		
Vehicles Used 8		
General Foreman <u>Franky Pace</u>		



Date 6-13-14

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed		
Employees on Job G.F.		
Vehicles or Equip. Used 11		
<u>Sewer Department</u>		
Address	HELPED CENTREVILLE VACUUM OUT WELL AT <b>Ex. 6 (Personal Privacy)</b>	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT CALVIN BLVD.	
Employees on Job F.P.-B.S., T.C., 2HR 6HR	CYCLED PUMP AT <b>Ex. 6 (Personal Privacy)</b> CYCLED BLOWERS AT OAKLAND <b>Ex. 7f (Water Infra.)</b>	
Vehicles or Equip. Used 14-9-3		
<u>Meter Readers</u>		
Employees on Job T.C. F.P.B.S., 2HR 6HR	FINISHED 29 F.P.B.S.	
Areas - Read	STARTED 16 T.C.	
Vehicles Used 14-8		
General Foreman <u>Frank J. Pace</u>		

Water Department		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed		
Employees on Job G.F.		
Vehicles or Equip. Used 11		
Sewer Department		
Address	REPLACED 2 FLOAT BALLS AT [Redacted] Ex. 6 (Personal Privacy)	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT [Redacted] Ex. 7f (Water Infra.) RILL BOX	
Employees on Job T.C. 1 HR F.P.-B.S. 2 HR	CYCLED BLOWERS AT OAKLAND [Redacted] Ex. 6 (Personal Privacy) CYCLED PUMP AT [Redacted] Ex. 6 (Personal Privacy)	
Vehicles or Equip. Used 3-14		
Meter Readers		
Employees on Job T.C. 2 HR B.S. 4 HR F.P. 6 HR	STARTED 29	
Areas - Read		
Vehicles Used 14		
General Foreman Frank J. Pace		

Date 9-9-16

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

**Water Department**

**Comments**

Address

CALL OUT 2HR OVERTIME

Jobs Completed

SHOT OFF BRANCH VALVE TO HYDRANT  
AT **Ex. 6 (Personal Privacy)**

Employees on Job

F.P.

Vehicles or Equip. Used

14

**Sewer Department**

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank Pace



<u>Water Department</u>		Comments
Address		SERVICE TRUCK W.O. RE-READS LOCATES
Jobs Completed		
Employees on Job G.F. - F.P. - B.S. - T.C. 4HR 6HR 4HR 2HR		
Vehicles or Equip. Used 2-14-11		
<u>Sewer Department</u>		
Address		BY-PASS PUMPED WITH 3" GAS PUMP AT Ex. 7f (Water Infra.)
Job Completed		CYCLED BLOWERS AT OAKLAND Ex. 7f (Water Infra.) CYCLED PUMP 4 Ex. 6 (Personal Privacy)
Employees on Job B.S. T.C. 4HR		CHECKED SOME STATIONS RE-SET BREAKER AT Ex. 6 (Personal Privacy)
Vehicles or Equip. Used 3		
Meter Readers		
Employees on Job T.C. - F.P. 2HR		FINISHED 26
Areas - Read		
Vehicles Used 2		
General Foreman <u>Franky Boe</u>		

Date 9-8-16

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

**Water Department****Comments**

Address

SERVICE TRUCK W.O.

Jobs Completed

Employees on Job

G.F.

Vehicles or Equip. Used

11

**Sewer Department**

Address

REPLACED FLAPPER IN PUMP AT SUPERIOR  
REMOVED MOTOR & MOTOR PLATE ASSEMBLY  
FROM SUPERIOR PUMP #9 - CLEANED FLOOR

Job Completed

CLEANED & EXERCISED MOTOR PLATE IN SHOP  
SHOOK FLOAT BALLS TO KICK BELLEVIEW ON IN  
THE A.M. & P.M. - RAN BLUFF IN P.M. - BLUFF OFF NOW

Employees on Job

F.P. - B.S. T.C.  
4 HR 4 HRHELPED CENTREVILLE VACUUM OUT WELL AT  
HOTEL BY **Ex. 6 (Personal Privacy)** DUMPED TRUCK  
AT **Ex. 6 (Personal Privacy)**

Vehicles or Equip. Used

14-9

Meter Readers

Employees on Job

F.P. - B.S. - T.C.  
4 HR

FINISHED

19-F.P. &amp; B.S. ~ 24-T.C.

Areas - Read

STARTED

26

Vehicles Used

3-8

General Foreman

Frank J. Pace

Date 9-7-16

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address

SERVICE TRUCK W.O.

Jobs Completed

REPAIRED SERVICE LEAK AT  
MICHAEL DR. - USED ONE 3/4" FLARE X 3/4" COMP.  
ONE METER SHUT OFF, ONE METER BACKSIDE  
ONE 3/4" X 3/4" COMP., 18' OF 3/4" COPPER TUBING

Ex. 6 (Personal Privacy)

Employees on Job

G.F. - B.S. - F.P.

ONE 18" X 30" P.V.C. METER BOX - BACK FILLED  
WITH SPOIL - NEED TO HAUL OFF EXCESS  
DIRT & ROOTS & LIMBS WITH DUMP TRUCK

Vehicles or Equip. Used

11-14-3 - BACKHOE

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

T.C.

FINISHED  
22 & 23

Areas - Read

STARTED  
24

Vehicles Used

8

General Foreman

Frank J. Pace



Date 9-6-16

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

<u>Water Department</u>		Comments
Address	Service TRUCK w/0'S	
Jobs Completed	checked LEAK AT <b>Ex. 6 Personal Privacy</b>	
Employees on Job	BS	
Vehicles or Equip. Used	#11	
<u>Sewer Department</u>		
Address	RAN SOME STATIONS BY PASSED AT 715 <b>Ex. 6 (Personal Privacy)</b>	
Job Completed	AND JUDITH CYCLED BLOWERS ON 73RD TURNED ON Bellevue AND	
Employees on Job	BS - GF RAN BLVTT A BIT	
Vehicles or Equip. Used	#3 - #11	
<u>Meter Readers</u>		
Employees on Job	TC FINISHED 20 - 21 STARTED 22	
Areas - Read		
Vehicles Used	8	
General Foreman	B. Luvil	

Date 9-5-16

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

**Water Department** **Comments**

Address	LABOR
Jobs Completed	
Employees on Job	
Vehicles or Equip. Used	

**Sewer Department**

Address	HOLIDAY
Job Completed	
Employees on Job	
Vehicles or Equip. Used	

**Meter Readers**

Employees on Job	HOLIDAY
Areas - Read	
Vehicles Used	

General Foreman Frank Pace

Date 9-8-16

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address		SERVICE TRUCK W.O.  RE-GRADS
Jobs Completed		REPAIRED YARD WHERE SERVICE LEAK WAS REPAIRED AT <b>Ex. 6 Personal Privacy</b> - HAULED OFF DIRT, HAULED IN GOOD DIRT & ROCKS, GRADED, SEEDED & STRAWED, REPLACED LANDSCAPING & ROCKED PARKING AREA
Employees on Job F.P. - B.S. - G.F. - T.C. 4HR 4HR 2HR		
Vehicles or Equip. Used  11-14-BACKHOE		
<u>Sewer Department</u>		
Address		SHOOK FLOATBALLS TO GET BELLEVUE ON TURNED ON BLUFF & IT PUMPED DOWN & SHUT OFF SHUT OFF BLUFF DUE TO BELLEVUE NOT CYCLING PROPERLY
Job Completed		BY-PASS PUMPED WITH 3" GAS PUMP AT <b>Ex. 7f (Water Infra.)</b> PILE BOX
Employees on Job T.C. - F.P. 6HR 4HR		CYCLED BLOWERS AT OAKLAND & <b>Ex. 6 (Personal Privacy)</b> CYCLED PUMPS ON HAND AT <b>Ex. 6 (Personal Privacy)</b>
Vehicles or Equip. Used  3-14		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Franky Pace</u>		



Date 9-1-16

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O. RE-REASS	
Jobs Completed	REPLACED CRUSHED METER BOX AT Ex. 6 (Personal Privacy) RD, A USED ONE 18"X30" P.V.C. METER BOX	
Employees on Job	G.F. F.P. - B.S. - T.C. 3 HR 3 HR	
Vehicles or Equip. Used	11-14-8 - BACKHOE	
<u>Sewer Department</u>		
Address	CHECKED STATIONS - PUMPED BELLEVUE DOWN & TURNED ON BLUFF PUMPED BLUFF UNTIL 3:55 THEN SHUT OFF DUE TO	
Job Completed	BELLEVUE NOT CYCLING PROPERLY - WE THINK IT IS ON BALL - HAVE TO SHAKE ON BALL TO GET STATION TO KICK ON - WILL PUMP DOWN BUT WON'T COME BACK ON WHEN CALLING BY-PASS PUMPED WITH 3" GAS PUMP AT PILL BOX	
Employees on Job	T.C. - F.P. - B.S. 6 HR 5 HR Ex. 7f (Water Infra.)	
Vehicles or Equip. Used	CYCLED BLOWERS AT OAKLAND AND AT 73RD Ex. 6 (Personal Privacy)	
<u>Meter Readers</u>		
<u>Employees on Job</u>		
<u>Areas - Read</u>		
<u>Vehicles Used</u>		
General Foreman <u>Franky Pace</u>		

Date 10-19-16

Daily Job Sheet

Sheet      of     Water Department

## Comments

Address	SERVICE TRUCK W.O.
Jobs Completed	POT HOLED MAIN ALONG LAKEWOOD FOR BARCO BORE JOB - LOCATED VALVE THAT FEEDS <b>Ex. 6 (Personal Privacy)</b>
Employees on Job G.F. - F.P. - B.S. 3 PR	
Vehicles or Equip. Used 11-2-BACKHOE	

Sewer Department

Address	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT <b>Ex. 7f (Water Infra.)</b> PILE BOX,
Employees on Job G.F. - T.C. 5 PR 2 PR	CYCLED BLOWERS AT <b>Ex. 6 (Personal Privacy)</b> CYCLED PUMPS AT <b>Ex. 6 (Personal Privacy)</b>
Vehicles or Equip. Used 3-9	JETTED LINE + LATERAL TO RELIEVE BACKUP AT <b>Ex. 6 (Personal Privacy)</b>

## Meter Readers

Employees on Job T.C. 6 PR	<del>FINISHED</del> 9
Areas - Read	STARTED
Vehicles Used	

General Foreman

Frank J. Pace



Date 11-30-16

Daily Job Sheet

Sheet 1 of 1Water Department

## Comments

Address

WORK orders  
↓  
LOCATES

Jobs Completed

Employees on Job

BS-GE-TC

Vehicles or Equip. Used

11-8-3

Sewer DepartmentAddress **Ex. 6 Personal Privacy**RESET STARTER ON #2  
PUMP - AT CRESTON & PUMPED  
DOWN

Job Completed

Employees on Job

BS

Vehicles or Equip. Used

11

Meter Readers

Employees on Job

TC

Areas - Read

24  
26

Vehicles Used

8

General Foreman

B. Smith



Date 11-29-16

Daily Job Sheet

Sheet 1 of 1Water DepartmentComments

Address	WORK ORDERS LOCATES
Jobs Completed	
Employees on Job G.F. - BS	
Vehicles or Equip. Used 2-11-14	

Sewer Department

Address	Bellevue STATION CRESTON "
Job Completed	Added OIL TO BLOWER #1 WILL NOT RUN ON HAND
Employees on Job BS	
Vehicles or Equip. Used 14	

Meter ReadersEmployees on Job

TC	
Areas - Read	FINISHED 22 19 23
Vehicles Used 8	
General Foreman	B. Smith

Date 11-28-16

Daily Job Sheet

Sheet 1 of 1**Water Department****Comments**

Address

Service TRUCK W.O.

Jobs Completed

Employees on Job 2 HRS

BS - GF

Vehicles or Equip. Used

11 - 2

**Sewer Department**

Address

Cycled Ex. 6 (Personal Privacy) and BLOWERS ON 73rd  
By PASSED JUDITH - 71ST AND  
PUMPED DOWN Ex. 6 Personal Privacy

Job Completed

CHECKED STATIONS BOTH PHASES  
BS.

Employees on Job 2 HRS

BS  
GF 6 HRS

Vehicles or Equip. Used

3 - 11

**Meter Readers**

Employees on Job

TC 8 HRS

Areas - Read

20-21- STARTED  
22

Vehicles Used

8

General Foreman

B. Amil

Date 11-28-16

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address	SERVICE TRUCK W.O.
Jobs Completed	
Employees on Job F.P. 4HR	
Vehicles or Equip. Used 11	

**Sewer Department**

Address	CYCLER <b>Ex. 6 (Personal Privacy)</b> COULD CLEAN & CAMERA LINE
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT <b>Ex. 7f (Water Infra.)</b> ALL BOX, CALVIN BLVD.
Employees on Job F.P. - G.F. - T.C. 4HR 6HR 3HR	CYCLER BLOWERS A <b>Ex. 6 (Personal Privacy)</b> CYCLER PUMPS AT
Vehicles or Equip. Used 3-11	

**Meter Readers**

Employees on Job T.C. 5HR	FINISHED 18
Areas - Read	
Vehicles Used 8	

General Foreman Frank J. Pace



Date 11-24-14

Daily Job Sheet

Sheet      of     Water Department

## Comments

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

HOLIDAY

A

P  
P

y

T

H A

N  
K

S

G I V I N G  
6

Date 11-25-16

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

Water Department

## Comments

Address

HOLIDAY

Jobs Completed

T  
H  
A

Employees on Job

N  
K  
S

Vehicles or Equip. Used

G<sub>1</sub>Sewer Department

Address

✓  
N  
G

Job Completed

F  
R

Employees on Job

I

Vehicles or Equip. Used

A  
A

Meter Readers

Employees on Job

Y

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 11-22-16

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed		
Employees on Job F.P. 4 HR		
Vehicles or Equip. Used 11		
Sewer Department		
Address	CHECKED STATIONS	
Job Completed	CHANGED OIL IN BLOWERS AT BELLEVUE & BLUFF	
Employees on Job F.P. 4 HR		
Vehicles or Equip. Used 11		
Meter Readers		
Employees on Job G.F. - T.C.	FINISHED 13 & 14 - T.C.      17 - G.F.	
Areas - Read	STARTED 18 - G.F.	
Vehicles Used 8 - 2		
General Foreman <u>Franky. Pace</u>		



Date 11-21-16

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

SERVICE TRUCK W.O.

Jobs Completed

Employees on Job

F.P.  
JHR

Vehicles or Equip. Used

11

**Sewer Department**

Address

Job Completed

BY-PASS PUMPED WITH 3" GAS PUMP AT  
PILL BOX**Ex. 7f (Water Infra.)**

Employees on Job

G.F.  
GHRCYCLED BLOWERS  
CYCLED PUMPS AT**Ex. 7f (Water Infra.)**

Vehicles or Equip. Used

3

**Meter Readers**

Employees on Job

F.B. T.C.  
GHRFINISHED  
15-F.P. 11+12-T.C.

Areas - Read

STARTED  
13-T.C.

Vehicles Used

11-2

General Foreman Frank J. Pace

Date 11-18-16

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

**Water Department****Comments**

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

**Sewer Department**

Address

Job Completed

Employees on Job

F.P. - T.C.

Vehicles or Equip. Used

9-14

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

OVERTIME

JETTED LINE TO RELIEVE BACKUP AT  
Ex. 6 (Personal Privacy)

Date 11-18-16

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

**Water Department****Comments**

Address

SERVICE TRUCK W.O.  
LOCATES

Jobs Completed

Employees on Job

F.P. T.C.  
2HR

Vehicles or Equip. Used

11 - 8

**Sewer Department**

Address

Job Completed

BY-PASS PUMPED WITH 3" GAS PUMP AT  
Ex. 7f (Water Infra.) PILL BOX, CALVIN BLVD

Employees on Job

G.F.

CYCLED BLOWER  
CYCLED PUMPS AT

Ex. 6 (Personal Privacy)

Vehicles or Equip. Used

3

Meter Readers

Employees on Job

T.C.  
6HR

FINISHED AREA 9

Areas - Read

Vehicles Used

8

General Foreman

Franky Pace



Date 11-17-16

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

**Water Department****Comments**

Address

SERVICE TRUCK W.O.

Jobs Completed

Employees on Job

F.P. - T.C.  
5 HR 1 HR

Vehicles or Equip. Used

11-14-16

**Sewer Department**

Address

Job Completed

JETTED LATERAL TO RELIEVE BACKUPS  
AT Y TOWN  
Ex. 6 (Personal Privacy) LATERALS MUST

Employees on Job

F.P. - T.C.  
3 HR

CYCLED BLOWERS AT OAKLAND

Ex. 7f (Water Infra.)

Vehicles or Equip. Used

14-9

**Meter Readers**

Employees on Job

G.F. T.C.  
4 HRFINISHED  
7-8 - G.F.

Areas - Read

STARTED  
9 - T.C.

Vehicles Used

2-8

General Foreman

Frank J. Pace

Date 11-16-16

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address	SERVICE TRUCK W/O.	
Jobs Completed	REBUILT SERVICE & HOOKED UP NEW LINE AT <div>Ex. 6 (Personal Privacy)</div> USED TWO 3/4" X 3/4" COMP. FITTINGS ONE METER SHUTOFF, ONE METER COUPLING, 12' OF 3/4" COPPER TUBING, ONE 18" X 30" P.V.C. METER BOX	
Employees on Job	G.F. (F.P. - B.S.) 3 HR	
Vehicles or Equip. Used	11-14 - BACKHOE	
Sewer Department		
Address	RV-PASS PUMPED WITH 3" GAS PUMP AT <div>Ex. 7f (Water Infra.)</div> RILL BOX	
Job Completed	CYCLED PUMP AT CYCLED BLOWERS AT <div>Ex. 6 (Personal Privacy)</div>	
Employees on Job	JETTED MAIN & TRIED TO JET LATERAL AT <div>Ex. 6 (Personal Privacy)</div> COULDN'T GET THROUGH LATERAL TALKED TO CUST.	
Vehicles or Equip. Used	JETTED LATERAL TO RELIEVE BACKUP AT <div>Ex. 6 (Personal Privacy)</div> <div>Ex. 6 (Personal Privacy)</div> NEEDED TO JET LATERAL AT <div>Ex. 6 (Personal Privacy)</div>	
Meter Readers		
Employees on Job	T.C. 5 HR FINISHED 6	
Areas - Read	STARTED ?	
Vehicles Used	?	
General Foreman	Frank J. Pace	



Date 11-15-16

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address

SERVICE TRUCK W.O.  
LOCATES

Jobs Completed

Employees on Job

G.F.

Vehicles or Equip. Used

11

Sewer Department

Address

REPLACED PART OF DISCHARGE LINE FROM  
BEHIND **Ex. 6 Personal Privacy** - USED ONE 3" FEMALE  
I.P.T. X 3" SCH 40 FITTING ONE 3" SCH 40 X 4" SCH 35  
GLOBE FITTING, ONE 4" FERNCO, 6' OF 4" SCH 35

Job Completed

PIPE, BLOCKING UNDER FITTINGS & BACKFILLED  
WITH ROCK **Ex. 6 Personal Privacy**CHECKED BACKUP CALL IN AT  
LINES DOWN & PUMP PUMPING - COST **PROB. TALKED TO CUST.**

Employees on Job

F.P. - B.S.

CHECKED BACKUP AT **Ex. 6 (Personal Privacy)**  
TO BY-PASS PUMP AT EDNA & SEE IF CLEAN  
OUT DROPS - TALKED TO CUST.

Vehicles or Equip. Used

BACKHOE-14

CHECKED BACKUP CALL AT **Ex. 7f (Water Infra.)** COULDN'T  
FIND CLEANOUT IN YARD DUE TO DOG IN YARD -  
MAIN LINE IS DOWN & FLOWING - PUMPS PUMPING

Meter Readers

Employees on Job

T.C.

FINISHED  
10-5

Areas - Read

Vehicles Used

8

General Foreman

Frank Pace



Water Department		Comments
Address		SERVICE TRUCK WORK ORDERS
Jobs Completed		
Employees on Job BS - GF		
Vehicles or Equip. Used 11 - 3		
Sewer Department		
Address		
Job Completed		BY PASSED BOTH SPOTS ON 71ST RAN BLOWERS ON 73RD RAN <div>Ex. 6 (Personal Privacy)</div> STATION - CHECKED PH 1 SEWERS
Employees on Job BS - GF		
Vehicles or Equip. Used 11 - 3		
Meter Readers		
Employees on Job TC		
Areas - Read		READ 3 & 4
Vehicles Used 8		
General Foreman		B. Smith

Date 11-11-10

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

**Water Department****Comments**

Address

HO

Jobs Completed

L

Employees on Job

1

Vehicles or Equip. Used

D

**Sewer Department**

Address

AY

Job Completed

VETE

Employees on Job

R  
A

Vehicles or Equip. Used

N  
S

Meter Readers

Employees on Job

DAY

Areas - Read

Vehicles Used

General Foreman

Frank J. Pore

Water Department		Comments
Address	SERVICE TRUCK W/O.	
Jobs Completed	Hauled IN DIRT, GRADED, RAKED & SEEDS YARDS WHERE LEAKS WERE REPAIRED AT Ex. 6 (Personal Privacy)	
Employees on Job F.P. - B.S. - T.C.	Ex. 6 (Personal Privacy)	
Vehicles or Equip. Used 14-C-11-BACKHOE	PUT BUCKETS ON ENDS OF 8" MAIN AT AALLIA Ex. 6 (Personal Privacy)	
Sewer Department		
Address		
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT Ex. 7f (Water Infra.) PILL BOX, CALVIN BLVD	
Employees on Job G.F.	CYCLED BLOWERS AT OAKLAND & CYCLED PUMPS AT Ex. 6 (Personal Privacy)	
Vehicles or Equip. Used 3		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J Pace</u>		



Date 11-9-10

Daily Job Sheet

Sheet      of     Water DepartmentComments

Address	SERVICE TRUCK W.O. RE MOVES RE READS
Jobs Completed	EXPOSED MAIN, FOUND LEAK ON SERVICE LINE, SHUT OFF CORP STOP. DISCONNECTED SERVICE LINE, REMOVED RING, LID, BOX & MATERIAL AT <span style="background-color: black; color: red;">Ex. 6 Personal Privacy</span>
Employees on Job F.P. - B.S., T.C. C.F. 4 HR 6.5 HR	BROUGHT FIRE HYDRANT INTO SHOP FROM <span style="background-color: black; color: red;">Ex. 7f (Water Infra.)</span>
Vehicles or Equip. Used 14-11-8 - BACKHOE	

Sewer Department

Address	CHECKED STATIONS CHANGED OIL AT BELLEVUE
Job Completed	CYCLED BLOWERS AT OAKLAND AND AT <span style="background-color: black; color: red;">Ex. 7f (Water Infra.)</span>
Employees on Job F.P. - B.S., 4 HR	
Vehicles or Equip. Used 14	

Meter Readers

Employees on Job T.C. C.F. 4 HR 1 1/2 HR	FINISHED 30 - C.F. 29, 1, & 2 - T.C.
Areas - Read	
Vehicles Used 8-11	
General Foreman <u>Frank J. Pace</u>	

Date 11-8-16

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed		
Employees on Job G.F.		
Vehicles or Equip. Used 11		
<u>Sewer Department</u>		
Address		
Job Completed	CYCLED BLOWERS AT OAKLAND DUE TO BACKUP CALL FROM <span>Ex. 6 (Personal Privacy)</span>	
Employees on Job		
Vehicles or Equip. Used		
<u>Meter Readers</u>		
Employees on Job F.P. - B.S. - T.C.	FINISHED ALL IN LARGE CONSUMERS EXCEPT <span>Ex. 6 (Personal Privacy)</span> DUE TO FIRE DEPT EXERCISES B.S. - T.C.	
Areas - Read	FINISHED 16-25-27 STARTED 30 F.P.	
Vehicles Used 2-8		
General Foreman	Frank J. Pace	



Date 11-7-14

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

SERVICE TRUCK W.O.

RE-READS

LOCATES

Jobs Completed

Employees on Job

B.S. - T.C.  
6 HR 2 HR

Vehicles or Equip. Used

11-14

**Sewer Department**

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT  
**Ex. 7f (Water Infra.)** PILL BOX

Job Completed

CYCLED BLOWERS AT OAKLAND + **Ex. 6 (Personal Privacy)**  
CYCLED PUMPS AT **Ex. 6 (Personal Privacy)**

Employees on Job

T.C. F.P. - G.F. - B.S. - T.C.  
4 HR 3 HRWORKED WITH VISU-SEWER AT **Ex. 6 (Personal Privacy)** TO  
KEEP LINE DOWN BY RUNNING PUMPS ON HAND

Vehicles or Equip. Used

2-3

PULLED PUMPS **Ex. 6 (Personal Privacy)** CLEANED OUT CHECK  
VALVES AT **Ex. 6 (Personal Privacy)** COULDN'T GET PUMPS TO PICK  
UP SUCTION

Meter Readers

Employees on Job

T.C. - B.S.

PASSPORTS WENT DOWN IMMEDIATELY  
IN LARGE CONSUMERS + DRIVE THROUGHS

Areas - Read

Vehicles Used

8

General Foreman

Frank J. Pace



Date 11-4-16

Daily Job Sheet

Sheet      of     

**Water Department**

**Comments**

Address

SERVICE TRUCK W.O.  
LOCATES

Jobs Completed

Employees on Job

F.P. - G.F.

Vehicles or Equip. Used

2-11

**Sewer Department**

Address

CHECKED STATIONS F.P.

Job Completed

CYCLED BLOWERS AT OAKLAND  
CYCLED PUMPS AT

Ex. 7f (Water Infra.)

Ex. 6 (Personal Privacy)

Employees on Job

T.C.

BY-PASS PUMPED WITH 3" GAS PUMP AT

Vehicles or Equip. Used

3

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 11-3-14

## Daily Job Sheet

Sheet      of     Water Department

## Comments

Address

SERVICE TRUCK W.O.

Jobs Completed

REPLACED LEAKING SADDLE  
USED ONE 6" A.C. X 3/4" SADDLE, ONE 3/4" X 3/4" CORP.  
STOP, 18" OF 3/4" COPPER TUBING, ONE 3/4" X 3/4" COMP.

Ex. 6 (Personal Privacy)

Employees on Job

Cof. B.S. - F.P. TK  
5 PMFITTING, BACKFILLED WITH SPOIL - LEFT  
CORP OFF AT MAIN DUE TO TAMPERING IN  
BOX.

Vehicles or Equip. Used

11 - 14 - BACKHOE

LOCATED VALVES AT  
Ex. 6 Personal Privacy  
Ex. 6 Personal PrivacySewer Department

Address

CHECKED STATIONS ON NORTH SIDE &  
SNOWS & BRIDGE DALE

Job Completed

REPLACED BROKEN FERNCO ON SUMP  
PUMP AT  
Ex. 7f (Water Infra.) FILL BOX

Employees on Job

F.P. - B.S.  
3 PM

Vehicles or Equip. Used

14

Meter Readers

Employees on Job

T.C.  
3 PMFINISHED  
24

Areas - Read

Vehicles Used

8

General Foreman

Frank J. Pace

Date 11-2-14

Daily Job Sheet

Sheet      of     **Water Department****Comments**

Address

SERVICE TRUCK W.O.  
LOCATES

Jobs Completed

Employees on Job

F.P. G.F.  
4 HR 4 HR

Vehicles or Equip. Used

2-11

**Sewer Department**

Address

CHANGED OIL IN BLOWER AT BELLEVUE  
PICKED UP VACUUM TUBES FROM

Ex. 6 Personal Privacy

Job Completed

BY-PASS PUMPED WITH 3" GAS PUMP AT  
Ex. 7f (Water Infra.) PILL BOX,

Employees on Job

B.S.

CYCLED PUMPS AT Ex. 6 (Personal Privacy)  
CYCLED BLOWERS AT OAKLAND & Ex. 7f (Water Infra.)

Vehicles or Equip. Used

3

**Meter Readers**

Employees on Job

F.P. - G.F.  
4 HRFINISHED  
19-F.P. & G.F. 23:26 T.C.

Areas - Read

STARTED  
24 T.C.

Vehicles Used

2

General Foreman

Frank J. Pace



Date 11-1-16

## Daily Job Sheet

Sheet      of     Water Department

## Comments

Address

SERVICE TRUCK W.O.

Jobs Completed

LOCATED 10" D.I. WATER MAIN ALONG  
OLD MO. AVE FOR BERCO

Employees on Job

F.P. - B.S. - G.F.  
7 HRLOCATED MAIN IN  
NORTH BORK JOB

Ex. 6 (Personal Privacy) FOR

Vehicles or Equip. Used

11-14- BACKHOLE

Sewer Department

Address

CHECKED SEWER BACKUP AT  
N. 80TH - CUST. PROB. - BELLEVUE & BLUFF  
PUMPING & WELLS DOWN

Ex. 6 (Personal Privacy)

Job Completed

CHECKED BACKUP AT  
OUR LINES DOWN - CUST PROB.

Ex. 6 (Personal Privacy)

Employees on Job

T.C. B.S. F.P.  
4 HR 1 HRJETTED LINE ON BROADWAY FOR  
CENTRE VILLE - T.C. 4 HR

Vehicles or Equip. Used

9-14

CYCLED PUMP AT

Ex. 6 Personal Privacy

Meter Readers

Employees on Job

TC  
4 HRFINISHED  
22

Areas - Read

Vehicles Used

8

General Foreman

Frank J. Pace

Date 12-30-16

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address	SERVICE TRUCK W.O. LOCATING	
Jobs Completed		
Employees on Job	F.P. 4 HR	
Vehicles or Equip. Used	11	
Sewer Department		
Address	PULLED PUMP & CLEANED OUT RAGS AT Ex. 7f (Water Infra.) - PERSHING BACK ON CHECKED STATIONS - BELL VIEW BREAKER	
Job Completed	KICKED OUT - RE-SET BREAKER - TRIED TO TURN BLUFF ON BUT STARTED TO SURCHARGE OUT OF M.H. - BLUFF IS OFF	
Employees on Job	BY-PASS PUMPED WITH 3" GAS PUMP AT Ex. 7f (Water Infra.) AMELIA	
Vehicles or Equip. Used	CYCLED PUMP AT Ex. 6 (Personal Privacy) CYCLED BLOWERS AT OAKLAND & Ex. 6 Personal Privacy	
3-14 - BACKHOE		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		



Date 12-29-16

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed		
Employees on Job F.P. - G.F. 4HR 4HR		
Vehicles or Equip. Used 11-3		
<b>Sewer Department</b>		
Address	BY-PASS PUMPED WITH GAS PUMP AT <b>Ex. 7f (Water Infra.)</b> - CALVIN BLVD. CHANGED OIL AT BELLVIEW	
Job Completed	CHECKED STATIONS ON NORTH END - BY-PASS PUMP AT CLINTON WAS RUNNING BUT NOT PUMPING - SHUT OFF BREAKER - SHUT OFF PERSHING AT POLE - NEED TO PULL BY-PASS	
Employees on Job G.F. - F.P. - T.C. 4HR 4HR 2HR	MADE HOLDER FOR MOTOR AT SUPERIOR - PUMPING & WELL DOWN WHEN LAST CHECKED NEED TO RECTIFY PROBLEM SOME WAY	
Vehicles or Equip. Used 3-14-8	CHECKED FOR BACKUP AT <b>Ex. 6 (Personal Privacy)</b> OUR LINES ARE DOWN BUT NEED CLEANED - TALKED TO CUST & TOLD HIM WE WOULD BE OUT AFTER THE NEW YEAR	
<b>Meter Readers</b>		
Employees on Job T.C. 6HR	FINISHED 23	
Areas - Read	STARTED 24	
Vehicles Used 8		
General Foreman <u>Frank J. Ace</u>		



Date 12-28-16

## Daily Job Sheet

Sheet      of     

Water Department		Comments
Address	SERVICE TRUCK W/O. SHUT OFFS - OURS & VILLAGES	
Jobs Completed		
Employees on Job F.P. - G.F. 6 HR 5.5 HR		
Vehicles or Equip. Used 2-11		
<b>Sewer Department</b>		
Address	BELLEVIEW BREAKER KICKED OUT - RESET & PUMPING NOW - BLUFF OFF DUE TO SURCHARGE IN STREET	
Job Completed	JACKETED LINE TO RELIEVE BACKUP AT Ex. 6 (Personal Privacy)	
Employees on Job F.P. - T.C. - G.F. 2 HR 2 HR 1 HR		
Vehicles or Equip. Used 2-11-9		
<b>Meter Readers</b>		
Employees on Job G.F. T.C. 1.5 HR 6 HR	FINISHED 21-G.F. 22-T.C.	
Areas - Read	STARTED 23-T.C.	
Vehicles Used 8		
General Foreman <u>Frank J. Pace</u>		

Date 12-27-16

Daily Job Sheet

Sheet      of     

Water Department		Comments
Address	REPLACED METER SHUT OFF & METER COUPLING, TURNED ON CORP. STOP AT MAIN, INSTALLED METER & TURNED ON SERVICE FOR CUSTOMER AT <b>Ex. 6 (Personal Privacy)</b>	
Jobs Completed	SERVICE TRUCK W.O.	
Employees on Job F.P. - T.C. GMR JMR		
Vehicles or Equip. Used 14-11-BACKHOLE		
<b>Sewer Department</b>		
Address	CYCLED PUMP AT <b>Ex. 6 (Personal Privacy)</b> CYCLED BLOWERS AT OAKLAND <b>Ex. 7f (Water Infra.)</b>	
Job Completed	BY-PASS PUMPED WITH GAS PUMP AT <b>Ex. 7f (Water Infra.)</b> PILL BOX	
Employees on Job G.F.		
Vehicles or Equip. Used 3		
<b>Meter Readers</b>		
Employees on Job F.P. T.C. JMR GMR	FINISHED 19-F.P.-T.C. 20-T.C.	
Areas - Read	STARTED 21	
Vehicles Used 8		
General Foreman <u>Franky Pace</u>		

Date 12-26-16

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address		
Jobs Completed		H
Employees on Job		O
Vehicles or Equip. Used		2
		1
<u>Sewer Department</u>		
Address		
Job Completed		D
Employees on Job		A
Vehicles or Equip. Used		Y
Meter Readers		
Employees on Job		
Areas - Read		M
Vehicles Used		A
		5
General Foreman		<u>Frank J. Pace</u>



Date 12-23-14

Daily Job Sheet

Sheet \_\_\_\_ of \_\_\_\_

Water Department		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed		
Employees on Job F.P.		
Vehicles or Equip. Used 11		
Sewer Department		
Address		
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT <b>Ex. 7f (Water Infra.)</b> PILL BOX,	
Employees on Job T.C.	CYCLED BLOWERS AT OAKLAND * <b>Ex. 6 Personal Privacy</b> CYCLED PUMP AT <b>Ex. 6 (Personal Privacy)</b>	
Vehicles or Equip. Used 3		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Franky Pace</u>		

Water Department		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed		
Employees on Job	F.P.	
Vehicles or Equip. Used	11	
Sewer Department		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
Meter Readers		
Employees on Job	T.C. FINISHED 17 & 18	
Areas - Read		
Vehicles Used	8	
General Foreman <u>Frank J. Pace</u>		

Date 12-21-16

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W/O.	
Jobs Completed	REMOVED HYDRANT HIT BY CAR AT MAPLE TREE - INSTALLED ONE 50' EXTREME DRESSER - 2" OF 6" C-900	
Employees on Job F.P. - T.C. 4HR	P.V.C. & ONE CLOW 2014 GATE VALVE & BLOCKING - NEEDED TO SET VALVE BOX & GRADE YARD	
Vehicles or Equip. Used 11-14 - BACKHOLE		
<u>Sewer Department</u>		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
Meter Readers		
Employees on Job T.C. 4HR	STARTED 17	
Areas - Read		
Vehicles Used 8		
General Foreman	Francis J. Pace	



Date 12-21-16

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

<u>Water Department</u>		Comments
Address		OVER TIME - 1 HR.
Jobs Completed		INSTALLED 501 EXTREME DRESSER, 6" VALVE BLOCKING WHERE CAR HIT HYDRANT AT MAPLE TREE
Employees on Job F.P. - T.C. 1 HR OT		
Vehicles or Equip. Used 14-BACKHOE		
<u>Sewer Department</u>		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Franky Pace</u>		

Date 12-20-16

Daily Job Sheet

Sheet \_\_\_ of \_\_\_

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W/O.	
Jobs Completed	SHUT OFF SERVICE AT CORP. STOP TO STOP LEAK IN BOX AT <b>Ex. 6 Personal Privacy</b> - NEED TO REBUILD SERVICE WHEN PEOPLE OCCUPY HOUSE	
Employees on Job F.P. - T.C. 2 HR		
Vehicles or Equip. Used 11-14- BACKHOE		
<u>Sewer Department</u>		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
<u>Meter Readers</u>		
Employees on Job T.C. 6 HR	FINISHED 15	
Areas - Read		
Vehicles Used		
General Foreman	Frank J. Pace	

Date 12-19-16

Daily Job Sheet

Sheet      of     

<u>Water Department</u>		Comments
Address	TRUCK #11 SERVICE TRUCK W. O. RE - CHECKS RE - READS	
Jobs Completed		
Employees on Job F.P.		
Vehicles or Equip. Used 11		
<u>Sewer Department</u>		
Address		
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT <b>Ex. 7f (Water Infra.)</b> PILL BOX	
Employees on Job T.C.	CYCLED PUMP AT CYCLED BLOWERS AT OAKLAND <b>Ex. 6 (Personal Privacy)</b>	
Vehicles or Equip. Used 3		
<u>Meter Readers</u>		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman	<u>Frank J. Pace</u>	



Date 12-16-16

Daily Job Sheet

Sheet     of    


Water Department		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed	REPAIRED MAIN BREAK AT <span>Ex. 6 Personal Privacy</span> USED TWO 501 DRESSERS, 18' OF 2" P.V.C. BACKFILLED WITH SAND + ROCK FROM VILLAGE	
Employees on Job	F.P. - T.C.    G.F. 2 HR    1.5	
Vehicles or Equip. Used	14 - BACKHOLE - 11	
Sewer Department		
Address		
Job Completed	BY-PASS PUMPED WITH 3" PUMP AT <span>Ex. 7f (Water Infra.)</span> PILL BOX, BLVD	
Employees on Job	CYCLED PUMP AT <span>Ex. 6 (Personal Privacy)</span> G.F. <span>Ex. 7f (Water Infra.)</span> 6 1/2 HR    CYCLED BLOWERS AT OAKLAND AND AT	
Vehicles or Equip. Used	3	
Meter Readers		
Employees on Job	T.C. 2 HR    FINISHED 14	
Areas - Read		
Vehicles Used	8	
General Foreman	Frank J. Pace	

<u>Water Department</u>		Comments
Address		SERVICE TRUCK W.O, LOCATES
Jobs Completed		REPLACED LEAKING SADDLES AT Ex. 6 (Personal Privacy) USED TWO 6" A.C. SADDLES, ONE 3/4" COMP. FITTING, TWO CORR. STOPS, BACK FILLED WITH SAND & CMC FROM SHOP
Employees on Job		
G.F. - F.P. - T.C. - B.S. JMR GHR		
Vehicles or Equip. Used		
11-14-6- BACKHOL		
<u>Sewer Department</u>		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
Meter Readers		
Employees on Job		FINISHED 12 + 13
T.C.		
Areas - Read		
Vehicles Used		8
General Foreman		Frank J. Pace

Date 12-14-16

Daily Job Sheet

Sheet 1 of 1

Water Department		Comments
Address		WORK orders + LOCATES
Jobs Completed		
Employees on Job BS 8 HRS GF 4 HRS		
Vehicles or Equip. Used 3- 11		
Sewer Department		
Address		
Job Completed		
Employees on Job GF 4 HRS		cycled BLOWERS AT 73rd TRIED TO Pump Ex. 7f (Water Infra.) NO SUCCESS
Vehicles or Equip. Used 3		
Meter Readers		
Employees on Job TC		READ 9 & 11 STARTED 12
Areas - Read		
Vehicles Used 8		
General Foreman		



Date 7-2-12-76

Daily Job Sheet

Sheet 1 of 1Water DepartmentComments

Address

RUN WORK ORDERS

Jobs Completed

Employees on Job

BS

Vehicles or Equip. Used

11

Sewer Department

Address

TAPPED M.H. Behind

Ex. 6 Personal Privacy

BY PASSED 71<sup>ST</sup> ST CYCLED

Job Completed

BLOWERS AT 73<sup>RD</sup> - ALSO

Ex. 6 (Personal Privacy)

VIOLET

Ex. 7f (Water Infra.)

Employees on Job

GF

Vehicles or Equip. Used

3

Meter Readers

Employees on Job

TC

Areas - Read

READ 6, 7. STARTED 8

Vehicles Used

8

General Foreman

B. Smith

Date 12-13-16

Daily Job Sheet

Sheet 1 of 1Water DepartmentComments

Address

WORK ORDERS 1 HR.

Jobs Completed

Employees on Job

TC

Vehicles or Equip. Used

2

Sewer Department

Address

Ex. 6 (Personal Privacy)

Job Completed

RAN NEW 4" PVC LINE INTO  
M. H. IN ALLEY

Employees on Job

BS-GF

Vehicles or Equip. Used

3- BACKHOE

8 PIECES 4" SDR35

1 450 GLUE

1 SWEEP

2 22 1/2" GIVE

1 4" FERNCO

Meter Readers

Employees on Job

TC

Areas - Read

FINISHED 8 STARTED 9

Vehicles Used

8

General Foreman

B. Smith

Date 12-9-16

Daily Job Sheet

Sheet 1 of 1Water DepartmentComments

Address

RAN WORK orders  
&  
LOCATES

Jobs Completed

Employees on Job

BS

Vehicles or Equip. Used

11

Sewer Department

Address

BY PASSED BOTH SPOTS ON 71ST  
PUMP - CYCLED BLOWERS ON  
73RD BY PASSED JUDITH - PUMPED DOWN  
VIOLET

Job Completed

CHANGED THE OIL IN 3" PUMP

Employees on Job

GF

Vehicles or Equip. Used

3

Meter Readers

Employees on Job

TL

READ AREA 5 + 10  
STARTED AREA 6

Areas - Read

Vehicles Used

8

General Foreman

B. Smith



Date 12-8-16

Daily Job Sheet

Sheet 1 of 1**Water Department****Comments**

Address

WORK ORDERS

Jobs Completed

Employees on Job

BS

Vehicles or Equip. Used

11

**Sewer Department**

Address

Ex. 6 Personal Privacy

Job Completed

Tapped line Behind

Ex. 6 (Personal Privacy)

Employees on Job

BS - TC

CLEANED ALLEY FOR SEWER  
LINE INSTALLATION

Vehicles or Equip. Used

JET TRUCK  
BACK HOSE

Meter Readers

Employees on Job

TC

Areas - Read

4-5

finished 4

STARTED 5

Vehicles Used

8

General Foreman

B. Smith

Date 12-7-16

Daily Job Sheet

Sheet 1 of 1**Water Department****Comments**

Address

WORK orders  
LOCATES

Jobs Completed

Employees on Job

BS- GF

Vehicles or Equip. Used

3- 11

**Sewer Department**

Address

71ST ST  
JUDITH  
VIOLETBy PASSED  
RAN PUMP AT

Ex. 6 Personal Privacy

Ex. 6 Personal Privacy

Job Complete

Ex. 6 (Personal Privacy)

73rd BLOWERS

CYCLED BLOWERS AT 73rd ST.

Employees on Job

Vehicles or Equip. Used

3

**Meter Readers**

Employees on Job

TC

Areas - Read

READ 3  
STARTED 4

Vehicles Used

8

General Foreman

B. Smith

Date 12-6-16

Daily Job Sheet

Sheet 1 of 1Water DepartmentComments

Address

WORK orders  
CLEANed GARAGE  
LOCATES

Jobs Completed

Employees on Job

GF-BS-TC

Vehicles or Equip. Used

#11 - #8 #3

Sewer Department

Address

Job Completed

Re-wound hose ON VACTOR

Employees on Job

BS-TC

Vehicles or Equip. Used

VACTOR

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman





Date 12-5-16

Daily Job Sheet

Sheet 1 of 1

Water Department		Comments
Address	Service TRUCK WORK orders	
Jobs Completed		
Employees on Job BS- GF		
Vehicles or Equip. Used 11- 3		
Sewer Department		
Address	BY PASSED 7151 ST- AND CYCLED <span style="background-color: black; color: red;">Ex. 6 Personal Privacy</span>	
Job Completed	CHECKED PH #1 STATIONS AND CRESTON	
Employees on Job BS- GF	BY PASSED JUDITH	
Vehicles or Equip. Used 11		
Meter Readers		
Employees on Job TC		
Areas - Read	25- 27- 30	
Vehicles Used 8		
General Foreman	B. Smith	

Date 12-2-16

Daily Job Sheet

Sheet 1 of 1**Water Department****Comments**

Address

WORK ORDERS  
+  
LOCATES

Jobs Completed

Employees on Job

BS

Vehicles or Equip. Used

11

**Sewer Department**

Address

CHECKED CRESTON STATION

Job Completed

Employees on Job

BS

Vehicles or Equip. Used

11

**Meter Readers**

Employees on Job

TC


29, 16, 1+2

Areas - Read

Vehicles Used

8

General Foreman



Date 12-1-16

Daily Job Sheet

Sheet 1 of 1Water DepartmentComments

Address

COOPER ST

REPAIRED 4" C.I. MAIN WITH  
REPAIR CLAMP. BACK FILLED WITH  
A LOAD OF 1" CLEAN & TOPPED OFF  
WITH CMK

Jobs Completed

Employees on Job

BS GF TC

TRUCK 11 RAN W/O'S  
IN AFTER NOON

Vehicles or Equip. Used

14 9 BACKHOE

Sewer Department

Address

Ex. 6 Personal Privacy

CHECKED ON CRESTON

Job Completed

REMOVED PAPER FROM MOUTH  
OF PIPE IN M. H.

Employees on Job

BS GF

Vehicles or Equip. Used

2- 11

Meter Readers

Employees on Job

TC

Areas - Read

STARTED #29

Vehicles Used

8

General Foreman

B. Smith